

. . . Fire Protection by Computer Design

Denali Fire protection, Inc.
270 Tiger Hill Road
Your Street Address 2
Oxford, Maine 04270
207-539-4226

Job Name : W.B. MASON NEW LOADING DOCK ADDITION
Building : STEEL STRUCTURE
Location : 106 PINE TREE INDUSTRIAL PARKWAY PORTLAND, MAINE
System : 1
Contract : C6-10
Data File : 1-C610.WXF

Hydraulic Design Information Sheet

Name - W.B. MASON Date - 02/15/10
Location - 106 PINE TREE INDUSTRIAL PARKWAY PORTLAND, MAINE
Building - STEEL STRUCTURE System No. - 1
Contractor - DENALI FIRE PROTECTION, INC. Contract No. - C6-10
Calculated By - CKD Drawing No. - 3
Construction: () Combustible (X) Non-Combustible Ceiling Height - VARIES
Occupancy - LOADING DOCK

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C (X) Figure 11.2.3.1.1 Curve OH II
S Other AREA REDUCED PER NFPA 13 SECTION 11.2.3.2.3.1
T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 1060	System Type	Sprinkler/Nozzle
	Density	- .2	(X) Wet	Make VICTAULIC
D	Area Per Sprinkler	- 117	() Dry	Model V2704
E	Elevation at Highest Outlet	- 114.83	() Deluge	Size 1/2"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155
G	Hose Allowance - Outside	-		

N Note

Calculation Flow Required - 508.661 Press Required - 43.522 AT TEST
Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 06/14/93		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 75	@ Press -	
R	Residual Press - 66	Elev. -	Well
	Flow - 1125		Proof Flow
S	Elevation - 100.0		

U Location - 100'-0" FROM THE BUILDING
P
L Source of Information - PORTLAND WATER DISTRICT
Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row	() Open Shelf	
O			
R	Flue Spacing	Clearance:Storage to Ceiling	
A	Longitudinal	Transverse	
G			
E	Horizontal Barriers Provided:		


Water Supply Curve (C)

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 2
Date 02/15/10

City Water Supply:
C1 - Static Pressure : 75
C2 - Residual Pressure: 66
C2 - Residual Flow : 1125

Demand:
D1 - Elevation : 10.178
D2 - System Flow : 258.661
D2 - System Pressure : 43.522
Hose (Adj City) : _____
Hose (Demand) : 250
D3 - System Demand : 508.661
Safety Margin : 29.405



Fittings Used Summary

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 3
Date 02/15/10

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
A	Generic Alarm Valve	0	0	0	0	0	0	7.7	21.5	0	17	17	27	29	0	0	0	0	0	0	0	0
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 4
Date 02/15/10

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	123.5	5.6	19.6	na	24.79	0.2	117	7.0
2	123.5	5.6	17.46	na	23.4	0.2	117	7.0
2A	123.5		19.69	na				
3	123.5	5.6	19.81	na	24.92	0.2	117	7.0
4	123.5	5.6	20.17	na	25.15	0.2	117	7.0
5	123.5	5.6	20.79	na	25.53	0.2	117	7.0
6	123.5	5.6	21.74	na	26.11	0.2	117	7.0
7	123.5	5.6	23.32	na	27.04	0.2	117	7.0
8	123.5	5.6	23.37	na	27.07	0.2	117	7.0
9	123.5	5.6	23.58	na	27.19	0.2	117	7.0
10	123.5	5.6	24.02	na	27.45	0.2	117	7.0
A	123.5		26.65	na				
B	123.5		26.73	na				
C	123.5		27.74	na				
D	123.5		32.4	na				
TI	123.5		32.87	na				
BASE	101.0		42.75	na				
TEST	100.0		43.52	na	250.0			

The maximum velocity is 13.16 and it occurs in the pipe between nodes 6 and A

Final Calculations - Hazen-Williams

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 5
Date 02/15/10


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1 to 2A	24.79 24.79	2.157 120 0.0058	1T	12.307 0.0	2.370 12.307 14.677	19.601 0.0 0.085			K Factor = 5.60	
	0.0 24.79						19.686		K Factor = 5.59	
2 to 2A	23.40 23.4	1.049 120 0.1740	1E 1T	2.0 5.0 0.0	5.790 7.000 12.790	17.460 0.0 2.226			K Factor = 5.60	
2A to 3	24.79 48.19	2.157 120 0.0197		0.0 0.0 0.0	6.040 0.0 6.040	19.686 0.0 0.119				Vel = 4.23
3 to 4	24.92 73.11	2.157 120 0.0429		0.0 0.0 0.0	8.420 0.0 8.420	19.805 0.0 0.361			K Factor = 5.60	Vel = 6.42
4 to 5	25.15 98.26	2.157 120 0.0739		0.0 0.0 0.0	8.420 0.0 8.420	20.166 0.0 0.622			K Factor = 5.60	Vel = 8.63
5 to 6	25.53 123.79	2.157 120 0.1133		0.0 0.0 0.0	8.420 0.0 8.420	20.788 0.0 0.954			K Factor = 5.60	Vel = 10.87
6 to A	26.12 149.91	2.157 120 0.1615	1T	12.307 0.0	18.080 12.307 30.387	21.742 0.0 4.906			K Factor = 5.60	Vel = 13.16
	0.0 149.91						26.648		K Factor = 29.04	
7 to 8	27.04 27.04	2.157 120 0.0068		0.0 0.0 0.0	8.420 0.0 8.420	23.318 0.0 0.057			K Factor = 5.60	Vel = 2.37
8 to 9	27.08 54.12	2.157 120 0.0245		0.0 0.0 0.0	8.420 0.0 8.420	23.375 0.0 0.206			K Factor = 5.60	Vel = 4.75
9 to 10	27.19 81.31	2.157 120 0.0521		0.0 0.0 0.0	8.420 0.0 8.420	23.581 0.0 0.439			K Factor = 5.60	Vel = 7.14
10 to B	27.45 108.76	2.157 120 0.0891	1T	12.307 0.0	18.080 12.307 30.387	24.020 0.0 2.709			K Factor = 5.60	Vel = 9.55
	0.0 108.76						26.729		K Factor = 21.04	
A to B	149.91 149.91	4.26 120 0.0059		0.0 0.0 0.0	13.790 0.0 13.790	26.648 0.0 0.081				Vel = 3.37
B to C	108.75 258.66	4.26 120 0.0161	1T	26.334 0.0	36.330 26.334 62.664	26.729 0.0 1.009				Vel = 5.82
C to D	0.0 258.66	4.26 120 0.0161	4L 1T	31.601 26.334 0.0	231.500 57.935 289.435	27.738 0.0 4.662				Vel = 5.82

Final Calculations - Standard

Denali Fire protection, Inc.
 W.B. MASON NEW LOADING DOCK ADDITION

Page 6
 Date 02/15/10

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D to TI	0.0 258.66	6.357 120 0.0023	2L 22.632 0.0	181.870 22.632 204.502	32.400 0.0 0.469		Vel = 2.61		
TI to BASE	0.0 258.66	6.357 120 0.0023	1A 33.948 1B 12.573 0.0	14.000 46.521 60.521	32.869 9.745 0.138		Vel = 2.61		
BASE to TEST	0.0 258.66	6.16 140 0.0020	1E 20.084 1G 4.304 1T 43.037	100.000 67.425 167.425	42.752 0.433 0.337		Vel = 2.78		
	250.00 508.66				43.522		Qa = 250.00 K Factor = 77.10		



. . . Fire Protection by Computer Design

Denali Fire protection, Inc.
270 Tiger Hill Road
Your Street Address 2
Oxford, Maine 04270
207-539-4226

Job Name : W.B. MASON NEW LOADING DOCK ADDITION
Building : STEEL STRUCTURE
Location : 106 PINE TREE INDUSTRIAL PARKWAY PORTLAND, MAINE
System : 1
Contract : C6-10
Data File : 2-C610.WXF

Hydraulic Design Information Sheet

Name - W.B. MASON Date - 02/15/10
Location - 106 PINE TREE INDUSTRIAL PARKWAY PORTLAND, MAINE
Building - STEEL STRUCTURE System No. - 1
Contractor - DENALI FIRE PROTECTION, INC. Contract No. - C6-10
Calculated By - CKD Drawing No. - 3
Construction: () Combustible (X) Non-Combustible Ceiling Height - 10'-0"
Occupancy - SALES FLOOR

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C (X) Figure 11.2.3.1.1 Curve OH II
S Other AREA REDUCED PER NFPA 13 SECTION 11.2.3.2.3.1
T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 944	System Type	Sprinkler/Nozzle
	Density	- .2	(X) Wet	Make VICTAULIC
D	Area Per Sprinkler	- 111	() Dry	Model V2708
E	Elevation at Highest Outlet	- 123.46	() Deluge	Size 1/2"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155
G	Hose Allowance - Outside	-		

N Note

Calculation Flow Required - 484.333 Press Required - 53.288 AT TEST
Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 06/14/93		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 75	@ Press -	
R	Residual Press - 66	Elev. -	Well
	Flow - 1125		Proof Flow
S	Elevation - 100.0		

U Location - 100'-0" FROM THE BUILDING
P
L Source of Information - PORTLAND WATER DISTRICT
Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf
O			
R	Flue Spacing	Clearance:Storage to Ceiling	
A	Longitudinal	Transverse	
G			
E	Horizontal Barriers Provided:		


Water Supply Curve (C)

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 2
Date 02/15/10

City Water Supply:
C1 - Static Pressure : 75
C2 - Residual Pressure: 66
C2 - Residual Flow : 1125

Demand:
D1 - Elevation : 10.161
D2 - System Flow : 234.333
D2 - System Pressure : 53.288
Hose (Adj City) : _____
Hose (Demand) : 250
D3 - System Demand : 484.333
Safety Margin : 19.819



Fittings Used Summary

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 3
Date 02/15/10

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
A	Generic Alarm Valve	0	0	0	0	0	0	7.7	21.5	0	17	17	27	29	0	0	0	0	0	0	0	0
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 4
Date 02/15/10

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D1	0.0	5.6	15.72	na	22.2	0.2	111	7.0
11	123.46	K = K @ L1	18.24	na	23.23			
12	123.46	K = K @ L1	18.35	na	23.3			
13	123.46	K = K @ L1	18.85	na	23.61			
14	123.46	K = K @ L1	19.91	na	24.27			
15	123.46	K = K @ L1	21.75	na	25.37			
16	123.46	K = K @ L1	16.66	na	22.2			
17	123.46	K = K @ L1	16.79	na	22.28			
18	123.46	K = K @ L1	17.25	na	22.59			
19	123.46	K = K @ L1	18.23	na	23.22			
20	123.46	K = K @ L1	19.93	na	24.28			
E	123.46		41.61	na				
F	123.46		41.65	na				
TOR	123.46		42.64	na				
TI	114.83		46.47	na				
BASE	101.0		52.57	na				
TEST	100.0		53.29	na	250.0			

The maximum velocity is 17.29 and it occurs in the pipe between nodes 15 and E

Final Calculations - Hazen-Williams

Denali Fire protection, Inc.
W.B. MASON NEW LOADING DOCK ADDITION

Page 5
Date 02/15/10

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D1 to L1	22.20 22.2	1.049 120 0.1578	1T	5.0 0.0 0.0	1.000 5.000 6.000	15.716 0.0 0.947			K Factor = 5.60 Vel = 8.24	
	0.0 22.20						16.663		K Factor = 5.44	
11 to 12	23.23 23.23	1.682 120 0.0173		0.0 0.0 0.0	6.000 0.0 6.000	18.244 0.0 0.104			K Factor @ node L1 Vel = 3.35	
12 to 13	23.30 46.53	1.682 120 0.0622		0.0 0.0 0.0	8.000 0.0 8.000	18.348 0.0 0.498			K Factor @ node L1 Vel = 6.72	
13 to 14	23.61 70.14	1.682 120 0.1330		0.0 0.0 0.0	8.000 0.0 8.000	18.846 0.0 1.064			K Factor @ node L1 Vel = 10.13	
14 to 15	24.26 94.4	1.682 120 0.2305		0.0 0.0 0.0	8.000 0.0 8.000	19.910 0.0 1.844			K Factor @ node L1 Vel = 13.63	
15 to E	25.37 119.77	1.682 120 0.3579	1T	9.9 0.0 0.0	45.580 9.900 55.480	21.754 0.0 19.858			K Factor @ node L1 Vel = 17.29	
	0.0 119.77						41.612		K Factor = 18.57	
16 to 17	22.20 22.2	1.682 120 0.0158		0.0 0.0 0.0	8.000 0.0 8.000	16.663 0.0 0.126			K Factor @ node L1 Vel = 3.21	
17 to 18	22.28 44.48	1.682 120 0.0574		0.0 0.0 0.0	8.000 0.0 8.000	16.789 0.0 0.459			K Factor @ node L1 Vel = 6.42	
18 to 19	22.59 67.07	1.682 120 0.1224		0.0 0.0 0.0	8.000 0.0 8.000	17.248 0.0 0.979			K Factor @ node L1 Vel = 9.68	
19 to 20	23.22 90.29	1.682 120 0.2122		0.0 0.0 0.0	8.000 0.0 8.000	18.227 0.0 1.698			K Factor @ node L1 Vel = 13.04	
20 to F	24.28 114.57	1.682 120 0.3297	3L 1T	7.425 9.9 0.0	48.580 17.325 65.905	19.925 0.0 21.730			K Factor @ node L1 Vel = 16.54	
	0.0 114.57						41.655		K Factor = 17.75	
E to F	119.77 119.77	4.26 120 0.0039		0.0 0.0 0.0	11.000 0.0 11.000	41.612 0.0 0.043			Vel = 2.70	
F to TOR	114.56 234.33	4.26 120 0.0134	1L	7.9 0.0 0.0	65.580 7.900 73.480	41.655 0.0 0.985			Vel = 5.27	
TOR to TI	0.0 234.33	6.357 120 0.0019	1T	37.72 0.0 0.0	10.000 37.720 47.720	42.640 3.738 0.091			Vel = 2.37	

Final Calculations - Standard

Denali Fire protection, Inc.
 W.B. MASON NEW LOADING DOCK ADDITION

Page 6
 Date 02/15/10

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TI to BASE	0.0 234.33	6.357 120 0.0019	1A 33.948 1B 12.573 0.0	14.000 46.521 60.521	46.469 5.990 0.115		Vel = 2.37		
BASE to TEST	0.0 234.33	6.16 140 0.0017	1E 20.084 1G 4.304 1T 43.037	100.000 67.425 167.425	52.574 0.433 0.281		Vel = 2.52		
	250.00 484.33				53.288		Qa = 250.00 K Factor = 66.35		