


**NOTES:**

- 1. INSTALL (3) 2" SCH 80 PVC CONDUIT AND (1) 1-1/2" SCH 80 PVC CONDUIT UNDERGROUND TO NEAREST QUAZITE BOX. LABEL CONDUIT ENDS.
- 2. INSTALL (2) 2" SCH 80 PVC CONDUIT UNDERGROUND AND STUBBED INTO ELECTRICAL ROOM. INSTALL 1" C TO BUILDING WITH CONNECTION TO MASTER AIPHONE STATION IN DISPATCH OFFICE. ROUTE CONDUITS THROUGH QUAZITE BOX IN THIS AREA.
- 3. INSTALL IN-GROUND 13" X 24" QUAZITE BOX. ROUTE ALL ACCESS CONTROL, CALL BOX, AND RFID CONDUITS AND CIRCUITS THROUGH THE QUAZITE BOX IN THE ASSOCIATED AREA.
- 4. INSTALL (3) 2" CONDUITS & (3) 1" CONDUIT FROM QUAZITE BOX TO ELECTRICAL ROOM.
- 5. INSTALL (3) 2" CONDUIT AND WITH WIRING AND PULL STRING AT EACH MAN GATE.
- 6. PANEL 'RBH' TO BE MOUNTED ON UNISTRUT FRAME (BY ELECTRICAL CONTRACTOR).
- 7. INSTALL (2) 1" SCH 80 PVC CONDUITS UNDERGROUND TO NEAREST QUAZITE BOX. LABEL CONDUIT ENDS.

ACCESS CONTROL DEVICE SCHEDULE	
A	PROVIDE & INSTALL DUAL HEIGHT SURFACE MOUNTED GOOSENECK STAND FOR MOUNTING OF ACCESS CONTROL DEVICES, SIMILAR TO DOOR KING MODEL DK1200-049. 1. TOP ARM HEIGHT SHALL BE 72" ABOVE CURB. 2. LOWER ARM SHALL BE 42" ABOVE CURB. 3. PROVIDE MOUNTING BOLT COVER.
B	ACCESS CONTROLS 1. MANUFACTURER TO BE DOOR KING. 2. PROVIDE 1506 KEYPAD (COORDINATE WITH OWNER PRIOR TO ORDERING).
C	ACCESS CONTROL VOICE SYSTEM 1. MANUFACTURER TO BE AIPHONE. 2. AUDIO VIDEO MASTER STATION: IS-MV (COORDINATE WITH OWNER PRIOR TO ORDERING). 3. CENTRAL EXCHANGE UNIT FOR 4 DOOR/SUBS & 4 MASTERS: IS-CCU (COORDINATE WITH OWNER PRIOR TO ORDERING). 4. AUDIO VIDEO FLUSH MOUNT DOOR STATION: IS-DVF (COORDINATE WITH OWNER PRIOR TO ORDERING). 5. SURFACE MOUNT BOX FOR IS-SS & IS-DVF: SBX-ISDVF (COORDINATE WITH OWNER PRIOR TO ORDERING). 6. 48V DC, 2A POWER SUPPLY (110 VAC): IS-PU-UL (COORDINATE WITH OWNER PRIOR TO ORDERING). 7. RACK MOUNT KIT FOR UP TO THREE IS-PU-UP: IS-RACK (COORDINATE WITH OWNER PRIOR TO ORDERING).
D	INSTALL FIRE ACCESS BOX ON APPROACHING FACE OF ACCESS CONTROL POST. 1. TOP OF BOX TO BE 4'-6" ABOVE CURB. 2. POST MOUNTING PLATE SHALL NOT PROTRUDE PAST THE FACE OF THE ACCESS CONTROL POST. 3. MANUFACTURER TO BE DOOR KING - COORDINATE MODEL NUMBER WITH LOCAL JURISDICTION REQUIREMENTS.
E	MAN GATE LOCK - PROVIDE DOOR KING DKGL-S12 MAGNETIC LOCK. COORDINATE REQUIREMENTS OF LOCK WITH GATE CONSTRUCTION.

**SITE POWER PLAN**  
SCALE: 1"=20'



Contractor:  
**DF Chase, Inc.**  
3001 Armory Drive  
Suite 225  
Nashville, TN 37204



OFFICE RENOVATION & DOCK ADDITION:  
**OLD DOMINION FREIGHT LINE**  
**ODFL PORTLAND, ME**  
185 RAND ROAD  
PORTLAND, ME 04102

CONSTRUCTION 4/25/2014  
DRAWINGS FOR PERMIT

Project No. 13061.00  
The Architect hereby reserves its common law copyright and other property rights in these plans, items and designs which are not to be reproduced, changed or copied in any form or manner whatsoever, nor are they to be assigned to any third party without first obtaining the express written permission from the Architect. The drawing is not final or to be used for construction until signed by the Architect.

Sheet Name:  
SITE POWER PLAN

Sheet Number:

**ES2.1**