



GEOTECHNICAL ▼ ENVIRONMENTAL ▼ INSPECTIONS ▼ TESTING

REPORT OF SOILS FIELD COMPACTION TESTING

CLIENT: Old Dominion Freight Lines
 500 Old Dominion Way
 Thomasville, NC. 27360
 Attn: Philip Danner

PROJECT: Old Dominion Building Expansion
 185 Rand Road
 Portland, ME

DATE: September 24, 2014 **REPORT #:** 14-55-00014-021A

General Location: Rear Parking Area
Field Rep: Eric Dolbec
Contractor: Chase
Earthwork: Shaw Brothers
Air Temp: 63°F
Weather: Sunny
Soil Type: Crushed Gravel
Soil ID#: 14-931
Sample Source: Brickyard Pit

Proctor Value: 138.7 lbs/ft³ **Optimum Moisture:** 6.1 %

Gauge Type: Troxler 3430 **Required Compaction:** 95 %

TEST NUMBER	DEPTH/ELEV.	MOISTURE %	DRY DENSITY PCF	PERCENT COMPACTION
1	8"/ n/a	1.5%	136.3	98.3%
LOCATION: south east end of walkway 20' in				
2	8"/ n/a	1.5%	137.9	99.4%
LOCATION: south east end of walkway 40' in				
3	8"/ n/a	1.7%	136.4	98.4%
LOCATION: south east end of walkway 60' in				
REMARKS:				