



## REPORT OF SOILS FIELD COMPACTION TESTING

**CLIENT:** Old Dominion Freight Lines                      **PROJECT:** Old Dominion Building Expansion  
 500 Old Dominion Way    185 Rand Road  
 Thomasville, NC. 27360    Portland, ME  
 Attn: Philip Danner

**DATE:** August 15, 2014    **REPORT #:** 14-55-00014-003

**General Location:** North Apron Fill  
**Field Rep:** Nickolas Brown  
**Contractor:** DL Chase  
**Earthwork:** Shaw Brothers  
**Air Temp:** 65°F  
**Weather:** Clouds  
**Soil Type:** Gravel  
**Soil ID#:** 14-931  
**Sample Source:** Shaw Brothers H Pit

**Proctor Value:** 138.7    **Optimum Moisture:** 9.8%

**Gauge Type:** Troxler 3430    **Required Compaction:** 95%

TEST NUMBER	DEPTH/ELEV.	MOISTURE %	DRY DENSITY PCF	PERCENT COMPACTION
	8"/58'	2.7%	133.4	96.2%
<b>LOCATION: 2' north of 11, 24' north of A</b>				
	8"/58'	2.6%	139.3	100+%
<b>LOCATION: 12' north of 11, 33' north of A</b>				
	8"/58'	3.1%	139.1	100+%
<b>LOCATION: 12' south of 15, 26' north of A</b>				
<b>LOCATION:</b>				
<b>LOCATION:</b>				
<b>LOCATION:</b>				
<b>LOCATION:</b>				
<b>LOCATION:</b>				
<b>REMARKS:</b>				

**NH MA ME CT VT RI    JOHN TURNER CONSULTING    CONSULTJTC.COM**

19 DOVER STREET DOVER, NH 03820 T 603.749.1841 F 603.516.6851	66 SOUTHGATE STREET WORCESTER MA 01603 T 508.505.0126	6 CLINTON AVENUE WESTFIELD MA 01085 T 413.642.0138	4775 ROUTE 14, UNIT 3 WRJ, VT 05001 T 802.295.1100	73 RAINMAKER DRIVE PORTLAND ME 04103-1291 T 207.883.7878
---	---	--	--	--