

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND

# BUILDING PERMIT

This is to certify that EASTERN FIRE PROTECTION  
of PO Box 1390- Kittyhawk Ave, Auburn, Maine

For installation at 20 PINE TREE INDUSTRIAL PKWY  
Hale Trailer

Job ID: 2011-06-1388-FAFS

CBL: 254 - - A - 008 - 001 - - - -

has permission to extend an NFPA 13 automatic sprinkler system provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

*[Handwritten signature]* (58)

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
PENALTY FOR REMOVING THIS CARD**

## BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life • [www.portlandmaine.gov](http://www.portlandmaine.gov)*

Director of Planning and Urban Development  
Penny St. Louis

Job ID: 2011-06-1388-FAFS  
Extension of an NFPA 13 sprinkler system

For installation at:  
20 PINE TREE IND PKWY

CBL: 254 - - A - 008 - 001 - - - -

## **Conditions of Approval:**

### **Fire**

The sprinkler system shall be installed in accordance with NFPA 13.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

The Fire Department will require Knox locking caps on all Fire Department Connections on the exterior of the building.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

Installation of a sprinkler or fire alarm system requires a Knox Box to be installed per city ordinance.

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-06-1388-FAFS	Date Applied: 6/13/2011	CBL: 254 - - A - 008 - 001 - - - - -	
Location of Construction: 20 PINE TREE IND PARKWAY	Owner Name: THE NORTHWOODS	Owner Address: PO BOX 1400 VOORHEES, NJ - NEW JERSEY 08043	Phone:
Business Name: Hale Trailer	Contractor Name: Eastern Fire Protection	Contractor Address: PO Box 1390 – Kittyhawk Ave, Auburn, ME 04210	Phone: 784-1507
Lessee/Buyer's Name:	Phone:	Permit Type: FAFS	Zone: I-M
Past Use: Warehouse & Office with Servicing Commercial Trailers	Proposed Use: Same: Warehouse & Office with Servicing Commercial Trailers – to install fire suppression system for new addition	Cost of Work: \$6000.00	CEO District:
		Fire Dept: <input checked="" type="checkbox"/> Approved w/conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A	Inspection: Use Group: Type:
		Signature: <i>Bjork</i> (58)	Signature:
Proposed Project Description: water based fire suppression system		Pedestrian Activities District (P.A.D.)	

Permit Taken By: Gayle	<b>Zoning Approval</b>		
<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</p>	<b>Special Zone or Reviews</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetlands <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> Maj <input type="checkbox"/> Min <input type="checkbox"/> MM Date: <i>OK - S</i> <i>6/16/11</i>	<b>Zoning Appeal</b> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	<b>Historic Preservation</b> <input checked="" type="checkbox"/> Not in Dist or Landmark <input type="checkbox"/> Does not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>S</i>
	<b>CERTIFICATION</b>		

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the appication is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHON



By mail

# 2011 06 13 88 66 2  
6/14/11



# Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Pine Tree

Installation address: 20 PENN TRAIL IND. PARKWAY CBL: 254 A 008

Exact location: (within structure) 2011 ADDITION

Type of occupancy(s) (NFPA & ICC): ONDEWARY HAZARD GROUP II

Building owner: HACO TRAECON HALE TRAILER

Managing Supervisor (RMS): WELL PLYNT License No: 368

Supervisor phone: 784-1507 E-mail: PLYNTW@TRAECON.COM

Installing contractor: TRAECON PENN PROTECTION License No: 101 I-M

Contractor phone: 784-1507 E-mail: (same)

The suppression work to be done will be: New:  Renovation:  Addition to existing system:

This is an amendment to an existing permit: Yes:  NO  Permit no: \_\_\_\_\_

NFPA Standard this system is designed to: 13C Edition: 2010

\*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire) for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

COST OF WORK: \$ 6000.00  
 PERMIT FEE: \$ 80.00  
 (\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

**RECEIVED**

JUN 13 2011

Dept. of Building Inspections  
City of Portland Maine

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Office / Service Warehouse: commercial trailers

Applicant signature: [Signature] Date: 06/09/11



# EASTERN FIRE PROTECTION

P.O. Box 1390  
Kittyhawk Ave.  
Auburn, ME 04210

PH # (207) 784-1507  
FAX # (207) 782-0566

# LETTER OF TRANSMITTAL

DATE	06/09/11	JOB NO.	4732
ATTENTION	KEITH GAUTNBALL		
RE:	HALO TRACOM		
	2011 ANDREON		

TO Bureau Inspectors Dept.  
389 Congress St. Room 315  
PONTIAC, MI 48101

**WE ARE SENDING YOU**  Attached  Under separate cover via \_\_\_\_\_ the following items:  
 Shop drawings  Descriptive data  Hydraulic calculations  
 Copy of letter  Literature  \_\_\_\_\_


QUANTITY	DRAWING NO.	DATE	DESCRIPTION	STATUS
2	1002	10/5/08	SPRINKLER SHOP DWG	C/15
2	2002	06/07/11		
2			HYDRAULIC CALCULATIONS	
1			PERMITS APPLICATION	
1			PERMITS CHECK	

- Status code
- A. Approved
  - B. Approved as noted
  - C. Submitted for approval
  - D. Corrected & resubmitted
  - E. For your files
  - F. Refer to remarks

Please return 1 copies each indicating your approval and/or comments.

REMARKS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

COPY TO \_\_\_\_\_ SIGNED [Signature]



... Fire Protection by Computer Design

RECEIVED  
JUN 13 2011  
Dept. of Building Inspections  
City of Portland Maine

EASTERN FIRE PROTECTION  
170 KITTYHAWK AVE.  
P.O. BOX 1390  
AUBURN, MAINE 04211-1390  
800-274-1507

Job Name	HALE TRAILER ADDITION ROOF
Drawing	EXISTING & NEW STEEL CONSTRUCTION
Location	20 PINE TREE IND. PARKWAY PORTLAND, MAINE
Remote Area	1 OF 1
Contract	AU-4732-11
Data File	1-4732.wx1

Hydraulic Design Information Sheet

Name - HALE TRAILER NEW ADDN ROOF PIPE Date - 06/07/11  
 Location - 20 PINE TREE IND. PARKWAY PORTLAND, MAINE  
 Building - EXISTING & NEW STEEL CONSTRUCTION System No. - 1 OF 1  
 Contractor - EASTERN FIRE PROTECTION CO., INC Contract No. - AU-4732-11  
 Calculated By - WILIAM FLYNT Drawing No. - 2 of 2  
 Construction: ( ) Combustible (X) Non-Combustible Ceiling Height - VARIES  
 Occupancy - ROOF PIPING NEW 2011 ADDITION .2/1620 SQ FT

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 (X) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C (X) Figure 13.2.1 Curve ORD II

S Other  
 T Specific Ruling Made By Date

E  
 M Area of Sprinkler Operation - 1620 System Type Sprinkler/Nozzle  
 Density - .2 (X) Wet Make TYCO  
 D Area Per Sprinkler - 124.63 SF ( ) Dry Model TY-B  
 E Elevation at Highest Outlet - 123'-6" ( ) Deluge Size 3/4"  
 S Hose Allowance - Inside ( ) Preaction K-Factor 8.0  
 I Rack Sprinkler Allowance - ( ) Other Temp.Rat.200  
 G Hose Allowance - Outside - 250

N Note Design Criteria per NFPA 13 (2010) Table 13.2.1, Class III commodity

Calculation Flow Required - 633 Press Required - 73 AT MAIN POINT  
 Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
 A Date of Test - 6/03/11 Cap. -  
 T Time of Test - 10:30 AM Rated Cap.- Elev.-  
 E Static Press - 85 @ Press -  
 R Residual Press - 84 Elev. - Well  
 Flow - 1443 Proof Flow  
 S Elevation - 95'-0"

U  
 P Location - OFF 12" CIRCULATING MAIN IN PINE TREE INDUSTRIAL PARKWAY

P  
 L Source of Information -  
 Y PORTLAND WATER DISTRICT

C Commodity Truck Parts Class III Location addition  
 O Storage Ht. 12 Area Aisle W.  
 M Storage Method: Solid Piled % Palletized 100 % Rack

M  
 (X) Single Row ( ) Conven. Pallet ( ) Auto. Storage ( ) Encap.  
 S R (X) Double Row ( ) Slave Pallet ( ) Solid Shelf ( ) Non  
 T A ( ) Mult. Row ( ) Open Shelf


O C  
 R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G  
 E Horizontal Barriers Provided:



City Water Supply  
 C1 - Static Pressure : 85  
 C2 - Residual Pressure: 84  
 C2 - Residual Flow : 1443

Demand:  
 D1 - Elevation : 12.343  
 D2 - System Flow : 383.116  
 D2 - System Pressure : 73.078  
 Hose ( Demand ) : 250  
 D3 - System Demand : 633.116  
 Safety Margin : 11.704



# Fittings Used Summary

EASTERN FIRE PROTECTION  
HALE TRAILER ADDITION ROOF

Page 3  
Date 060711

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
A	Alarm Rel E1 & E3							7.7	21.5		17		27	29								
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40	
T	NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
MAIN	85.0	84	1443.0	84.782	633.12	73.078

**NODE ANALYSIS**

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
23	123.5	8	9.77	25.0	
24	123.5	8	9.99	25.29	
25	123.5	8	10.81	26.3	
26	123.5	8	12.58	28.38	
27	123.5	8	15.76	31.76	
19	123.5	8	20.23	35.98	
21	123.5	8	20.66	36.37	
22	123.5	8	22.26	37.74	
11	123.5	8	9.71	24.93	
12	123.5	8	9.93	25.21	
13	123.5	8	10.74	26.22	
14	123.5	8	12.5	28.29	
15	123.5	8	15.66	31.66	
16	123.5		33.11		
17	123.5		33.31		
18	123.5		34.01		
EXT4	123.5		49.27		
BASE	101.5		69.64		
MAIN	95.0		73.08	250.0	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
HALE TRAILER ADDITION ROOF

Page 5  
Date 060711

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
23 to 24	123.50 123.50	8.00	25.00 25.0	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0198	9.769 0.0 0.224		Vel = 3.61	
24 to 25	123.50 123.50	8.00	25.29 50.29	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0719	9.993 0.0 0.815		Vel = 7.26	
25 to 26	123.50 123.50	8.00	26.30 76.59	1.5 1.682		0.0 0.0	11.330 0.0	120 0.1565	10.808 0.0 1.773		Vel = 11.06	
26 to 27	123.50 123.50	8.00	28.38 104.97	1.5 1.682		0.0 0.0	11.330 0.0	120 0.2805	12.581 0.0 3.178		Vel = 15.16	
27 to 17	123.50 123.50	8.00	31.76 136.73	1.5 1.682	1L 1T	2.475 9.9	26.000 12.375	120 0.4573	15.759 0.0 17.549		Vel = 19.74	
17			0.0 136.73						33.308		K Factor = 23.69	
19 to 21	123.50 123.50	8.00	35.98 35.98	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0387	20.225 0.0 0.438		Vel = 5.20	
21 to 22	123.50 123.50	8.00	36.36 72.34	1.5 1.682		0.0 0.0	11.330 0.0	120 0.1409	20.663 0.0 1.596		Vel = 10.45	
22 to 18	123.50 123.500	8.00	37.75 110.09	1.5 1.682	1L 1T	2.475 9.9	26.000 12.375	120 0.3063	22.259 0.0 11.753		Vel = 15.90	
18			0.0 110.09						34.012		K Factor = 18.88	
11 to 12	123.50 123.50	8.00	24.93 24.93	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0196	9.708 0.0 0.222		Vel = 3.60	
12 to 13	123.50 123.50	8.00	25.21 50.14	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0715	9.930 0.0 0.810		Vel = 7.24	
13 to 14	123.50 123.50	8.00	26.21 76.35	1.5 1.682		0.0 0.0	11.330 0.0	120 0.1556	10.740 0.0 1.763		Vel = 11.02	
14 to 15	123.50 123.50	8.00	28.29 104.64	1.5 1.682		0.0 0.0	11.330 0.0	120 0.2788	12.503 0.0 3.159		Vel = 15.11	
15 to 16	123.50 123.50	8.00	31.66 136.3	1.5 1.682	1L 1T	2.475 9.9	26.000 12.375	120 0.4547	15.662 0.0 17.449		Vel = 19.68	
16 to 17	123.50 123.50		0.0 136.3	3 3.26		0.0 0.0	10.870 0.0	120 0.0181	33.111 0.0 0.197		Vel = 5.24	
17 to 18	123.50 123.500		136.73 273.03	3 3.26		0.0 0.0	10.750 0.0	120 0.0655	33.308 0.0 0.704		Vel = 10.49	




Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
HALE TRAILER ADDITION ROOF

Page 6  
Date 060711

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
18 to EXT4	123.500 123.500		110.09 383.12	3 3.26	6L 1T	40.319 20.159	64.000 60.478	120	34.012 0.0			
EXT4 to BASE	123.500 101.500		0.0 383.12	4 4.26	5T 3L 1A 1G	131.671 23.701 22.384 2.633	145.000 180.389 325.389	120 0.0333	49.272 9.528 10.839		Vel = 14.73	
BASE to MAIN	101.500 95		0.0 383.12	6 6.16	1L 1G 1T	12.911 4.304 43.037	90.000 60.252 150.252	140 0.0042	69.639 2.815 0.624		Vel = 8.62	
MAIN			250.00 633.12						73.078		Qa = 250.00 K Factor = 74.06	



... Fire Protection by Computer Design

EASTERN FIRE PROTECTION  
170 KITTYHAWK AVE.  
P.O. BOX 1390  
AUBURN, MAINE 04211-1390  
800-274-1507

Job Name	HALE TRAILER ADDITION ROOF
Drawing	EXISTING & NEW STEEL CONSTRUCTION
Location	20 PINE TREE IND. PARKWAY PORTLAND, MAINE
Remote Area	1 OF 1
Contract	AU-4732-11
Data File	: 1-4732.wx1

Hydraulic Design Information Sheet

Name - HALE TRAILER NEW ADDN ROOF PIPE Date - 06/07/11  
 Location - 20 PINE TREE IND. PARKWAY PORTLAND, MAINE  
 Building - EXISTING & NEW STEEL CONSTRUCTION System No. - 1 OF 1  
 Contractor - EASTERN FIRE PROTECTION CO., INC Contract No. - AU-4732-11  
 Calculated By - WILIAM FLYNT Drawing No. - 2 of 2  
 Construction: ( ) Combustible (X) Non-Combustible Ceiling Height - VARIES  
 Occupancy - ROOF PIPING NEW 2011 ADDITION .2/1620 SQ FT

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 (X) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C (X) Figure 13.2.1 Curve ORD II

S Other

T Specific Ruling Made By Date

E  
 M Area of Sprinkler Operation - 1620 System Type Sprinkler/Nozzle  
 Density - .2 (X) Wet Make TYCO  
 D Area Per Sprinkler - 124.63 SF ( ) Dry Model TY-B  
 E Elevation at Highest Outlet - 123'-6" ( ) Deluge Size 3/4"  
 S Hose Allowance - Inside - ( ) Preaction K-Factor 8.0  
 I Rack Sprinkler Allowance - ( ) Other Temp.Rat.200  
 G Hose Allowance - Outside - 250  
 N

Note Design Criteria per NFPA 13 (2010) Table 13.2.1, Class III commodity

Calculation Flow Required - 633 Press Required - 73 AT MAIN POINT  
 Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
 A Date of Test - 6/03/11 Cap. -  
 T Time of Test - 10:30 AM Rated Cap.- Elev.-  
 E Static Press - 85 @ Press -  
 R Residual Press - 84 Elev. - Well  
 S Flow - 1443 Proof Flow  
 U Elevation - 95'-0"

P Location - OFF 12" CIRCULATING MAIN IN PINE TREE INDUSTRIAL PARKWAY

P Source of Information -  
 Y PORTLAND WATER DISTRICT

C Commodity Truck Parts Class III Location addition  
 O Storage Ht. 12 Area Aisle W.  
 M Storage Method: Solid Piled % Palletized 100 % Rack

M (X) Single Row ( ) Conven. Pallet ( ) Auto. Storage ( ) Encap.  
 S R (X) Double Row ( ) Slave Pallet ( ) Solid Shelf ( ) Non  
 T A ( ) Mult. Row ( ) Open Shelf

O C  
 R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G  
 E Horizontal Barriers Provided:


Water Supply Curve (C)

EASTERN FIRE PROTECTION  
HALE TRAILER ADDITION ROOF

Page 2  
Date 060711

City Water Supply:  
C1 - Static Pressure . 85  
C2 - Residual Pressure: 84  
C2 - Residual Flow . 1443

Demand:  
D1 - Elevation . 12.343  
D2 - System Flow . 383.116  
D2 - System Pressure . 73.078  
Hose ( Demand ) . 250  
D3 - System Demand . 633.116  
Safety Margin . 11.704





Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
A	Alarm Rel E1 & E3							7.7	21.5		17		27	29								
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
MAIN	85.0	84	1443.0	84.782	633.12	73.078

**NODE ANALYSIS**

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
23	123.5	8	9.77	25.0	
24	123.5	8	9.99	25.29	
25	123.5	8	10.81	26.3	
26	123.5	8	12.58	28.38	
27	123.5	8	15.76	31.76	
19	123.5	8	20.23	35.98	
21	123.5	8	20.66	36.37	
22	123.5	8	22.26	37.74	
11	123.5	8	9.71	24.93	
12	123.5	8	9.93	25.21	
13	123.5	8	10.74	26.22	
14	123.5	8	12.5	28.29	
15	123.5	8	15.66	31.66	
16	123.5		33.11		
17	123.5		33.31		
18	123.5		34.01		
EXT4	123.5		49.27		
BASE	101.5		69.64		
MAIN	95.0		73.08	250.0	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
HALE TRAILER ADDITION ROOF

Page 5  
Date 060711

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
23 to 24	123.50 123.50	8.00	25.00 25.0	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0198	9.769 0.0 0.224		Vel = 3.61	
24 to 25	123.50 123.50	8.00	25.29 50.29	1.5 1.682		0.0 0.0	11.330 11.330	120 0.0719	9.993 0.0 0.815		Vel = 7.26	
25 to 26	123.50 123.50	8.00	26.30 76.59	1.5 1.682		0.0 0.0	11.330 11.330	120 0.1565	10.808 0.0 1.773		Vel = 11.06	
26 to 27	123.50 123.50	8.00	28.38 104.97	1.5 1.682		0.0 0.0	11.330 11.330	120 0.2805	12.581 0.0 3.178		Vel = 15.16	
27 to 17	123.50 123.50	8.00	31.76 136.73	1.5 1.682	1L 1T	2.475 9.9	26.000 12.375 38.375	120 0.4573	15.759 0.0 17.549		Vel = 19.74	
17			0.0 136.73						33.308		K Factor = 23.69	
19 to 21	123.50 123.50	8.00	35.98 35.98	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0387	20.225 0.0 0.438		Vel = 5.20	
21 to 22	123.50 123.50	8.00	36.36 72.34	1.5 1.682		0.0 0.0	11.330 11.330	120 0.1409	20.663 0.0 1.596		Vel = 10.45	
22 to 18	123.50 123.500	8.00	37.75 110.09	1.5 1.682	1L 1T	2.475 9.9	26.000 12.375 38.375	120 0.3063	22.259 0.0 11.753		Vel = 15.90	
18			0.0 110.09						34.012		K Factor = 18.88	
11 to 12	123.50 123.50	8.00	24.93 24.93	1.5 1.682		0.0 0.0	11.330 0.0	120 0.0196	9.708 0.0 0.222		Vel = 3.60	
12 to 13	123.50 123.50	8.00	25.21 50.14	1.5 1.682		0.0 0.0	11.330 11.330	120 0.0715	9.930 0.0 0.810		Vel = 7.24	
13 to 14	123.50 123.50	8.00	26.21 76.35	1.5 1.682		0.0 0.0	11.330 11.330	120 0.1556	10.740 0.0 1.763		Vel = 11.02	
14 to 15	123.50 123.50	8.00	28.29 104.64	1.5 1.682		0.0 0.0	11.330 11.330	120 0.2788	12.503 0.0 3.159		Vel = 15.11	
15 to 16	123.50 123.50	8.00	31.66 136.3	1.5 1.682	1L 1T	2.475 9.9	26.000 12.375 38.375	120 0.4547	15.662 0.0 17.449		Vel = 19.68	
16 to 17	123.50 123.50		0.0 136.3	3 3.26		0.0 0.0	10.870 10.870	120 0.0181	33.111 0.0 0.197		Vel = 5.24	
17 to 18	123.50 123.500		136.73 273.03	3 3.26		0.0 0.0	10.750 10.750	120 0.0655	33.308 0.0 0.704		Vel = 10.49	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
HALE TRAILER ADDITION ROOF

Page 6  
Date 060711

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
18 to EXT4	123.500 123.500		110.09 383.12	3 3.26	6L 1T	40.319 20.159	64.000 60.478	120	34.012 0.0			
EXT4 to BASE	123.500 101.500		0.0 383.12	4 4.26	5T 3L 1A 1G	131.671 23.701 22.384 2.633	145.000 180.389 325.389	120	49.272 9.528 10.839		Vel = 14.73	
BASE to MAIN	101.500 95		0.0 383.12	6 6.16	1L 1G 1T	12.911 4.304 43.037	90.000 60.252 150.252	140	69.639 2.815 0.624		Vel = 8.62	
MAIN			250.00 633.12								Qa = 250.00 K Factor = 74.06	