

Web Mail - 190 Rand Road Property# 70249

From: Aaron Richards <Aaron.Richards@motion-ind.com>
To: "fireinspector@portlandmaine.gov" <fireinspector@portlandmaine.gov>
Date: 5/23/2011 9:41 AM
Subject: 190 Rand Road Property# 70249

Violations Notice Update

I just wanted to give you an update on the violations notice.

Violation #1 Fire Alarm Inspection

We have had Eastern Fire Protection inspect this system. They were going to get in touch with you to find out exactly what is required per code before they put a sticker on the panel.

Violation #4 Knox Box

The Knox box is physically here but has not been mounted to the building. I would like to have someone from the PFD show me exactly where they would like this box mounted.

Violation #5 Gas Cylinders

The cylinders have been chained outside in a cage.

Violation #6 Area for Hot Work

We have designated new areas that are away from the paint booths for our cutting and grinding.

Violation #7 Fire Suppression for the paint booths.

We have received a quotation from Eastern Fire Services for \$7000.00 to do this work. They told me that they would not be able to schedule the work until late-summer. Is this acceptable? I know our permit is up in June. I would like to stick with Eastern if possible but obviously the permit is very important.

Violation #8 Address

The address is already on the sign which is visible from the street. I believe this was just overlooked.

Violation #9 Spray Permit

All paperwork has been filed and fees have been paid. We are awaiting Fire Department approval.

Violation #10 Disorderly Storage

We have cleaned up the building in general and the panels are all accessible.

Violation #11 Sprinkler System

See violation # 7 comments.

I know that our 32 days are almost up. I don't know if there is anything else that I can do but we need these paint booths to do business. Please let me know if this is acceptable.

Regards,
Aaron

Aaron Richard
Motion Industries Inc. ME16
Portland, ME
T.207-828-4727
F.207-828-4757

