

COMMENTS

6-1-99 MacLand + I left a Red tag because the slab will not be 6" thick as per plan. MacLand will recheck in the morning.

Checked setbacks to stakes with Tim R.

6-7-99 Went back & checked 8" dug down on right side for more depth.

Missing

2/27/03 Work complete JB

Inspection Record		Date
Type		
Foundation:	_____	_____
Framing:	_____	_____
Plumbing:	_____	_____
Final:	_____	_____
Other:	_____	_____