

**Laurie Leader - Re: BP#2015-00660 856 Brighton Avenue - Sign Permit**

---

**From:** Derek Viger <dviger@breakwaterschool.org>  
**To:** Laurie Leader <LRL@portlandmaine.gov>  
**Date:** 4/27/2015 10:27 AM  
**Subject:** Re: BP#2015-00660 856 Brighton Avenue - Sign Permit

---

Hi Laurie,

I have the calculations you requested.

Jessie Building: 338sqft  
Sign: 17sqft  
Percentage: 5%

Daniel N Crewe Building: 1150sqft  
Sign: 7sqft  
Percentage: 0.6%

Please let me know if you need anything else. Thank you.

Best,  
Derek

On Mon, Apr 13, 2015 at 10:20 AM, Laurie Leader <[LRL@portlandmaine.gov](mailto:LRL@portlandmaine.gov)> wrote:

Derek,

I am handling the zoning review for the two permits you have applied for. I will need further clarification of the following for the "The Dan" building:

- Per the sign ordinance, you are allowed 1.5 SF per linear foot of building facade in a B1 zone. Provide calculations of the wall area and confirm the sign meets this criteria.

Please feel free to call or email if you have further questions.

Thanks,

Laurie

Laurie Leader  
Plan Review/Code Enforcement  
City of Portland, Maine  
Inspections Division  
389 Congress Street  
Portland, ME 04101

P: [207-874-8714](tel:207-874-8714)

F: [207-874-8716](tel:207-874-8716)

E: [lrl@portlandmaine.gov](mailto:lrl@portlandmaine.gov)

To view building permit status go to <http://www.portlandmaine.gov/792/Permit-Status>

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

--

Derek Viger  
Development and Communications Coordinator  
Breakwater School  
856 Brighton Avenue  
Portland, ME 04101  
**Work 207-772-4295 x227**  
**Cell 207-272-4520**  
**Home 207-829-9309**