


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

November 1, 2017

Responsible Party 1: WEBBER OIL COMPANY 700 MAIN ST BANGOR, ME 04401		
Location 952 BRIGHTON AVE	CBL 260 A024001	Inspection Date 9/29/2017
Inspector Christopher Fleming	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 11/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
1-14-3.2 EMERGENCY LIGHTING AND EXIT SIGNS SHALL BE TESTED; EMERGENCY LIGHTING FACILITIES AND EXIT SIGNS SHALL BE TESTED MONTHLY FOR 30 SECONDS AND ANNUALLY FOR 90 MINUTES, AND WRITTEN RECORDS SHALL BE MAINTAINED. Emergency lights did not illuminate when tested.	✓
1-14.14 ILLUMINATION OF EXIT SIGNS; EXIT SIGNS SHALL BE CONTINUOUSLY ILLUMINATED AND USE AN EMERGENCY LIGHTING SOURCE. Exit sign over emergency exit failed the battery test.	✓
FINAL DATE OF COMPLETED VIOLATION(S)	<u>11 / 21 / 17</u>
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	<u>11 / 21 / 17</u>

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION


I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

11-19-2017

Date




Responsible Party

Date

Responsible Party

SEEN AND AGREED

11/28/17
Date



Fire Prevention Bureau