

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

LEEMAN REBECCA & MARGARET W WEST JTS

Located at

118 ROWE AVE

PERMIT ID: 2017-00595

ISSUE DATE: 06/21/2017

CBL: 261 D018001

has permission to **Demolish single story, rear section of house & open side porch - rebuild one story, rear 14' x 22' section, relocate stairs off side of deck, add new steps on left side of front porch & replace bulkhead .**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Brian Stephens

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Single family

Building Inspections

Use Group: R

Type:

Single Family Dwelling

Crawl Space & First Floor

MUBEC/IRC-2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Footings

Foundation/Backfill

Close-in Plumbing/Framing

Electrical Close-in

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00595	Date Applied For: 04/26/2017	CBL: 261 D018001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same. Single Family.		Proposed Project Description: Demolish single story, rear section of house & open side porch - rebuild one story, rear 14' x 22' section, relocate stairs off side of deck, add new steps on left side of front porch & replace bulkhead		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 04/27/2017	
Note: R-3				Ok to Issue: <input checked="" type="checkbox"/>
lot size - 12600 sf front - 25' min - 46.5 given - OK side - 8' min. - 13' 10" given on left & 21'8" given on right - OK Rear- 25' min. - 91.5' scaled - OK Lot coverage (35%) = 4410 sf - 1570 sf - OK max ht - 35' - one story -OK				
Conditions:				
1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Brian Stephens	Approval Date: 06/21/2017	
Note:				Ok to Issue: <input type="checkbox"/>
Conditions:				
1) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings undergoing alterations, hard wired to the electrical system. Interconnection is required, where permanent wiring is feasible, which shall be verified upon inspection.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) Insulation shall be installed to the equivalent R-value and windows to the equivalent U-factor for climate zone 6 per the IECC Tables				
4) Where supported by attachment to an exterior wall, decks shall be positively anchored to the primary structure and designed for both vertical and lateral loads as applicable. Such attachment shall not be accomplished by the use of toenails or nails subject to withdrawal. See IRC 2009 Sec. 502.2.2 and IBC Sec. 1604.8.3 for details. Deck lateral load connection shall be allowed with hold-down tension devices installed in not less than two locations per deck, with each device having an allowable stress design capacity of not less than 1500 pounds. Where positive connection to the primary building structure cannot be verified during inspection, decks shall be self- supporting.				
5) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				
6) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				