

918295

262-A-001

Permit # _____ City of _____ BUILDING PERMIT APPLICATION Fee _____ Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Emery Water House Co. Phone # 775-2371
Address: POB 659 Rand Rd Portland, ME 04104

LOCATION OF CONSTRUCTION Rand Rd.

Contractor: Les Wilson & Sons Sub.: _____

Address: 161 Warren Ave Westbrook Phone # 854-4583

Est. Construction Cost: 38,900.00 Proposed Use: Comm w/oil tank

Past Use: Comm

of Existing Res. Units _____ # of New Res. Units _____

Building Dimensions L _____ W _____ Total Sq. Ft. _____

Stories: _____ # Bedrooms _____ Lot Size: _____

Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____

Explain Conversion Install 15,000 Gal above grnd oil tank

For Official Use Only

Date: November 26, 1991

Subdivision: _____

Inside Fire Limits: _____

Bldg Code: _____

Time Limit: _____

Estimated Cost: _____

Name: _____

Lot: DEC - 9 1991

Ownership: Public _____ Private _____

PERMIT ISSUED

CITY OF PORTLAND

Zoning:
Street Frontage Provided: _____
Provided Setbacks: Front _____ Back _____ Side _____

Review Required:
Zoning Board Approval: Yes _____ No _____ Date: _____
Planning Board Approval: Yes _____ No _____ Date: _____
Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
Special Exception _____
Other (Explain) _____

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____ **HISTORIC PRESERVATION**
Not in District nor Landmark.
3. Type Ceilings: _____
4. Insulation Type _____ Size _____ **Does not require review.**
5. Ceiling Height: _____ **Requires Review.**

Roof:

1. Truss or Rafter Size _____ Span _____ **Action: Approved.**
2. Sheathing Type _____ Size _____ **Approved with Condition.**
3. Roof Covering Type _____ **Denied.**

Chimneys:

Type: _____ Number of Fire Places _____ Date: _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Permit Received By Mary Gresik

Signature of Applicant _____ Date _____

PERMIT ISSUED WITH LETTER

CONTINUED TO REVERSE SIDE

White - Tax Assessor

Ivory Tag - CEO

Handwritten notes and signatures at the bottom right of the page.

PLOT PLAN



FEES (Breakdown From Front)

Base Fee \$ _____
 Subdivision Fee \$ _____
 Site Plan Review Fee \$ _____
 Other Fees \$ _____
 (Explain) _____
 Late Fee \$ _____

Inspection Record

Type

Date

Type	Date
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____

COMMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as has authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

John H. Guffin *P.O. Box 659* *BAND Rd. PORTLAND Me* *775-2371*
 SIGNATURE OF APPLICANT ADDRESS PHONE NO.

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE NO.

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

December 5, 1991

Emery Waterhouse Co.
POB 659
Rand Rd
Portland, ME 04104

Re: Rand Rd

Dear Sir,

Your application to install a 15,000 gallon above ground tank has been reviewed and a permit is herewith issued subject to the following requirements:

1. A travel lane at least 16' wide shall be maintained between the tanks installation and the building.
2. Piping shall be installed in such a way that it is protected against mechanical damage by vehicles in the area.
3. Installation shall be done in accordance with Section 2-3 of N.F.P.A. #30.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,



P. Samuel Hoffses
Chief of Inspection Services

cc: Wallace C. Garroway, Jr., Lt, FPB


PINE TREE SHOPPING CENTER

LOT SIZE 30.67A.
ZONED B-1 + I-1

PARKING LOT

RAND ROAD

EXISTING TANKS
GRASS



TRAILER PARKING

TO RAND RD

PORTLAND TERMINAL CO.

11/22/91 13:28


2 207 781 3795

ADAMS AND FOGG

81

ABOVEGROUND TANKS FOR ENVIRONMENTALLY SENSITIVE AREAS OR CONTAINING ENVIRONMENTALLY SENSITIVE MATERIALS

Containment Tanks



Containment Tanks

The Mohawk Containment Tank is a timely solution to aboveground pollution concerns. The steel containment tank is strong as well as simple and quick to install. The leakproof containment tank is sized to contain a volume 110% greater than the capacity of the tank it protects which meets the NFPA 30 and UFC's 110% capacity rule if the protective tank is open to the environment.

The tank contained is built to the UL 142 standards for an aboveground tank. All tanks and containment tanks are elevated for visual leak inspection and are painted with red oxide primer. Custom designs for vertical or multi-tank containment and special coatings are available.

Specifications

MODEL #	TANK CAPACITY	DIKE CAPACITY	TANK SIZE	DIKE SIZE	DIKE WT.	DIKE TANK TOTAL WEIGHT
5060	300	360	3'2" x 6'	6' x 4' x 2'	570	854
5010	500	500	4'0" x 5'4"	8' x 5' x 2'	800	1,394
5020	1000	1100	4'0" x 10'6"	6' x 12' x 2'	1,251	2,261
5030	1000	1100	5'4" x 6'0"	8' x 8'2" x 2'	1,458	2,575
5040	1500	1650	5'4" x 9'0"	14' x 6' x 2'	2,228	3,558
5050	2000	2200	5'4" x 12'0"	14' x 7' x 3'	2,124	4,247
5060	5000	5500	5'4" x 18'0"	20' x 6' x 3'	3,173	5,980
5070	4000	4500	5'4" x 24'0"	25' x 6' x 3'	3,863	7,475
5080	5000	5500	8' x 13'6"	20' x 10' x 4'	5,334	10,724
5090	6000	7100	8' x 16'0"	24' x 10' x 4'	6,217	12,367
5100	6000	6900	8' x 21'4"	30' x 10' x 4'	7,859	13,678
5110	10000	11200	8' x 28'0"	30' x 10' x 5'	8,438	18,898
5120	12000	13400	10' x 20'6"	30' x 12' x 5'	8,561	20,504
5130	15000	17000	10' x 25'0"	32' x 12' x 6'	11,155	26,155
5140	20000	22000	10' x 30'0"	42' x 12' x 6'	16,421	36,571



R=6% 11-22-91 01:34PM P04/**

15,000 GAL. #2 fuel