

## Benjamin Wallace - Re: Pine Tree

---

**From:** Benjamin Wallace  
**To:** Rich Brobst  
**Date:** 11/30/2011 11:05 AM  
**Subject:** Re: Pine Tree  
**Attachments:** 1064 Brighton Ave Plaza - FIREFIGHTER BUILDING MARKING SIGN.pdf; Benjamin Wallace.vcf

---

Hi Rich,

I've attached the worksheet we use for the signs and on the back (2nd page) towards the bottom is the name, address and phone number of the company that makes the signs. You can just print the two page worksheet attached and give it to them and they'll know just how to do it.

Second I've finally had the opportunity to do a complete review of the permit submittal as I've only now received the permit from City Hall. I think this is the one you were going to get me a cleaned up operations matrix deleting the apartment reference and adding the master box column. Also I don't recall having received a master box application yet and can't find one anywhere. Please e-mail me a completed master box application. The building name is going to be Pine Tree Shopping Center and the address we're going to use will be 1100 Brighton Ave. Additionally I've identified several issues with some of the strobe spacing/ rating and a lack of a smoke detector over a NAC power supply and need a revised/ as-built set of plans indicating the corrections.

Strobe spacing:

- Full Belly Deli rear
- Fashion Bug back room
- Dollar Tree bathroom hall
- CVS back room
- Big lots most rear room/ corridor
- Little Caesar's front strobe isn't adequate to cover the middle of the space
- Hair Excitement front

Please on all future submittals provide a paper copy of all documentation with the application form(s) and check to the Building Inspections Office. We do need to continue getting a full size set of plans with the application.

Thanks,  
Ben

Lt. Benjamin Wallace Jr.  
 Fire Prevention Officer  
 Portland Fire Department  
 380 Congress Street  
 Portland, Maine 04101  
 (207)874-8400  
 wallaceb@portlandmaine.gov  
 >>> Rich Brobst <rich@protectionprofessionals.net> 11/29/2011 2:50 PM >>>  
 yes please.

*Thank you for your time;*

*Rich Brobst, Jr*  
*NICET III*  
*Master Electrician*

*Protection Professionals  
325 US Route One  
Falmouth, Maine 04105  
207-775-5755  
Cell: 207-899-7761*

*This email was sent from the firm of Protection Professionals. It may contain information that is privileged or confidential. If you suspect that you were not the intended recipient, please delete it and notify us as soon as possible. Further dissemination, copying or distribution of this message or associated files is strictly prohibited. We do not accept responsibility for the security or safety of this message due to the vulnerability of the internet and the recipient should therefore exercise all due caution. Thank you.*

---

**From:** "Benjamin Wallace" <wallaceb@portlandmaine.gov>  
**To:** "Rich Brobst" <rich@protectionprofessionals.net>  
**Sent:** Tuesday, November 29, 2011 1:02:32 PM  
**Subject:** Re: Pine Tree

Are you inquiring where to purchase one?

>>> Rich Brobst <rich@protectionprofessionals.net> 11/29/2011 9:13 AM >>>  
Good day:

Can you please send me the location for the sign you showed me in your office? It is the style which you desired over the annunciator. thanks

*Thank you for your time;*

*Rich Brobst, Jr  
NICET III  
Master Electrician  
Protection Professionals  
325 US Route One  
Falmouth, Maine 04105  
207-775-5755  
Cell: 207-899-7761*

*This email was sent from the firm of Protection Professionals. It may contain information that is privileged or confidential. If you suspect that you were not the intended recipient, please delete it and notify us as soon as possible. Further dissemination, copying or distribution of this message or associated files is strictly prohibited. We do not accept responsibility for the security or safety of this message due to the vulnerability of the internet and the recipient should therefore exercise all due caution. Thank you.*