



526 West River Road Suite 2  
Augusta, Maine 04330  
Phone: (207) 458 -7143  
Email: Iconenviro@aol.com

# Icon Environmental Consultants


October 27, 2017

Atlantic Environmental Contractors  
81 East Avenue  
Auburn, Maine 04240

Re: Former Travel Lodge 1200 Brighton Ave Portland, Maine Project #1879 Phase 2

Dear Jim:

Icon Environmental performed a Final Visual Evaluation and Clearance Sample collection with analysis at the Former Travel Lodge 1200 Brighton Ave Portland, Maine. The abatement work was completed on October 2, 2017. Atlantic Environmental Contractors removed approximately popcorn ceiling cover and transite door and window panels in rooms 141-148 using Maine DEP approved demolition abatement containment. Atlantic also had a waiver for open ceilings and non aggressive final air test. The abatement activity was performed by Maine DEP licensed personnel.





The only space reviewed for this site was within the containment or barrier tape walls, no exterior locations beyond the containment or barrier tape were observed. The review of the work area is a window in time and post visit site conditions may change; those changes, if any, cannot be attributed to Icon Environmental Consultants review or acceptance of the site during our visit. Icon did not perform a post tear down site visual.

A total of five air samples were collected in the work space. The samples were collected by Icon Air Monitor, Craig Wilson. The containment visual evaluations were acceptable. The air samples were analyzed using the NIOSH 7400 Method. The air samples were reported below Maine DEP and EPA clearance criteria. The air test results indicate reoccupation is acceptable.

Icon Air Analysis Sheet, Final Cleaning Checklist and photographs are attached.

Please contact us at (207) 458-7143 with any questions.

Sincerely,

*Craig E. Wilson*

Craig E. Wilson

Air Analyst, Air Monitor, Maine DEP # AA-0016, AM-0019