

**ICON ENVIRONMENTAL CONSULTANTS
 187 BRUNSWICK AVE SUITE A
 GARDINER, MAINE 04345
 AIR SAMPLE ANALYSIS REPORT
 207-458-7143
 Iconenviro@aol.com**

Client: AEC
Former Travel Lodge
1200 Brighton Ave
Portland, Maine

Date: 10/27/2017

Project: Phase 2 Ceiling and transite

Client Ref. Number: AEC- 1879 Collected by: Craig Wilson AM-0019

SAMPLE #	LOCATION/NAME	DURATION	AVE. FLOW RATE	LITERS	FIBER COUNT	CONCENTRATION
B-1	Blank	-----	-----	-----	0/100	
C-1	Room 141	1535-1810	16 lpm	2480	8/100	0.001 f/cc
C-2	Room 143	1536-1811	16 lpm	2480	11/100	0.002 f/cc
C-3	Room 145	1536-1811	16 lpm	2480	4/100	0.001 f/cc BDL
C-4	Room 147	1538-1812	16 lpm	2480	5/100	0.001 f/cc BDL
C-5	Room 148	1538-1812	16 lpm	2480	3.5/100	0.001 f/cc BDL
B-2	Blank	-----	-----	-----	1/100	
QA/QC						

Analyst: C. Wilson
BDL = Below detection limit
Client requests disposal of samples (Yes)/No
PCM Analysis performed per NIOSH 7400 method.
 Log in Date: _____ Log in Storage Date: _____

Maine DEP #: AA-0016

Air Sample Analysis Report Rev. 6/07
 Waste Date: _____