Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/05/17

ICON ENVIRONMENTAL CONSULTANTS
187 BRUNSWICK AVE SUITE A
GARDINER, MAINE 04345
AIR SAMPLE ANALYSIS REPORT
207-458-7143
Iconenviro@aol.com

Client: AEC **Date: 10/27/2017**

Former Travel Lodge
1200 Brighton Ave
Portland, Maine

Project: Phase 2 Ceiling and transite

Client Ref. Number: AEC- 1879 Collected by: Craig Wilson AM-0019

SAMPLE #	LOCATION/NAME	DURATION	AVE. FLOW RATE	LITERS	FIBER COUNT	CONCENTRATION
B-1	Blank	----------	----------	----------	0/100	
C-1	Room 141	1535-1810	16 lpm	2480	8/100	0.001 f/cc
C-2	Room 143	1536-1811	16 lpm	2480	11/100	0.002 f/cc
C-3	Room 145	1536-1811	16 lpm	2480	4/100	0.001 f/cc BDL
C-4	Room 147	1538-1812	16 lpm	2480	5/100	0.001 f/cc BDL
C-5	Room 148	1538-1812	16 lpm	2480	3.5/100	0.001 f/cc BDL
B-2	Blank	----------	----------	----------	1/100	
QA/QC						

Analyst: C. Wilson **Maine DEP #: AA-0016**
BDL = Below detection limit
Client requests disposal of samples (Yes)/No
PCM Analysis performed per NIOSH 7400 method. **Air Sample Analysis Report Rev. 6/07**
Log in Date:_____ Log in Storage Date:_____ Waste Date:_____