

From: Craig Messinger
To: Helen Donaldson
Date: 2/23/2015 11:46 AM
Subject: Re: 1210 Brighton Avenue

Hi Nell,

Thanks for revised plans, I can see where they relocated the fire hydrant and seems to be fine.

Would you please add the following to the conditions:

Private hydrants shall be maintained and cleared of snow during the winter months.

Private hydrants shall be painted as follows: Bonnet-gray, caps-silver, Barrel-red.

Please call me if you have any questions,

Thanks Craig

380 Congress st
Portland Maine 04101
874-8400