
MEMORANDUM

To: FILE
From: Nell Donaldson
Subject: Application ID: 2014-220
Date: 3/19/2015

Comments Submitted by: Craig Messinger/Fire on 2/23/2015

Hi Nell,
Thanks for revised plans, I can see where they relocated the fire hydrant and seems to be fine.
Would you please add the following to the conditions:
Private hydrants shall be maintained and cleared of snow during the winter months.
Private hydrants shall be painted as follows: Bonnet-gray, caps-silver, Barrel-red.
Please call me if you have any questions,
Thanks Craig

380 Congress st
Portland Maine 04101
874-8400