GENERAL NOTES:

- 1. The notes on the drawings are not intended to replace specifications. in addition to general notes. See specifications for requirements
- 2. Structural drawings shall be used in conjunction with job specifications and architectural, mechanical, electrical, plumbing, and site drawings. Consult, openings, chases, inserts, reglets, sleeves, depressions, and other details not shown on structural drawings.
- 3. All dimensions and conditions must be verified in the field. Any discrepancies shall be brought to the attention of the engineer before proceeding with the affected part of the work.
- 4. Do not scale plans.
- 5. Sections and details shown on any structural drawings shall be considered typical for similar conditions.
- 6. All propietary products shall be installed in accordance with the manufacturers written instructions.
- 7. The structure is designed to be self supporting and stable after the erection is complete. It is the contractor's sole responsibility to determine erection procedures and sequencing to ensure the safety of the building and its components during erection. This includes the addition of necessary shoring, sheeting temporary bracing, guys or tiedowns. Such material shall remain the property of the contractor after completion of the project.
- 8. All applicable federal, state, and municipal regulations shall be followed, including the federal department of labor occupational safety and health act.

DESIGN LOADS:

- 1. Building code: IBC (2009) International Building Code.
- 2. Design Live Loads: (Ground Snow load =50 psf) 45 psf + drift as applicable RTU Unit #1 (A3-D.750-G18) 1029 lbs. RTU Unit #2 (A4-D.1000-920).... 1641 lbs.
- 3. Design wind loads are based on exposure C using 100 mph basic wind speed.
- 4. Seismic Design Utilizes Analysis Procedure shall be equivalent Lateral Force Procedure per IBC 2009.

TIMBER FRAMING:

- 1. All Timber framing shall be in accordance with the AITC timber construction manual or the national design specification (NDS) latest edition
- 2. Individual timber framing members shall be visually graded, minimum grade #2 Spruce—Pine—Fir (SPF), kiln dried to 19% maximum moisture content.
- 3. Timber shall be southern yellow pine treated with ACQ water borne preservative in accordance with AWPA treatment C1 with 0.40 PCF retainage for items in contact with roofing, masonry or concrete with 0.60 PCF retainage for items in contact with earth.
- 4. Metal connectors shall be used at all timber to timber connections or as noted on the design drawings. All metal connectors in contact with pressure treated timber shall be hot—dippped galvanized.
- 5. Provide Simpson H2.5A hurricane anchors where timber framing and/or trusses bear on bearing walls and structural beams.
- 6. Nails and screws not specified shall conform with IBC 2009. All nails and screws in contact with pressure treated timber shall be stainless steel.
- 7. Provide $\frac{1}{2}$ " thick APA rated exterior wall sheathing fastened w/ 10d nails @ 4" o.c. at panel edges and 6" o.c. intermediate. Lap
- sheathing 1'-0" minimum over existing structure (Where applicable). 8. Provide 5%" thick APA rated roof sheathing fastened w/ 10d nails @ 6" o.c. at panel edges and intermediate.
- 9. Provide ¾" thick APA rated floor sheathing fastened w/ construction adhesive and 10d ring shank nails @ 6" o.c. at panel edges and intermediate.
- 10. LVL indicated laminated veneer lumber beams manufactured by Boise Cascade or approved equal.

TUR //ces	041(
RUC SER\	MAINE	4830 5432
	,	54

ENGINEERINC SIX Q STREET SOUTH PORTLAND, PHONE: (207) 767-4 FAX: (207) 799-5, EMAIL: JLEASLIPF?

JOSEPH H. LEASURE No. 6242

designed by: JHL	rev.	date	description	appr'd	THE PARTY OF THE P
drawn by: RJW	٧	04/13/16	04/13/16 FOR REVIEW & COORD.	JHL	10 (M)
checked by: JHL	В	05/10/16	05/10/16 FOR PERMIT AND PRICING	THF	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\
scale: AS NOTED					ENS
date: 04/13/2016					ED
plot date: 05/10/2016					SIR THE
project #: 2016-069					MININ

BISTRO ON AVEI HANIC, ASIAN BRITCH