

PRO KITCHEN SUPPLY CO. INC. Exhaust Hood

Model	Length	Depth	Height	Weight	Capacity	Material
UH09042	12'-0"	24"	24"	150	1000	Stainless Steel
UH09041	12'-0"	24"	24"	150	1000	Stainless Steel
UH09040	12'-0"	24"	24"	150	1000	Stainless Steel

CONFORMS TO UL 719 AND UL-C-8648-08 Use UL Classified Grease Filters


Exhaust Hood Light Fixture Electrical Rating: 120V 60Hz 100Watt Per Fixture

Top Filtration is determined by multiplying the number of fixtures times 100W.

Please See Table 1 for more information.

Listed Light Fixtures are rated 120V, 60Hz, Total Current: _____

Sub-assembly For Exhaust Hood Without Exhaust Damper For Use Only With PRO KITCHEN SUPPLY CO. Inc. hood assembly For Exhaust Hood Without Exhaust Damper.




Dimensional Information & Performance Data

Muffin Roof Supply Fan

MU Belt Drive Series

Model	Dimensions	Capacity	Weight
MU160	16" Dia	1000 CFM	15 lbs
MU180	18" Dia	1500 CFM	20 lbs
MU200	20" Dia	2000 CFM	25 lbs
MU220	22" Dia	2500 CFM	30 lbs
MU240	24" Dia	3000 CFM	35 lbs
MU260	26" Dia	3500 CFM	40 lbs
MU280	28" Dia	4000 CFM	45 lbs
MU300	30" Dia	4500 CFM	50 lbs
MU320	32" Dia	5000 CFM	55 lbs
MU340	34" Dia	5500 CFM	60 lbs
MU360	36" Dia	6000 CFM	65 lbs
MU380	38" Dia	6500 CFM	70 lbs
MU400	40" Dia	7000 CFM	75 lbs



Performance Data

Muffin Roof Supply Fan

MU Belt Drive Series

Model	Dimensions	Capacity	Weight
MU160	16" Dia	1000 CFM	15 lbs
MU180	18" Dia	1500 CFM	20 lbs
MU200	20" Dia	2000 CFM	25 lbs
MU220	22" Dia	2500 CFM	30 lbs
MU240	24" Dia	3000 CFM	35 lbs
MU260	26" Dia	3500 CFM	40 lbs
MU280	28" Dia	4000 CFM	45 lbs
MU300	30" Dia	4500 CFM	50 lbs
MU320	32" Dia	5000 CFM	55 lbs
MU340	34" Dia	5500 CFM	60 lbs
MU360	36" Dia	6000 CFM	65 lbs
MU380	38" Dia	6500 CFM	70 lbs
MU400	40" Dia	7000 CFM	75 lbs

PROPOSED FLOOR PLAN
SCALE: 3/16"=1'-0"

DRAFTSMEN:
Stephen S. Andrews
23 Panther Pond Pines Rd.
Raymond, Maine 04071
207-415-5065

PROJECT NAME:
Kon Asian Bistro
1140 Brighton Ave, Portland, Maine 04102

BY: SSA
DATE: 12-15-10

DESCRIPTION: PROPOSED FLOOR PLAN INCLUDING EXPANSION SPACE

CODE:

TOWN: Portland, Me.

DATE: 05-02-16

SCALE:

DESIGNED: SSA

DRAWN: SSA

TITLE:
Proposed Floor Plan
Exhaust Fan Detail &
Specifications

FILE:
SHEET:
A-5