

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

Judith D. Valle
Valle's Steakhouse
1140 Brighton Avenue
Portland, Maine 04103

July 22, 1997

Dear Ms. Valle,

Upon a another recent inspection, conducted on 7/17/97, at the above mentioned address, more of the same type of violations and unsafe conditions were revealed and shall also be corrected.

KITCHEN/BASEMENT AREA(S):

Violations and unsafe conditions which **shall be corrected within 48 hours**, are as follows:

1. Tube guards protecting the fixtures in this location, have the end caps missing, **creating a potential hazard to personnel and the public from broken or shattered glass fragments and toxic lamp gases.**

BASEMENT AREA(S):

Violations and unsafe conditions which **shall be corrected within 48 hours**, are as follows:

1. Open junction boxes, live wires, open boxes on compressors.
2. Hard wire fixture at bottom of stairway, and add a wall switch for control of fixture.
3. Mechanical room shall have additional lighting added, with a wall switch to control all fixtures in this space.

TRASH AREA/EXTERIOR OF BUILDING:

1. Wire fixtures with approved methods.
2. Remove all extension cords.
3. Repair or replace fixtures.
4. Install knock out seals in trash compactor and cooling tower disconnects.
5. Label both disconnects properly with an approved method.
6. Liquid tight conduit shall be protected from physical damage to cooling tower. Conduit is presently on the ground.

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

If these violations are not corrected as outlined, the City shall be forced to **order the disconnection of electrical service to the building, as well as prompt legal action, until the hazards are eliminated, and full compliance is met.**

Sincerely,

A handwritten signature in black ink, appearing to read 'Michael A. Collins'. The signature is fluid and cursive.

Michael A. Collins
Chief Electrical Inspector
City Of Portland

cc: P. Samuel Hoffses, C, Insp Svcs Div
M. Schmuckal, Asst. C, Insp Svcs Div
Joseph Gray, Dir PUD
Gary Wood, Corp Counsel
Lt. McDougall, FM, PFD
Amy Powers, CEO
Dick Bates, Paul Connolly, CMP
Dena Tomlinson, City Clerk's Office
Mike LaPlante, Electrician