Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/16/14

200 Front Desk

D1 to D4 will be fire door with 45 minute rating and self-closing with latching.