Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/16/14

1-HOUR RATED (UL DESIGN No. U333)

STC = 34

- 2x WIDTH WOOD STUDS AT 16"o.c.
- 5/8" TYPE - X GYPSUM WALL BOARD EACH SIDE OF STUDES
- 3 1/2" BATT INSULATION

W-4 PUBLIC SPACE to Apartment