



**Portland Fire Department**

11/19/2019

G6 HOSPITALITY PROPERTY LLC

CARROLLTON, TX 75011

CERTIFIED MAIL

RE: 1 RIVERSIDE ST  
PORTLAND, ME 04102

266 A001001

Page 1 of 2

**NOTICE OF VIOLATION  
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 10/29/2019 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

**A reinspection of your property will take place on 11/29/2019 10:00:00AM .**

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Fire Prevention Bureau  
City of Portland

NON-COMPLIANCE VIOLATION LIST			
NAME	CODE DESCRIPTION	COMMENTS	Deadline
PFD Rules, 5.10.2	All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company.	All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company.	11/12/2019
NFPA 101-9.7.5	Sprinkler systems must be inspected annually and have a current inspection sticker.	Sprinkler systems must be inspected annually and have a current inspection sticker. Standpipe system inspection tag date: 06/08/2011	11/28/2019