

246-A-2

2001-0244

81 Riverside St.
Building Addition
Harper Hotels

add to Spreadsheet

Numeric Summary									
Project: All Projects									
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min		
TWR 1 Side Front20	Illuminance	Fc	4.32	53.9	0.0	0.00	43.40	340.00	0.00
BLDG PAR Wall 22	Illuminance	Fc	4.34	34.0	0.1	0.1	43.40	340.00	0.00
BLDG PAR Wall 18	Illuminance	Fc	0.02	0.3	0.0	0.00	0.00	0.00	0.00
1' AFG	Illuminance	Fc	12.18	95.1	0.0	0.00	0.00	0.00	0.00
TWR 2 Side Front21	Illuminance	Fc	11.43	343	0.0	0.00	0.00	0.00	0.00
1' ABOVE DECK	Illuminance	Fc	29.68	60.8	15.0	1.98	1.98	4.05	4.05

ATLANTIC COAST
 ELECTRIC
 P.O. BOX 8
 GORHAM, MAINE 04038



36 Main St. Gorham, ME		LIGHTOLIER/GENLYTE	
HOLIDAY INN - Exit 8			
DRW'G.# 2		DATE: 4/24/02	
SCALE: 1/16" = 1'			

Luminaire Schedule				
Project: All Projects				
Symbol	Qty	Label	Lumens	TLF
□	8	L	36000	0.750
○	9	A	20500	0.750
+	11	H	8000	0.750
□	2	L1	13500	0.750
□	2	K	1725	0.950
Description				
EFXM400CV				
LD12DWH/LD12D25HB				
SD12D10HVMH				
EFXM175CV				
P5644-30				