

•
•
•
•
•
•
•

389 Congress St.rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: John Nolan/Ben Walter **From:** Mike Nugent

Fax: 878-5235/7746016 **Date:** July 15, 2004

Phone **Pages:** 1

Re: 191 Riverside St.(268 A002)

Urgent For Review Please Comment Please Reply Please Recycle



I have nearly completed the review of the above project. Sr. Planner, Bill Needleman advises that the final permit cannot be issued until they have finally signed off. There are Site Plan Issues.

Here are my comments/Questions:

Fire Dampers are omitted in the following locations:

- 1) On page M1
 - a) " 20" x 20" S R 220 CFM Acme XTW2H"
 - b) On an HVAC 3 Supply and return
 - c) On EF-3
- 2) On page M2
 - a) " 20" x 20" SR 220 CFM Acme XTW2H"
 - b) On an HVAC 4 Supply and return
 - c) On EF 4
- 3) On Page M3
 - a) Stair 3 Duct Penetration
- 4) On Page M4
 - a) Stair 1 Duct Penetration
- 5) Need info for exhaust system in repair garage that establishes compliance with Table 1604.3 of the 1993 BOCA Mechanical Code.
- 6) Loading capability and testing standards used for the Glazing/Store Front See Chapter 24 1999 BOCA

• • • • •

