

Freedom Fire Protection, Inc.

Over 30 Years of Fire Protection Experience
209 Quaker Ridge Rd. Casco, Maine 04015
Phone 207/627-4109 Fax 207/627-7340

April 30, 2013

Portland City Hall
Third Floor Room 315
Portland, Maine 04101

Attn. Captain Pirone

Ref: Berlin City Toyota Service Bay Addition
191 Riverside Street
Portland, Maine 04101

Subj: Sprinkler System Certification Letter

This letter is certification that sprinkler system for the new service bay was designed, calculated and installed at the above referenced location by Freedom Fire Protection, and meets the requirements of the National Fire Protection Association 13 Standard (NFPA 13). The sprinkler system for this area was connected to an existing sprinkler system supplying sprinkler protection to the rest of the building.

Sprinkler permit # 9967 was issued by the State of Maine Fire Marshal's office.

The sprinkler system was left in service by Freedom Fire Protection on April 12, 2013.

Regards,

Mark Radziszewski