

. . . Fire Protection by Computer Design

METROPOLITAN FIRE PROTECTION
460 PARKWAY BOULEVARD
BROOMALL, PA 19008
484-421-3021

Job Name : BERLIN CITY TOYOTA
Building : 191 RIVERSIDE STREET
Location : PORTLAND, MAINE 04103
System : #1 AREA#1
Contract :
Data File : Berlin City Toyota HC.WXF

Hydraulic Design Information Sheet

Name - BERLIN CITY TOYOTA Date - 4/4/12
 Location - PORTLAND, MAINE 04103
 Building - 191 RIVERSIDE STREET System No. - #1 AREA#1
 Contractor - Contract No. -
 Calculated By - TIM VESS Drawing No. - FP-2
 Construction: () Combustible (X) Non-Combustible Ceiling Height - VARIES
 Occupancy - CAR DEALERSHIP

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E

			System Type	Sprinkler/Nozzle
M	Area of Sprinkler Operation - 1500		(X) Wet	Make TYCO
	Density - .20		() Dry	Model TY-FRB
D	Area Per Sprinkler - 130.00		() Deluge	Size 3/4"
E	Elevation at Highest Outlet - 20.00		() Preaction	K-Factor 8.0
S	Hose Allowance - Inside -		() Other	Temp.Rat.155
I	Rack Sprinkler Allowance -			
G	Hose Allowance - Outside - 250			

N

Note

Calculation Flow Required - 572.298 Press Required - 55.802 At Test
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9/8/2004		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 82	@ Press -	
R	Residual Press - 78	Elev. -	Well
	Flow - 1393		Proof Flow
S	Elevation - 0		

U

P Location -

P

L Source of Information - PORTLAND WATER DISTRICT

Y


Water Supply Curve (C)

METROPOLITAN FIRE PROTECTION
BERLIN CITY TOYOTA

Page 2
Date 4/4/12

City Water Supply:
 C1 - Static Pressure : 82
 C2 - Residual Pressure: 78
 C2 - Residual Flow : 1393

Demand:
 D1 - Elevation : 8.662
 D2 - System Flow : 322.298
 D2 - System Pressure : 55.802
 Hose (Adj City) :
 Hose (Demand) : 250
 D3 - System Demand : 572.298
 Safety Margin : 25.427



Fittings Used Summary

METROPOLITAN FIRE PROTECTION
 BERLIN CITY TOYOTA

Page 3
 Date 4/4/12

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

METROPOLITAN FIRE PROTECTION
 BERLIN CITY TOYOTA

Page 4
 Date 4/4/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
33	18.5		22.98	na				
43	20.0		15.9	na				
106	20.0	8	13.44	na	29.33	0.2	130	7.0
105	20.0	8	11.63	na	27.28	0.2	130	7.0
104	20.0	8	10.8	na	26.29	0.2	130	7.0
103	20.0	8	10.57	na	26.01	0.2	130	7.0
102	20.0	8	10.57	na	26.01	0.2	130	7.0
101	20.0	8	10.81	na	26.31	0.2	130	7.0
23	20.0		27.38	na				
32	18.5		23.6	na				
42	20.0		23.29	na				
22	20.0		28.34	na				
31	18.5		23.92	na				
41	20.0		23.66	na				
21	20.0		28.52	na				
30	18.5		24.15	na				
40	20.0		23.71	na				
20	20.0		28.69	na				
29	18.5		24.4	na				
39	20.0		23.97	na				
19	20.0		29.04	na				
28	18.5		24.58	na				
38	20.0		24.34	na				
60	20.0		29.12	na				
18	20.0		30.3	na				
27	18.5		24.68	na				
37	20.0		24.31	na				
17	20.0		30.77	na				
26	18.5		24.73	na				
36	20.0		24.39	na				
16	20.0		31.49	na				
34	18.5		22.81	na				
25	18.5		24.76	na				
35	20.0		24.31	na				
15	20.0		32.35	na				
44	20.0		15.8	na				
112	20.0	8	13.38	na	29.26	0.2	130	7.0
111	20.0	8	11.59	na	27.24	0.2	130	7.0
110	20.0	8	10.78	na	26.26	0.2	130	7.0
109	20.0	8	10.56	na	26.0	0.2	130	7.0
108	20.0	8	10.56	na	26.0	0.2	130	7.0
107	20.0	8	10.81	na	26.31	0.2	130	7.0
24	20.0		27.69	na				
14	18.5		28.88	na				
13	18.5		28.95	na				
12	18.5		29.17	na				
11	18.5		29.37	na				
10	18.5		29.55	na				
9	18.5		29.91	na				
8	18.5		31.09	na				
7	18.5		31.7	na				
6	18.5		32.44	na				
5	18.5		33.35	na				
4	10.66		40.87	na				
3	7.66		43.28	na				
2	7.66		44.53	na				
1	2.0		47.44	na				

Flow Summary - Standard

METROPOLITAN FIRE PROTECTION
BERLIN CITY TOYOTA

Page 5
Date 4/4/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
0	2.0		51.52	na				
TEST	0.0		55.8	na	250.0			

The maximum velocity is 17.09 and it occurs in the pipe between nodes 33 and 43

Final Calculations - Hazen-Williams

METROPOLITAN FIRE PROTECTION
BERLIN CITY TOYOTA

Page 6
Date 4/4/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
33	-108.43	1.61	2T 16.0	1.450	22.978				
to		120	0.0	16.000	-0.650				
43	-108.43	-0.3685	0.0	17.450	-6.431		Vel = 17.09		
43	0.0	1.61	0.0	6.660	15.897				
to		120	0.0	0.0	0.0				
106	-108.43	-0.3685	0.0	6.660	-2.454		Vel = 17.09		
106	29.33	1.61	0.0	8.830	13.443		K Factor = 8.00		
to		120	0.0	0.0	0.0				
105	-79.1	-0.2055	0.0	8.830	-1.815		Vel = 12.47		
105	27.28	1.61	0.0	8.830	11.628		K Factor = 8.00		
to		120	0.0	0.0	0.0				
104	-51.82	-0.0941	0.0	8.830	-0.831		Vel = 8.17		
104	26.29	1.61	0.0	8.830	10.797		K Factor = 8.00		
to		120	0.0	0.0	0.0				
103	-25.53	-0.0254	0.0	8.830	-0.224		Vel = 4.02		
103	26.01	1.61	0.0	8.830	10.573		K Factor = 8.00		
to		120	0.0	0.0	0.0				
102	0.48	0.0	0.0	8.830	0.0		Vel = 0.08		
102	26.01	1.61	0.0	8.830	10.573		K Factor = 8.00		
to		120	0.0	0.0	0.0				
101	26.49	0.0272	0.0	8.830	0.240		Vel = 4.17		
101	26.31	1.61	1T 8.0	162.160	10.813		K Factor = 8.00		
to		120	0.0	8.000	0.0				
23	52.8	0.0973	0.0	170.160	16.563		Vel = 8.32		
23	0.0	1.61	1T 8.0	1.450	27.376				
to		120	0.0	8.000	0.650				
13	52.8	0.0974	0.0	9.450	0.920		Vel = 8.32		
	0.0								
	52.80				28.946		K Factor = 9.81		
32	22.21	1.61	2T 16.0	1.450	23.601				
to		120	0.0	16.000	-0.650				
42	22.21	0.0197	0.0	17.450	0.343		Vel = 3.50		
42	0.0	1.61	8E 32.0	217.000	23.294				
to		120	1T 8.0	40.000	0.0				
22	22.21	0.0196	0.0	257.000	5.042		Vel = 3.50		
22	0.0	1.61	1T 8.0	1.450	28.336				
to		120	0.0	8.000	0.650				
12	22.21	0.0196	0.0	9.450	0.185		Vel = 3.50		
	0.0								
	22.21				29.171		K Factor = 4.11		
31	23.62	1.61	2T 16.0	1.450	23.924				
to		120	0.0	16.000	-0.650				
41	23.62	0.0220	0.0	17.450	0.384		Vel = 3.72		

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
41	0.0	1.61	1T 8.0	213.000	23.658				
to		120	0.0	8.000	0.0				
21	23.62	0.0220	0.0	221.000	4.858		Vel = 3.72		
21	0.0	1.61	1T 8.0	1.450	28.516				
to		120	0.0	8.000	0.650				
11	23.62	0.0219	0.0	9.450	0.207		Vel = 3.72		
	0.0								
	23.62				29.373		K Factor = 4.36		
30	23.94	1.61	1T 8.0	1.450	24.147				
to		120	0.0	8.000	-0.650				
40	23.94	0.0226	0.0	9.450	0.214		Vel = 3.77		
40	0.0	1.61	2E 8.0	213.000	23.711				
to		120	0.0	8.000	0.0				
20	23.94	0.0225	0.0	221.000	4.980		Vel = 3.77		
20	0.0	1.61	1T 8.0	1.450	28.691				
to		120	0.0	8.000	0.650				
10	23.94	0.0225	0.0	9.450	0.213		Vel = 3.77		
	0.0								
	23.94				29.554		K Factor = 4.40		
29	24.19	1.61	1T 8.0	1.450	24.401				
to		120	0.0	8.000	-0.650				
39	24.19	0.0231	0.0	9.450	0.218		Vel = 3.81		
39	0.0	1.61	2E 8.0	213.000	23.969				
to		120	0.0	8.000	0.0				
19	24.19	0.0230	0.0	221.000	5.075		Vel = 3.81		
19	0.0	1.61	1T 8.0	1.450	29.044				
to		120	0.0	8.000	0.650				
9	24.19	0.0230	0.0	9.450	0.217		Vel = 3.81		
	0.0								
	24.19				29.911		K Factor = 4.42		
28	34.13	1.61	1T 8.0	1.450	24.583				
to		120	0.0	8.000	-0.650				
38	34.13	0.0435	0.0	9.450	0.411		Vel = 5.38		
38	0.0	1.61	1E 4.0	106.040	24.344				
to		120	0.0	4.000	0.0				
60	34.13	0.0434	0.0	110.040	4.779		Vel = 5.38		
60	0.0	2.157	1E 6.153	106.120	29.123				
to		120	0.0	6.153	0.0				
18	34.13	0.0104	0.0	112.273	1.173		Vel = 3.00		
18	0.0	2.157	1T 12.307	1.450	30.296				
to		120	0.0	12.307	0.650				
8	34.13	0.0105	0.0	13.757	0.144		Vel = 3.00		

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 34.13					31.090		K Factor = 6.12	
27 to 37	27.61	1.61 120 0.0294	1T	8.0 0.0 0.0	1.450 8.000 9.450	24.682 -0.650 0.278		Vel = 4.35	
37 to 17	0.0 27.61	1.61 120 0.0293	2E	8.0 0.0 0.0	212.160 8.000 220.160	24.310 0.0 6.459		Vel = 4.35	
17 to 7	0.0 27.61	1.61 120 0.0293	1T	8.0 0.0 0.0	1.450 8.000 9.450	30.769 0.650 0.277		Vel = 4.35	
	0.0 27.61					31.696		K Factor = 4.90	
26 to 36	29.06	1.61 120 0.0323	1T	8.0 0.0 0.0	1.450 8.000 9.450	24.732 -0.650 0.305		Vel = 4.58	
36 to 16	0.0 29.06	1.61 120 0.0322	2E	8.0 0.0 0.0	212.160 8.000 220.160	24.387 0.0 7.100		Vel = 4.58	
16 to 6	0.0 29.06	1.61 120 0.0322	1T	8.0 0.0 0.0	1.450 8.000 9.450	31.487 0.650 0.304		Vel = 4.58	
	0.0 29.06					32.441		K Factor = 5.10	
34 to 33	107.72	3.26 120 0.0117		0.0 0.0 0.0	14.660 0.0 14.660	22.806 0.0 0.172		Vel = 4.14	
33 to 32	108.43 216.15	3.26 120 0.0425		0.0 0.0 0.0	14.660 0.0 14.660	22.978 0.0 0.623		Vel = 8.31	
32 to 31	-22.21 193.94	3.26 120 0.0348		0.0 0.0 0.0	9.290 0.0 9.290	23.601 0.0 0.323		Vel = 7.45	
31 to 30	-23.62 170.32	3.26 120 0.0273		0.0 0.0 0.0	8.160 0.0 8.160	23.924 0.0 0.223		Vel = 6.55	
30 to 29	-23.95 146.37	3.26 120 0.0207		0.0 0.0 0.0	12.290 0.0 12.290	24.147 0.0 0.254		Vel = 5.63	
29 to 28	-24.19 122.18	3.26 120 0.0148		0.0 0.0 0.0	12.290 0.0 12.290	24.401 0.0 0.182		Vel = 4.70	

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
28	-34.13	3.26		12.290	24.583				
to		120		0.0	0.0				
27	88.05	0.0081		12.290	0.099		Vel =	3.38	
27	-27.61	3.26		12.290	24.682				
to		120		0.0	0.0				
26	60.44	0.0041		12.290	0.050		Vel =	2.32	
26	-29.06	3.26	1E	9.408	12.290	24.732			
to		120		0.0	9.408	0.0			
25	31.38	0.0012		0.0	21.698	0.026	Vel =	1.21	
25	0.0	1.61	1E	4.0	1.450	24.758			
to		120		0.0	4.000	-0.650			
35	31.38	0.0372		0.0	5.450	0.203	Vel =	4.95	
35	0.0	1.61	1E	4.0	212.160	24.311			
to		120		0.0	4.000	0.0			
15	31.38	0.0372		0.0	216.160	8.035	Vel =	4.95	
15	0.0	1.61	1T	8.0	1.450	32.346			
to		120		0.0	8.000	0.650			
5	31.38	0.0371		0.0	9.450	0.351	Vel =	4.95	
	0.0								
	31.38					33.347	K Factor =	5.43	
34	-107.72	1.61	2T	16.0	1.450	22.806			
to		120		0.0	16.000	-0.650			
44	-107.72	-0.3641		0.0	17.450	-6.353	Vel =	16.98	
44	0.0	1.61		0.0	6.660	15.803			
to		120		0.0	0.0	0.0			
112	-107.72	-0.3640		0.0	6.660	-2.424	Vel =	16.98	
112	29.26	1.61		0.0	8.830	13.379	K Factor =	8.00	
to		120		0.0	0.0	0.0			
111	-78.46	-0.2026		0.0	8.830	-1.789	Vel =	12.36	
111	27.24	1.61		0.0	8.830	11.590	K Factor =	8.00	
to		120		0.0	0.0	0.0			
110	-51.22	-0.0921		0.0	8.830	-0.813	Vel =	8.07	
110	26.26	1.61		0.0	8.830	10.777	K Factor =	8.00	
to		120		0.0	0.0	0.0			
109	-24.96	-0.0243		0.0	8.830	-0.215	Vel =	3.93	
109	26.00	1.61		0.0	8.830	10.562	K Factor =	8.00	
to		120		0.0	0.0	0.0			
108	1.04	0.0001		0.0	8.830	0.001	Vel =	0.16	
108	26.00	1.61		0.0	8.830	10.563	K Factor =	8.00	
to		120		0.0	0.0	0.0			
107	27.04	0.0282		0.0	8.830	0.249	Vel =	4.26	

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
107	26.30	1.61	1T 8.0	162.160	10.812			K Factor = 8.00	
to 24	53.34	120 0.0992	0.0	8.000	0.0			Vel = 8.41	
24	0.0	1.61	1E 4.0	1.450	27.693				
to 14	53.34	120 0.0991	0.0	4.000	0.650			Vel = 8.41	
14	0.0	3.068	0.0	14.660	28.883				
to 13	53.34	120 0.0043	0.0	0.0	0.0			Vel = 2.31	
13	52.80	3.068	0.0	14.660	28.946				
to 12	106.14	120 0.0153	0.0	0.0	0.0			Vel = 4.61	
12	22.22	3.068	0.0	9.290	29.171				
to 11	128.36	120 0.0217	0.0	0.0	0.0			Vel = 5.57	
11	23.62	3.26	0.0	8.160	29.373				
to 10	151.98	120 0.0222	0.0	0.0	0.0			Vel = 5.84	
10	23.94	3.26	0.0	12.290	29.554				
to 9	175.92	120 0.0290	0.0	0.0	0.0			Vel = 6.76	
9	24.19	3.26	2E 18.815	13.160	29.911				
to 8	200.11	120 0.0369	0.0	18.815	0.0			Vel = 7.69	
8	34.14	3.26	0.0	12.290	31.090				
to 7	234.25	120 0.0493	0.0	0.0	0.0			Vel = 9.00	
7	27.61	3.26	0.0	12.290	31.696				
to 6	261.86	120 0.0606	0.0	0.0	0.0			Vel = 10.07	
6	29.06	3.26	0.0	12.290	32.441				
to 5	290.92	120 0.0737	0.0	0.0	0.0			Vel = 11.18	
5	31.38	3.26	3E 28.223	18.160	33.347				
to 4	322.3	120 0.0890	0.0	28.223	3.396			Vel = 12.39	
4	0.0	3.26	1E 9.408	3.000	40.872				
to 3	322.3	120 0.0891	0.0	9.408	1.299			Vel = 12.39	
3	0.0	4.26	2E 26.334	25.540	43.276				
to 2	322.3	120 0.0242	0.0	26.334	0.0			Vel = 7.25	

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
2 to 1	0.0 322.3	4.26 120 0.0242	1E 13.167 0.0	5.660 13.167 18.827	44.531 2.451 0.456		Vel = 7.25
1 to 0	0.0 322.3	4.26 120 0.0242	2E 26.334 1Zac 0.0	4.830 26.334 31.164	47.438 3.332 0.754		* Fixed loss = 3.332 Vel = 7.25
0 to TEST	0.0 322.3	8.27 140 0.0007	4E 113.872 0.0	458.330 113.872 572.202	51.524 3.866 0.412		* Fixed loss = 3 Vel = 1.93
	250.00 572.30				55.802		Qa = 250.00 K Factor = 76.61