

Application ID Number: 2-0116

Delete Save Close

Department: Fire

Status: Approved with Conditions

Reviewer: Lt. McDougall

Comments:

Approval Date: 02/11/2002

Given On Date: 02/11/2002

OK to Issue Permit Name: Lt. McDougall Date: 02/11/2002 Date 2:

Conditions Section: Add New Condition From Add New Condition Delete Condition

the fire alarm system shall be installed in accordance with NFPA 72 standards

fire extinguishers shall be installed in accordance with NFPA 10 standards

Create Date: 02/08/2002 By: jodnea Update Date: 02/11/2002 By: dgc