

Attic or additional Floor Joist Species Dimensions and Spacing (Table 802.4.2 or 503.3.1(1) & Table 503.3.2(1))	2x4 Manuf. Trusses @ 24"oc. 2x4 man.f. Scissor Truss @ 24"oc.	Boise Cascade spec. will be submitted ok
Roof Rafter; Pitch, Span, Spacing & Dimension (Table 802.3.2(7))	0:12 9'6" x 10'	OK
Sheathing; Floor, Wall and roof (Table 503.2.1(1))	1/4 T & G Advantec, 7/16 OSB, 1/2" CDX	OK
Fastener Schedule (Table 602.3(1) & (2))	BOCA 1999 notes	OK
Private Garage Section 309 and Section 407 1999 BOCA) Living Space ? (Above or beside)		
Fire separation	1 hr ^{Ceilings} walls / walls	OK
Fire rating of doors to living space Door Sill elevation (407.5 BOCA)	1 hr 4"	OK
Egress Windows (Section 310)	1 each Bed room per plans	OK
Roof Covering (Chapter 9)	Asphalt	OK
Safety Glazing (Section 308)	N/A	OK
Attic Access (BOCA 1211.1)	see page 10 notes	
Draft Stopping around chimney	2" 26 gauge see notes	shows no chimney N/A