PLUMBING FIXTURE SCHEDULE

TAG	DESCRIPTION	FIXTURE	FAUCET/DRAIN	TRIM	SUPPORT	NOTES
WC–A	FLOOR MOUNTED ADA WATER CLOSET	AMERICAN STANDARD MODEL 2216.143, VITREOUS CHINA, SIPHON JET TYPE, 1.6GPF, WHITE		CHURCH #9500–SSC SEAT – WHITE		
LAV–A	WALL–HUNG – ADA – LAVATORY	AMERICAN STANDARD MODEL 0356.421, VITREOUS CHINA, 21"x19", 4" CENTERS	CHICAGO FAUCETS MODEL 802–NVCP	MCGUIRE LOOSE KEY ANGLE STOPS, ESCUTCHEONS AND RISERS	ZURN MODEL #Z–1231 CARRIER	1 2
SK–A	STAINLESS STEEL COUNTERTOP SINK	ELKAY MODEL LRAD–2219–60–4, 304 SS, 18 GA SELF–RIMMING SINGLE BOWL SINK, 4 HOLES	CHICAGO FAUCETS MODEL #1102CP W/369 LEVER HANDLES	–	–	2

NOTES: 1 PROVIDE TRAP PRIMER CONNECTED TO LAV–A COLD WATER.
2 PROVIDE OFFSET TRAP WITH GRID DRAIN STRAINER & INSULATED DRAIN & SERVICE PIPES.

DOMESTIC WATER HEATER SCHEDULE

TAG	FUEL	INPUT WATTS	RECOVERY RATE 63°F RISE	STORAGE TANK SIZE/GAL.	ELECTRICAL DATA AMPS	ELECTRICAL DATA VOLT/ø	FLUE SIZE (in.)	OPERATING WEIGHT (lbs.)	TYPICAL UNIT MFR. & MODEL NO.	NOTES
EWH–1	ELEC.	4600	0.5 GPM	N/A	22	208/1	N/A	N/A	CHRONOMITE E–46 FLP	

NOTES:

PLUMBING FIXTURE CONNECTION SCHEDULE

FIXTURE	CW	HW	WASTE	VENT	NOTES
FLOOR – MOUNTED WATER CLOSET	1/2"	–	3"	2"	
LAVATORY	1/2"	1/2"	1–1/2"	1–1/2"	
STAINLESS STEEL COUNTERTOP SINK	1/2"	1/2"	1–1/2"	1–1/2"	

NOTES:

COMPUTER ROOM UNIT SCHEDULE

TAG	SERVICE	TYPE	COOLING MBH TOTAL	COOLING MBH SENS	MAX CFM	DIRECT EXPANSION COIL EAT °F	DIRECT EXPANSION COIL LAT °F	DIRECT EXPANSION COIL ROWS	DIRECT EXPANSION COIL FACE AREA	ESP IN. WC	REHEAT MBH	REHEAT KW	ELECTRICAL DATA FLA	ELECTRICAL DATA VOLTS/ø	ELECTRICAL DATA FAN HP	WEIGHT LBS.	TYPICAL UNIT MFG & MODEL NO.	NOTES
AC–1	ETO	DUCTLESS SPLIT	24	–	700	80	55	–	–	0.1	N/A	N/A	17	208/1	1/12	207	MITSUBISHI P24FK3	1

NOTES: 1 INSTALL CU–1 IN BASEMENT.

FAN SCHEDULE

TAG	LOCATION	SERVICE	TYPE	ROOF OPENING	CFM	SP IN W.G.	DIAMETER IN.	RPM	ELECTRICAL DATA WATTS/HP	ELECTRICAL DATA VOLTS	ELECTRICAL DATA PH	ELECTRICAL DATA VFD	TYPICAL UNIT MFG & MODEL NO.	NOTES
EF–1	RESTROOM 107	RESTROOM EXHAUST	CENT. CEILING	N/A	70	0.10	4	–	19/–	120	1	NO	PANASONIC FV–07VQ2	

NOTES:

REGISTER, DIFFUSER & GRILLE SCHEDULE

TAG	CFM	NECK SIZE	TYPE	ΔP	MAX NC	TYPICAL UNIT MFG & MODEL NO.	NOTES
CD–1	100	6"ø	4–WAY	.04	<10	KRUEGER PLQ–12x12	
CD–2	200	8"ø	4–WAY	.03	<10	KRUEGER PLQ–12x12	
RG–1	1000	18x18	–	.04	16	KRUEGER EGC–10	
RG–2	300	12x10	–	.03	12	KRUEGER 880–H	
SG–1	300	12x10	DBL DEFL.	.03	12	KRUEGER 880–H	

NOTES:

NOTES:

1. SEE SHEET M–0.0 FOR LEGEND AND ABBREVIATIONS.

vocon DESIGN INC.
2450 Prospect Avenue
Cleveland, Ohio 44115
216 623-6800 p.
216 623-0410 f.
vocon@vocon.com

K.W. Architects, Inc
2450 Prospect Ave. 1st flr. 216-623-6800
Cleveland, Ohio 44115 216-623-0410fax

SMRT
ARCHITECTURE ENGINEERING PLANNING
SMRT
144 Fore Street/P.O. Box 618
Portland, Maine 04104
tel. (207) 772-3846
fax. (207) 772-1070

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am a duly registered Architect under the laws of the State of which governors this project. WARNING: per LAW No person may alter these documents unless person is, "or under the direct supervision of" the licensed architect.

Signature:

Registration No:

Date:

SEAL:

Type III Branch
Proposed New Construction
85 Commercial Street–Long Warf
Portland, ME

KeyBank
2025 Ontario St., 4th Floor, Cleveland, Ohio 44115

REVISIONS:

Drawn by: BGQ
Checked by: DBR
Job Number: 03095-00

Dwg. Phase: Construction Documents

Sheet Title:

DETAILS, SCHEDULES AND SPECIFICATIONS

Sheet Number:

M–5.1

Original Date: 9-5-03