Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/10/16

5/27/16

Scope of Work: Loring House

Casco Bay Electric is installing system connected strobes in (14) handicapped accessible units to comply with ADA requirements.

There is an existing conventional Notifier fire alarm control panel in the building which will be utilized.

Norris Inc. will test the new devices when the installation is complete.