

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 3-3-2005
 Permit # 054184
 CBL# 269 B 001

LOCATION: Barron Center Ambulance → 1097 Brighton Ave **METER MAKE & #**
CMP ACCOUNT # _____ **OWNER** City of Portland
TENANT _____ **PHONE #** 541-6594

					TOTAL	EACH FEE	
OUTLETS		Receptacles		Switches		Smoke Detector	.20
	<u>5</u>	<u>Junction Boxes</u>					
FIXTURES		Incandescent	<u>2</u>	Fluorescent		Strips	.20
							<u>1.40</u>
SERVICES		Overhead		Underground		TTL AMPS <800	15.00
		Overhead		Underground		>800	25.00
Temporary Service		Overhead		Underground		TTL AMPS	25.00
							25.00
METERS		(number of)					1.00
MOTORS		(number of)					2.00
RESID/COM		Electric units					1.00
HEATING		oil/gas units		Interior		Exterior	5.00
APPLIANCES		Ranges		Cook Tops		Wall Ovens	2.00
		Insta-Hot		Water heaters		Fans	2.00
		Dryers		Disposals		Dishwasher	2.00
		Compactors		Spa		Washing Machine	2.00
		Others (denote)					2.00
MISC. (number of)		Air Cond/win					3.00
		Air Cond/cent				Pools	10.00
		HVAC		EMS		Thermostat	5.00
		Signs					10.00
		Alarms/res					5.00
		Alarms/com					15.00
		Heavy Duty(CRKT)					2.00
		Circus/Carnv					25.00
		Alterations					5.00
		Fire Repairs					15.00
		E Lights					1.00
		E Generators					20.00
PANELS		Service		Remote		Main	4.00
TRANSFORMER		0-25 Kva					5.00
		25-200 Kva					8.00
		Over 200 Kva					10.00
						TOTAL AMOUNT DUE	
		MINIMUM FEE/COMMERCIAL	45.00			MINIMUM FEE	35.00



CONTRACTORS NAME Vernon Cox City Employee **MASTER LIC. #** MS60016582
 ADDRESS 1145 Brighton Ave **LIMITED LIC. #** _____
 TELEPHONE 541 6594

SIGNATURE OF CONTRACTOR _____

Ambulance Entrance Renovations
The Barron Center
1145 Brighton Ave. Portland

Low Voltage work and Door Systems to be done by HCI

The following work will be done by in-house Electricians and City Employees

Vernon L.Cox # MS60016582 Ph -207-541-6594 or pager 471-0048
Gary Jackson #JY40001938

Install (2) light fixtures

Provide ¾" Rigid conduit run for low voltage cable to be installed by others

Provide ¾" EMT conduit run with (4) J boxes

(1) 20 amp circuit for Door motors (1) 20 amp circuit for Cabinet unit heater

Supplies needed

60' ¾" EMT Conduit

30' ¾" rigid Conduit

[8] ¾" EMT connectors

[4] ¾" EMT couplings

[12] ¾" Mineralac hangers

[3] ¾" rigid two hole straps

[5] 4" square J boxes

[2] 20 amp sp THQB Breakers

#12 THHN to be used from stock