

City of Portland, Maine - Building or Use Permit Application
 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-1622	Issue Date: JAN - 3 2005	CBL: 271 A002001
-----------------------	------------------------------------	---------------------

Location of Construction: 550 Warren Ave	Owner Name: Joker's Realty Two Llc	Owner Address: 510 Warren Ave
Business Name:	Contractor Name: Destefano and Associates	Contractor Address: 2456 Lafayette Rd Portsmouth
Lessee/Buyer's Name	Phone:	Permit Type: Additions - Commercial

Past Use: Commercial/Portland Sports Ctr	Proposed Use: Portland Sports Ctr. 8,000 sq ft addition for Batting Cages "Fitter Ropes"	Permit Fee: \$3,696.00	Cost of Work: \$400,000.00	CEO District: 5
--	---	----------------------------------	--------------------------------------	---------------------------

Proposed Project Description: Portland Sports Ctr. 8,000 sq ft addition for Batting Cages <i>original approval under permit 03-088Z</i>	FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: <i>A4</i> Type: <i>3B</i> <i>12/30/04</i>
--	--	---

Permit Taken By: Idobson	Date Applied For: 10/27/2004	Zoning Approval
------------------------------------	--	------------------------

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..	Special Zone or Reviews <input type="checkbox"/> Shoreland <i>NA</i> <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <i>flood zone</i> <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <i>original #2003-0066</i> Maj <input checked="" type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>11/15/04</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:
--	---	---	--

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

Form # P 04

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK
CITY OF PORTLAND

Please Read Application And Notes, If Any, Attached

PERMIT

Permit Number: 041622

PERMIT ISSUED
JAN - 3 2005
CITY OF PORTLAND

This is to certify that Joker's Realty Two Llc /Destination and Address
has permission to Portland Sports Ctr. 8,000 sq addition Battin pages
AT 550 Warren Ave City of Portland 271 A002001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is laid or closed-in. **HEAVY NOTICE IS REQUIRED.**

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. [Signature]
Health Dept. _____
Other _____
Department Name _____

[Signature] 12/30/04
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-1622	Date Applied For: 10/27/2004	CBL: 271 A002002
------------------------------	--	----------------------------

Location of Construction: 550 Warren Ave	Owner Name: Portland Sports Center Llc	Owner Address: 512 Warren Ave	Phone:
Business Name:	Contractor Name: Destefano and Associates	Contractor Address: 2456 Lafayette Rd Portsmouth	Phone: (603) 765-1638
Lessee/Buyer's Name	Phone:	Permit Type: Additions - Commercial	

Proposed Use: Portland Sports Ctr. 8,000 sq ft addition for Batting Cages	Proposed Project Description: Portland Sports Ctr. 8,000 sq ft addition for Batting Cages
---	---

Dept: Zoning **Status:** Approved **Reviewer:** Marge Schmuckal **Approval Date:** 11/15/2004
Note: was part of the original approval in 2003 - #03-0882 **Ok to Issue:**

Dept: Building **Status:** Approved **Reviewer:** Mike Nugent **Approval Date:** 12/30/2004
Note: **Ok to Issue:**

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Lt. MacDougal **Approval Date:** 1111512004
Note: **Ok to Issue:**

- 1) the fire alarm system shall be maintained to NFPA 72 standards
- 2) the sprinkler system shall be maintained to NFPA 13 standards
- 3) Application requires State Fire Marshal approval.

Dept: Engineering **Status:** **Reviewer:** Tony **Approval Date:** **Ok to Issue:**

- The stormwater "hydrocad" calculations diagram does not agree with the post-development conditions map. Specifically, the report diagram specifies "pond 2P" flowing in "pond 1P". The plan specifies "pond 1P" flowing into the analysis point, "pond 2P".

- Although the stormwater report reflects a reduction in the post-development peak rates of runoff outletting the site, Public Works is more concerned with the increased volume of runoff leaving the site. The stormwater narrative does not discuss the downstream flooding issues for properties on Holm Avenue, that are currently impacted by the volume of runoff generated on properties along Warren Avenue. This development will result in a peak volume runoff increase of 90%. This will certainly have an impact on the properties along Holm Avenue. As such, Public Works is requesting the applicant either develop a plan to retain additional runoff volume or make an infrastructure financial contribution towards stormwater improvements planned through the Capisic Watershed Master Plan.

Dept: DRC **Status:** Approved with Conditions **Reviewer:** Sebago Technic **Approval Date:** 07/22/2003
Note: **Ok to Issue:**

- 1) see Planning conditions

Dept: Planning **Status:** Approved with Conditions **Reviewer:** Kandi Talbot **Approval Date:** 07/22/2003
Note: **Ok to Issue:**

Location of Construction: 550 Warren Ave	Owner Name: Portland Sports Center Llc	Owner Address: 5 12 Warren Ave	Phone:
Business Name:	Contractor Name: Destefano and Associates	Contractor Address: 2456 Lafayette Rd Portsmouth	Phone (603) 765-1638
Lessee/Buyer's Name	Phone:	Permit Type: Additions - Commercial	

- 4) iv. Fixture "E", as shown on the lighting photometric plan, shall not exceed 250 watts.
- 5) iii. that the applicant contribute \$25,000 towards stormwater improvements planned through the Capisic Brook Watershed Master Plan prior to issuance of a building permit.
- 6) ii. that the plans be revised to include a landscaped island with trees on the easterly side of the rear parking area, that groups of buffering be installed to screen the property from the rear, that the Crimson Barberry specie be changed to a Bayberry specie or a plant which is more natural and less invasive, and that the plan be reviewed and approved by the City Arborist.
- 7) i. that the applicant contribute \$5,000 for construction of sidewalk and granite curb along Warren Avenue, to connect the existing sidewalks between the Joker's property and Home Depot's property prior to issuance of a building permit.

Comments:

11/16/2004-mjn:

- 1) The Statement of Special Inspection needs to be more inclusive, please look at Section 1704 of the 2003 IBC. The submission just includes geotechnical elements and foundation work.
- 2) The "MUROX" plans are not stamped.
- 3) Changer Nangia's page 3 certification form is incomplete. Use Group groups need to be properly identified and the type of construction. (and more)
- 4) Need stamped HVAC Plans
- 5) Is the Modular Building staying????????????????? If that's the intent....Type 2 construction??????????????
- 6) Interested in Fire separation assemblies between the offices and the "A" use groups.
- 7) Looking for some recognition of the potential for Snow Drifting conditions and the design work necessary to accommodate this.

All Purpose Building Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

550 Warren Ave

Location/Address of Construction: <u>512 Warren Ave</u>		
Total Square Footage of Proposed Structure <u>8000 Expansion</u>	Square Footage of Lot <u>311,963</u>	
Tax Assessor's Chart, Block & Lot Chart# <u>278</u> Block# <u>A</u> Lot# <u>1</u>	Owner: <u>Double Play LLC</u> <u>Mike Courts</u>	Telephone: <u>207 878-2600</u>
Lessee/Buyer's Name (If Applicable)	Applicant name, address & telephone: <u>603-730-0339</u> <u>DeStefano & Associates</u> <u>2456 Lafayette Rd.</u>	cost Of Work: \$ <u>400,000</u> Fee: \$ <u>3096</u>
Current use: <u>Sports</u> <u>Portsmouth, NH 03801</u>		
If the location is currently vacant, what was prior use: _____		
Approximately how long has it been vacant: _____		
Proposed use: <u>Sports</u>		
Project description: <u>Addition of 8000 sq ft existing sports facility for batting cages.</u>		
Contractor's name, address & telephone: <u>same as Applicant.</u>		
Who should we contact when the permit is ready: <u>John DeStefano 603 765 1638</u>		
Mailing address: <u>cell 251-0820 Andy</u> <u>JDeStefano@DeStefano-Assoc.com</u>		
We will contact you by phone when the permit is ready. You must come in and pick up the permit and review the requirements before starting any work, with a Plan Reviewer. A stop work order will be issued and a \$100.00 fee if any work starts before the permit is picked up. PHONE:		

IF THE REQUIRED INFORMATION IS NOT INCLUDED IN THE SUBMISSIONS THE PERMIT WILL BE AUTOMATICALLY DENIED AT THE DISCRETION OF THE BUILDING/PLANNING DEPARTMENT, WE MAY REQUIRE ADDITIONAL INFORMATION IN ORDER TO APPROVE THIS PERMIT.

I hereby certify that I am the Owner of record of the named property, or that the owner of record authorizes the proposed work and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: John DeStefano Date: 10/12/04

This is NOT a permit, you may not commence ANY work until the permit is issued.
If You are in a Historic District you may be subject to additional permitting and fees with the Planning Department on the 4th floor of City Hall

DESTEFANO & ASSOCIATES, INC.
 2456 Lafayette Road, Suite 3
 PORTSMOUTH, NH 03801

LETTER OF TRANSMITTAL

(603)430-0339
 Fax (603)430-0346

TO CITY OF PORTLAND
BUILDING DEPT

DATE	11-30-04	JOB NO.
ATTENTION	MIKE NOBENT	
RE:	FROZEN ROPES 510 WAREH AVE	

WE ARE SENDING YOU Attached Under separate cover via _____ the following items:

Shop drawings Prints Plans Samples Specifications
 Copy of letter Change order _____

COPIES	DATE	NO	DESCRIPTION
1	10/25		2003 STRUCTURAL M INFO STAMPED 10/26/04 (1 SHEET)
1	11/22		STATEMENT OF SPECIAL INSPECTIONS (18 SHTS)

THESE ARE TRANSMITTED as checked below:

- For approval Approved as submitted Resubmit _____ copies for approval
 For your use Approved as noted Submit _____ copies for distribution
 As requested Returned for corrections Return _____ corrected prints
 For review and comment _____
 FOR BIDS DUE _____ PRINTS RETURNED AFTER LOAN TO US

REMARKS _____


PLEASE CALL JOHN DESTEFANO OR MYSELF
 IF YOU HAVE ANY QUESTIONS.

THANK YOU,


ANDY VANASSE

RSI-0820

COPY TO _____

SIGNED 

FROM DESIGNER: Chander P. Nangia
 DATE: October 25th, 2004
 Job Name: Frozen Pipes
 Address of Construction: Portland, Maine



2003 International Building Code

Construction project was designed according to the building code criteria listed below:

Building Code and Year 2003 Use Group Classification(s) A, E
 Type of Construction 2B

Will the structure have a fire suppression system in accordance with Section 903.3.1 of IBC?
 Is the structure mixed use? _____ If yes, separated or non separated (see Section 302.3).
 Supervisory alarm system? _____ Geotechnical/Soils report required? (See Section 180.)

STRUCTURAL DESIGN CALCULATIONS

Submitted for all structural members (IBC 1.106.1.1)

DESIGN LOADS ON CONSTRUCTION DOCUMENTS (1803)

Uniformly distributed floor live loads (1803.7.7, 1807)

Floor Area Use	Loads Shown

- Live loads (IBC)
- Roof live
- Roof snow loads (1803.7.8, 1808)
- Ground snow load, P_g (1808.2)
- If $P_g > 10$ psf, flat-roof snow load, P_f (1808.3)
- If $P_g > 10$ psf, snow weight loads, C_s (Table 1808.3.1)
- If $P_g > 10$ psf, snow load height reduction factor, C_d (Table 1808.3)
- Roof thermal factor, C_t (Table 1808.3.2)
- Sloped roof snow load, P_s (1808.4)

Wind loads (1803.1.4, 1809)

ASCE 7-6 Design option utilized (1809.1.1, 1809.2)
102 Basic wind speed (1809.3)
II, 1.0 Building category and wind importance factor, I_w (Table 1809.5, 1809.6)
C Wind exposure category (1809.4)
10, 18 Internal pressure coefficient (ASCE 7)
25, 9, 6 Component and cladding pressures (1809.1.1, 1809.5.2)
25, 9, 6 Main force wind pressure (1809.1.1, 1809.5.1)
30, 7

- Seismic design category (1816.8)
- Ballistic design force-resisting system (Table 1817.8.2)
- Response modification coefficient, R , and deflection amplification factor, C_d (Table 1817.8.3)
- Equivalent laterally force analysis
- Analysis procedure (1818.6, 1817.8)
- Design base shear (1817.4, 1817.8.1)

Earthquake design data (1803.1.5, 1814 - 1826)

IBC 2003 Design option utilized (1814.1)
I Seismic use group (Category) (Table 1804.3, 1816.2)
0.5274 Spectral response coefficients, S_{DS} & S_{D1} (1816.1)
0, 230
E Site class (1816.1.3)

- Flood loads (1808.1.6, 1812)
- Flood hazard area (1812.9)
- Elevation of structure
- Other loads
- Concentrated loads (1807.4)
- Partition loads (1807.5)
- Impact loads (1807.8)
- Misc. loads (Table 1807.6, 1807.6.1, 1807.7, 1807.12, 1807.13, 1812, 1812.1, 1817, 1810.4)

Statement of Special Inspections

Project: Frozen Ropes E-06098

Location: Portland, Maine

Owner: Frozen Ropes

Owner's Address: 5 10 Warren Avenue, Portland, ME 04101

Architect of Record: Curtis Walter Steward Architects, Portland, ME 04101

Structural Engineer of Record: Murox Building System, St George, Quebec
(Super Structure & Wall System **ONLY**)

This statement of Special Inspections is submitted as a condition for issuance in accordance with **the** Special Inspection requirements of the Building **Code. It includes a** Schedule of Special Inspection Services applicable to this project as **well as the name of the** Special Inspector and the identity of other approved agencies intended to be retained for conducting **these** inspections.

The **Special** Inspector shall keep records of **all** inspections and shall furnish inspection reports to the Building Official, Structural Engineer and Architect of Record. Discovered discrepancies shall be brought to the immediate attention of the Contractor for correction. If such discrepancies are not corrected, the discrepancies shall be brought to the attention **of the** Building Official, Structural Engineer and **the** Architect **of** Record. The Special Inspection program does not relieve the contractor of his **responsibilities**.

Interim reports shall be **submitted to** the Building Official, Owner, Structural Engineer and Architect of Record.

A final Report of Special Inspections documenting completion of all required Special Inspections and correction of any discrepancies noted in the inspections shall be **submitted prior to** issuance of certificate of Use and Occupancy.

Job site **safety** and means and methods of construction are solely the responsibility *of* the contractor.

Interim Report Frequency: Upon Completion


Prepared **by:** Murox Building System

Chander P. Nangia, PE

Chander P. Nangia
Signature:

Design Professional Seal

11-22-2004
Date:



Owner's Authorization:

John P. Dettono 11/29/04
Signature Date

Building Official's Acceptance:

Signature Date

Frozen Ropes E-06098

Schedule of Special Inspection Services

The following sheets comprise the required schedule of special inspections for this project. The construction divisions which requires special inspections for this project are as follows:

<p>Soils & foundations Cast-in-place concrete Precast Concrete Masonry XX Structural Steel Cold-formed steel framing</p>	<p>Spray Fire Resistance Material Wood Construction Exterior Insulation & Finnish System Mechanical & Electrical Systems Architectural Systems Special Cases</p>
---	--

Inspection Agents	Firm	Address
1. Special Inspector	Chander P. Nangia PE	2030, 127E street, Saint-George Quebec , Canada, G5Y 2W8
2. Inspector	Quality Assurance Labs	80 Pleasant Avenue Portland, Maine 04106
3. Inspector	Canam Steel Corp	1 st Avenue, St George Quebec, Canada
4. Inspector	Inspection Agency	

Seismic Performance Category D

Basic Wind Speed 102

Wind Exposure Category C

Frozen Ropes E-6098

Quality Assurance Plan

Quality Assurance for seismic Resistance

Seismic Design Category
Quality Assurance Plan Required (Y)

Description of seismic force resisting system and designated seismic systems:

Structural Brace Frame Designed by **Murox Building System.**

Quality for Wind Requirements

Basic Wind Speed (3 second gust)
Wind exposure Category
Quality Assurance Plan Required (N)

Description of **wind** force resisting **system and** designated wind resisting components:

Statement of Responsibility

Each contractor responsible for **the** construction or fabrication of **a system** or components designated **above *must*** submit a statement of Responsibility.

Contractors Required to submit Statement of Responsibility:

Steel Contractor & Erector.

Qualifications of Inspectors and Testing Technicians

The qualifications of all personnel performing Special inspection activities are subject to the approval of the Building Official, The credentials of all Inspectors and testing technicians shall be provided if requested.

It is recommended that the person administering the Special inspections program be a Structural Engineer or a Professional Engineer experienced in the design of buildings.

Key for Minimum Qualifications of inspection Agents:

When the Structural Engineer of Record deems it appropriate that the individual performing a stipulated test or inspection have a specific certification or license as indicated below, such designation shall appear below the Agent Number on the Schedule of Special Inspections.

SE	Structural Engineer - a licensed SE or PE specializing in the design of building structures. This may be required for the inspection of critical structural elements.
GE	Geotechnical Engineer - a licensed PE specializing in soil mechanics and foundations. This may be required for the inspection of difficult soil conditions or deep foundations.
EIT	Engineer-In-Training - a graduate engineer who has passed the Fundamentals of Engineering examination. This may be required for the inspection of elements that require some engineering mining to properly evaluate.
ACI	American Concrete Institute - Level I Certified Concrete Field Testing Technician. This certification is appropriate for individuals performing concrete sampling, slump tests, air-content tests, temperature tests, unit weight tests, and casting compression test cylinders.
AWS	American Welding Society - Certified Welding Inspector (CWI). This certification is appropriate for individuals performing visual inspection of welds.
ASNT	American Society of Non-Destructive Testing - Level II or III. This certification is appropriate for individuals performing ultra-sonic testing of welds.
SMSI	Structural Masonry Special inspector - certification by ICBO.
SWSI	Structural Steel and Welding Special Inspector - certification by ICBO.
SFSI	Spray-Applied Fireproofing Special Inspector - certification by ICBO.
PCSI	Prestressed Concrete Special Inspector - certification jointly sponsored by ICBO, BOCA and SBCCI with participation from PCI and PTI.
RCSI	Reinforced Concrete Special Inspector - certification jointly sponsored by ACI, ICBO, BOCA and SBCCI

Frozen Ropes E-06098

Schedule of Special Inspection Services

Structural Steel

Item	Agent No	Scope
1. Fabricator Certification/ Quality Control Procedures	#3 PE/ Canam	Review shop fabrication and quality control Procedures.
2. Material Certification	#3 PE/ Canam	Review certified mill test reports and Identification marks.
3. Open Web Steel Joists	#2 Quality Assurance Labs	Inspect installation, field welding and bridging of joists.
4. Bolting	#2 Quality Assurance Labs	Inspect installation & tightening of high strength bolts. Verify proper tightening sequence.
5. Welding	#2 Quality Assurance Labs	Visually review all welds. Verify length and size of fillet welds.
6. Structural Details	#2 Quality Assurance Labs and #3 PE/ Canam	Review of erection drawings and identification of marks.
7. Metal deck	#2 Quality Assurance Labs	Inspect steel frame for proper support, inspect welding & side lap fastening of metal roof deck.
8. Others	#2 Quality Assurance Labs	Inspect steel frame for compliance with construction documents, including bracing & connection details.
9. Anchor Bolts	2 Quality Assurance Labs	Inspect size, positioning & embedment of anchor bolts. Inspect concrete placement & consolidation around anchors.

Structural Steel Review:

Items	Agents	Scope	References
Fabricator Certification/quality control procedures	#3 Canam Steel Corp	Review each fabricators quality control procedures and welders certificates.	
Material verification of structural steel	#3 Canam Steel Corp/ #2 Quality Assurance Labs	Inspect 10% of marking to conform to ASTM Standards specified in the construction documents (IA). Review of certified mill test reports. (CSC)	ASTM A6 ASTM A568 IBC 1708.4
Material verification of high-strength, washers.	#2 Quality Assurance Labs	Inspect 15% for identification markings to conform to ASTM Standards & manufacturers certificate of compliance.	AISC ASD Section A3.4
High strength bolting	#2 Quality Assurance Labs	Inspect 10% of bearing type bolted connections & 100 % inspection of slip-critical connections (if applicable)	IBC 1704.3.3
Material verification of weld filler materials	#2 Quality Assurance Labs	Identification markings to conform to AWS specifications. Review manufacturers certificate of compliance.	AISC ASD Sect . 3.6
Welding	#3 Canam Steel #2 Quality Assurance Labs	Check welder certification (IA). Inspect 50% of single pass fillet welds less than 5/16" and 100% of roof deck welds (IA). 50% inspection of single pass fillet welds greater than or equal to 5/16", multi-pass fillet welds, complete and partial penetration groove welds. (IA)	AWS D1.1 AWS D1.3 IBC 1704.3.1
Structural framing, details & assemblies	#3 Canam Steel/ or #2 Quality Assurance Labs	Inspect 20% for size and installation and connection details for conformance with construction documents and shop drawings.	IBC 1704.3.2

IA = Inspection Agency
CSC = Canam Steel Corp

Special Inspection Requirements

Structural tests and special inspections are required on this project for the following portions of construction:

1. Soils and Foundations
2. Cast in place concrete
3. Structural Steel

Structural tests and inspections are to be performed by the registered design professional and / or a qualified person, competent in the inspection of the particular type of construction. The registered design professionals and suggestions for testing agencies are listed below.

Inspection Agent	Pirm	Address
Engineer of record for foundation	David Price Engineering,	75 Farms Edge Road , North Yarmouth, ME . 04097
Engineer of record for Structural Steel	Murox Building System	2030, 127E street, Saint-George Quebec, Canada, G5Y 2W8
Architect of Record	Curtis Walter Stewart Architects	434 Cumberland Avenue, Portland ME, 04101
Geotechnical Engineer	R.W. Gillespie	86 Industrial Park Road, ste 4 Saco, ME 04072
Testing & Inspection Agency	Quality Assurance Labs	80 Pleasant Avenue Portland, Maine 04106

Notes:

1. For minimum qualifications for persons performing special inspections refer to specifications page # 4.
2. The qualifications of all persons performing special inspections are subject to the review of the professional Engineer of record.

Certificate of Registration

This is to certify that QUASAR has registered the Quality Management System of:

LES ACIERS CANAM,

UNE DIVISION DE LE GROUPE CANAM MANAC INC.

115, Boulevard Canam Nord, Casier postal 130, St-Gédéon (Québec) G0M 1T0

to the Quality System Standard:

ISO 9001:2000

Initial Registration: 29 July 1998

Date of Issue: 5 October 2004


Date of Expiry: 29 July 2007

Scope: Design and manufacturing of structural steel components, open web steel joists and pre-fabricated buildings (MUROX)

Certificate Number: Q3345



General Manager
Edward J. Whalen, P.Eng.



Terms and Conditions governing registration and the use of this certificate are defined in the contract between QUASAR and the Holder. Refer to www.qualitysystem.com for current registration status. QUASAR, A Division of the CWB Group, 7250 West Credit Avenue, Mississauga, Ontario, Canada, L5N 5M1. Tel: (905) 542-0547, Fax: (905) 542-1318
10/04E-01/12.2

STEEL JOIST INSTITUTE

THIS TO ATTEST THAT THE

LES ACIERS CANAM

STEEL JOIST PLANT

AT

SAINT GEDEON, QUEBEC, CANADA

HAS SUCCESSFULLY PASSED THE STEEL JOIST INSTITUTE'S

PLANT CERTIFICATION PROGRAM

AND IS HEREWITH CERTIFIED ON THE FOLLOWING PRODUCTS

***** K-SERIES * LH-SERIES * DLH-SERIES * JOIST GIRDERS *****

AWARDED THIS 29TH DAY OF MARCH 2004

VALID THROUGH MARCH 29, 2006

Robert R. Hackworth

MANAGING DIRECTOR



Appendix A

Certificate of Compliance (Bolts)

NUCOR

LOT NO.
171977C

Post Office Box 6100
Saint Joe, Indiana 46785
Telephone 280/337-1600

FASTENER DIVISION

CUSTOMER NO/NAME
8616 AMCAN THREADED PRODUCTS
TEST REPORT SERIALS FB221968
TEST REPORT ISSUE DATE 11/13/03
DATE SHIPPED 2/05/04
NAME OF LAB SAMPLER: Chad Cook, LAB TECHNICIAN
CUSTOMER P.O. # L-004400
NUCOR PART NO QUANTITY DESCRIPTION
168600 400 3/4-18 X 8 A325 HWY HK
MANUFACTURE DATE 11/11/03 STRUC SCREW PLAIN



CHEMISTRY

MATERIAL NUMBER	HEAT NUMBER	CHEMISTRY COMPOSITION (HTX HEAT ANALYSIS) BY MATERIAL SUPPLIER				
		C	MN	P	S	SI
RM028522	RR 139329	.41	.89	.008	.016	.21
		MIN .30	.60			.15
		MAX .52		.040	.050	.30

GERDEAN-AMERISTEEL
(formerly CO-STEEL)
P. O. BOX 218328
TAMPA, FL 33631-8328
AZLA NO: 492.01 EXP: 2004-02-28
FOR CHEMICAL TESTING

MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-02

SURFACE HARDNESS (R50N)	CORE HARDNESS (RC)	PROOF LOAD 28400 LBS	TENSILE STRENGTH 10 DEG WEDGE (LBS)	STRESS (PSI)
N/A	30.2	PASS	50047	149841
N/A	30.0	PASS	50029	149787
N/A	31.9	PASS	50733	151695
N/A	30.6			
AVERAGE VALUES FROM TESTS		PRODUCTION LOT SIZE	22000 PCS	
30.7		50270	150508	

VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325 50 PCS SAMPLED - LOT PASSED
HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F)

DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	#SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across Corners	8	1.4000	1.4070
Grip Length	8	1.6400	1.6500
Head Height	8	0.4690	0.4740
Threads	8	PASS	PASS

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE FAR AND ASTM SPECIFICATIONS. THE SAMPLES TESTED CONFORM TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED FREE OF MERCURY CONTAMINATION. THE STEEL WAS MELTED AND MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. WE CERTIFY THAT THIS DATA IS A TRUE REPRESENTATION OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND OUR TESTING LABORATORY. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



NUCOR FASTENER
A DIVISION OF NUCOR CORPORATION

Morton Schaffer

MORTON SCHAFFER
QUALITY ASSURANCE SUPERVISOR

MECHANICAL FASTENER
CERTIFICATE NO. AZLA 182-01

MUCOR FASTENER

A Division of Nucor Corporation

Post Office Box 6100 • Saint Joe, Indiana 46785 • Telephone 219/337-1000

CUSTOMER NO/NAME: 5614 MUCOR THREADED PRODUCTS
 TEST REPORT SERIAL#: FR156522 MUCOR ORDER # 344607
 TEST REPORT ISSUE DATE: 4/06/99 COST PART #
 DATE SHIPPED: 8/18/99 CUSTOMER P.O. # 2180
 NAME OF LAB SAMPLER: MARK GRABER, LAB TECHNICIAN
 *****CERTIFIED MATERIAL TEST REPORT*****
 MUCOR PART NO: QUANTITY: LOT NO.: DESCRIPTION:
 108800 5880 3/4-10 X 1 1/4 A325 NBY HX
 MANUFACTURE DATE: 4/01/99 STRUC SCREW PLAIN



---CHEMISTRY

MATERIAL NUMBER	HEAT NUMBER	MATERIAL GRADE -1039H CHEMISTRY COMPOSITION (WT% HEAT ANALYSIS) BY MATERIAL SUPPLIER				
		C	MN	P	S	SI
RH017160	RR 117615	.40	.93	.006	.012	.19
		MIN .30	.60			.15
		MAX .52		.060	.050	.30

CO-STEEL RARITAN
 RARITAN RIVER STEEL
 P. O. BOX 17202
 NEWARK, NJ 07194
 AZLA NO: EXP:
 FOR CHEMICAL TEST!

---MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-97

SURFACE HARDNESS (R50N)	CORE HARDNESS (RC)	PROOF LOAD (LBS)	TENSILE STRENGTH	
			DEC-WEDGE	STRESS (PSI)
N/A	26.7	N/A	N/A	N/A
N/A	26.6	N/A	N/A	N/A
N/A	26.0	N/A	N/A	N/A
N/A	26.6	N/A	N/A	N/A
N/A	25.7	N/A	N/A	N/A
N/A	26.8	N/A	N/A	N/A
N/A	25.4	N/A	N/A	N/A
N/A	27.2	N/A	N/A	N/A
AVERAGE VALUES FROM TESTS		PRODUCTION LOT SIZE	107500 PCS	
26.9		TOO SHORT TO TEST		

---VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325 745 PCS. SAMPLER
HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F)

---DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across	8	1.4020	1.4090
Grip Length	8	0.2960	0.3238
Head Height	8	0.4630	0.4680
Threads	8		

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE SAE AND ASTM SPECIFICATIONS. THE SAMPLES TESTED CONFORM TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED FREE OF MERCURY CONTAMINATION. THE STEEL WAS MELTED AND MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. WE CERTIFY THAT THIS DATA IS A TRUE REPRESENTATION OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND OUR TESTING LABORATORY. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



MECHANICAL FASTENER
CERTIFICATE NO. AZLA 100249

MUCOR FASTENER
A DIVISION OF MUCOR CORPORATION

Kevin Johnson
KEVIN JOHNSON
QUALITY ASSURANCE SUPERVISOR

NUCOR FASTENER

A Division of Nucor Corporation

Post Office Box 8100 - South Joe, Indiana 46785 - Telephone 219/337-1600

CUSTOMER NO/NAME 5616 ANCAN THREADED PRODUCTS
 TEST REPORT SERIAL# P8157818 NUCOR ORDER # 244607
 TEST REPORT ISSUE DATE 6/03/99 CUST PART #
 DATE SHIPPED 6/18/99 CUSTOMER P.O. # 2180
 NAME OF LAB SAMPLER: PHILLIP A. TITLER, LAB TECHNICIAN
 -----CERTIFIED MATERIAL TEST REPORT-----
 NUCOR PART NO QUANTITY LOT NO DESCRIPTION
 168660 4950 211600 5/8-10 X 2 A325 NYV HX
 MANUFACTURE DATE 6/25/99 STRUC SCRPH PLATH



---CHEMISTRY

MATERIAL NUMBER	HEAT NUMBER	CHEMISTRY COMPOSITION (WT% HEAT ANALYSIS) BY MATERIAL SUPPLIER				
RH017339	AR 118566	C	MN	P	S	SI
		.62	.95	.006	.012	.17
		MIN .30	.60			.15
		MAX .52		.040	.050	.30

SUPPLIER
 CO-STEEL RARITAN
 RARITAN RIVER STEEL
 P. O. BOX 17202
 NEWARK, NJ 07194
 AZLA NO: EXP:
 FOR CHEMICAL TESTING

---MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-97

SURFACE HARDNESS (R130N)	CORE HARDNESS (RC)	PROOF LOAD (LBS)	TENSILE STRENGTH (LBS)	DEC-WEDGE STRESS (PSI)
N/A	29.2	N/A	N/A	N/A
N/A	28.4	N/A	N/A	N/A
N/A	30.6	N/A	N/A	N/A
N/A	29.1	N/A	N/A	N/A
N/A	28.4	N/A	N/A	N/A
N/A	27.7	N/A	N/A	N/A
N/A	27.5	N/A	N/A	N/A
N/A	29.4	N/A	N/A	N/A
N/A	30.6	N/A	N/A	N/A
N/A	29.6	N/A	N/A	N/A
N/A	29.6	N/A	N/A	N/A
N/A	28.5	N/A	N/A	N/A
N/A	29.4	N/A	N/A	N/A
N/A	29.0	N/A	N/A	N/A

AVERAGE VALUES FROM TESTS: 29.0
 PRODUCTION LOT SIZE: 211600 PCS
 TOO SHORT TO TEST

---VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325
 HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F) 2015 PCS. SAMPLED LOT PASSED

---DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across	8	1.3980	1.4040
Grip Length	8	0.5280	0.5500
Head Height	8	0.6640	0.6740

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE SAE AND ASTM SPECIFICATIONS. THE SAMPLES TESTED CONFORM TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED FREE OF MERCURY CONTAMINATION. THE STEEL WAS MELTED AND MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. WE CERTIFY THAT THIS DATA IS A TRUE REPRESENTATION OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND OUR TESTING LABORATORY. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



MECHANICAL FASTENER
 CERTIFICATE NO. AZLA 100269

NUCOR FASTENER
 A DIVISION OF NUCOR CORPORATION

Kevin Johnson
 KEVIN JOHNSON
 QUALITY ASSURANCE SUPERVISOR

A Division of Ingersoll Corporation

Post Office Box 8100 - Saint Joe, Indiana 46785 - Telephone 219/337-1800

CUSTOMER NO/NAME: 8514 AMCAN THREADED PRODUCTS
 TEST REPORT SERIALS: P8182092
 TEST REPORT ISSUE DATE: 5/21/00
 DATE SHIPPED: 5/17/00
 NAME OF LAB SAMPLER: FRANKLIN A. NEAL, LAB TECHNICIAN
 MICRO ORDER #: 376051
 COST. PART #:
 CUSTOMER P.O. #: 3506
 CERTIFIED MATERIAL TEST REPORT
 MICRO PART NO: 188870
 QUANTITY: 6025
 LOT NO.: 120219X
 DESCRIPTION: 3/4-18 X 2 1/4 A325 HWY MX STRUC SCREEN PLAIN
 MANUFACTURE DATE: 3/15/00



---CHEMISTRY

MATERIAL NUMBER	HEAT NUMBER	CHEMISTRY COMPOSITION (WTK HEAT ANALYSIS) BY MATERIAL SUPPLIER					SUPPLIER
		C	MN	P	S	SI	
RW817467	RR 119494	.40	.92	.005	.007	.22	CO-STEEL USA DIST., INC. P. O. BOX 705 GREENUP, KY 41144 ASLA NO: EXP: FOR CHEMICAL TESTING
	MIN	.38	.88			.15	
	MAX	.52		.040	.050	.30	

---MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-97

SURFACE HARDNESS (RCPH)	CORE HARDNESS (RC)	PROOF LOAD 20400 LBS	TENSILE STRENGTH 6 DEQ-WEDOE (LBS)	STRESS (PSI)
N/A	29.1	PASS	47765	14312
N/A	30.6	PASS	47975	14240
AVERAGE VALUES FROM TESTS		PRODUCTION LOT SIZE	6693 PCS	142726
29.9		47671		

---VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325 115 PCS. SAMPLED LOT PASSED
 HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F)

---DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	#SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across	8	1.4020	1.4120
Grip Length	8	0.7770	0.8070
Head Height	8	0.4630	0.4740
Threads	8	PASS	PASS

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE SAE AND ASTM SPECIFICATIONS. THE SAMPLES TESTED CONFORM TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. THE DATA VALUES LISTED ARE A SUMMARY OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND DO NOT CONSTITUTE A TEST REPORT. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



INGERSOLL FASTENER
 CERTIFICATE NO. ASLA 119-01

TECHNICAL SERVICES MANAGER

NUCOR FASTENER

A Division of Nucor Corporation

Post Office Box 6100 • Safford, Indiana 46785 • Telephone 219/337-1600

CUSTOMER NO/NAME: 5514 ARCAN THREADED PRODUCTS
 TEST REPORT SERIAL#: FB134984 NUCOR ORDER # 344607
 TEST REPORT ISSUE DATE: 5/17/99 CUST PART #
 DATE SHIPPED: 8/16/99 CUSTOMER P.O. # 2180
 NAME OF LAB SAMPLER: MARK GRABER, LAB TECHNICIAN
 *****CERTIFIED MATERIAL TEST REPORT*****
 NUCOR PART NO: QUANTITY LOT NO. DESCRIPTION
 160580 4275 1104229A 7/4-10 X 2 1/2 A325 HVY HEX
 MANUFACTURE DATE: 5/12/99 STRUC SCREEN PLAIN



---CHEMISTRY

MATERIAL NUMBER	HEAT NUMBER	CHEMISTRY COMPOSITION (WTS HEAT ANALYSIS) BY MATERIAL					SUPPLIER
		C	MN	P	S	SI	
RND17372	RR 118547	.42	.90	.004	.014	.25	CO-STEEL RARITAN
		MIN .30	.60			.15	RARITAN RIVER STEEL
		MAX .52		.040	.050	.30	P. O. BOX 17202
							NEWARK, NJ 07194
							AZLA NO: EXP:
							FOR CHEMICAL TESTING

---MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-97

SURFACE HARDNESS (R50N)	CORE HARDNESS (RC)	PROOF LOAD 28400 LBS	TENSILE STRENGTH 10 DEG-WEDGE	
			(LBS)	STRESS (PSI)
N/A	29.8	PASS	46583	136476
N/A	31.3	PASS	46969	140626
N/A	31.1	PASS	46818	139276
N/A	29.9	PASS	46788	140078
N/A	30.4	PASS	47005	140734
N/A	30.8	PASS	46559	138799
N/A	29.7	PASS	46476	136151
N/A	29.9	PASS	46922	140486
N/A	30.4	PASS	48276	138957
N/A	30.5	PASS	46534	138725
N/A	30.4	PASS	46323	138692
N/A	28.4	PASS	46460	139102
N/A	29.6	PASS	46632	139632
AVERAGE VALUES FROM TESTS		PRODUCTION LOT SIZE	177000 PCS	
30.1		46357	138795	

---VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325 1700 PCS. SAMPLED LOT PASSED
 HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F)

---DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across	8	1.3980	1.4060
Grip Length	8	1.0240	1.0670
Head Height	8	0.4710	0.4760
Threads	8	PASS	PASS

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE SAE AND ASTM SPECIFICATIONS. THE SAMPLES TESTED CONFORM TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED FREE OF OBVIOUS CONTAMINATION. THE STEEL WAS MELTED AND MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. WE CERTIFY THAT THIS DATA IS A TRUE REPRESENTATION OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND OUR TESTING LABORATORY. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



NUCOR FASTENER
 A DIVISION OF NUCOR CORPORATION

Karen Johnson
 KAREN JOHNSON
 QUALITY ASSURANCE SUPERVISOR

MECHANICAL FASTENER
 CERTIFICATE NO. AZLA 100249

NUCOR FASTENER

A Division of Nucor Corporation

Post Office Box 2080 • Conway, Arkansas 72032

CUSTOMER NO/NAME 5616
 TEST REPORT SERIALS CB090168
 TEST REPORT ISSUE DATE 6/24/99
 DATE SHIPPED 8/18/99
 NAME OF LAB SAMPLER: ROBERT QUINT, LAB TECHNICIAN
 NUCOR PART NO QUANTITY LOT NO. DESCRIPTION
 160590 3400 51222CA 3/4-10 X 2 3/4 A325 HWY HX
 MANUFACTURE DATE 6/22/99 STRUC SCREEN PLAIN



---CHEMISTRY MATERIAL GRADE -1017HL
 MATERIAL NUMBER HEAT NUMBER
 CH0027X1 NU 70420X
 CHEMISTRY COMPOSITION (WT% HEAT ANALYSIS) BY MATERIAL SUPPLIER

	C	MN	P	S	SI
MIN	.37	.78	.009	.024	.24
MAX	.30	.60			.15

 NUCOR STEEL NEBRASKA A2LA NO: EXP:

---MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-97

SURFACE HARDNESS (HR15N)	CORE HARDNESS (RC)	PROOF LOAD 28400 LBS	TENSILE STRENGTH 10 DEG-WEDGE	
			(LBS)	STRESS (PSI)
N/A	28.4	PASS	49160	147186
N/A	29.4	PASS	46920	140479
N/A	28.8	PASS	49490	148174
AVERAGE VALUES FROM TESTS		PRODUCTION LOT SIZE	10700 PCS	
29.5		48523	145280	

---VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325 316 PCS. SAMPLED LOT PASSED
 HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F)

---DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across	8	1.4040	1.4080
Grip Length	8	1.2500	1.2800
Head Height	8	0.4780	0.4790
Threads	8	PASS	PASS

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE SAE AND ASTM SPECIFICATIONS. THE SAMPLE TESTED CONFORMS TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED FREE OF FERRITIC CONTAMINATION. THE STEEL WAS MILDLY AND MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. WE CERTIFY THAT THIS DATA IS A TRUE REPRESENTATION OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND OUR TESTING LABORATORY. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



NUCOR FASTENER
 A DIVISION OF NUCOR CORPORATION

Nicholas Tepovich

NICHOLAS TEPOVICH
 QUALITY ASSURANCE SUPERVISOR

MECHANICAL FASTENER
 CERTIFICATE NO. A2LA 100250



A Division of Nucor Corporation

Post Office Box 6100 • Saint Joe, Indiana 46785 • Telephone 219/337-1800

CUSTOMER NO./NAME: 6616 AMCAN THREADED PRODUCTS
 TEST REPORT SERIAL# PR181178
 TEST REPORT ISSUE DATE 5/15/00
 DATE SHIPPED 5/03/00
 NAME OF LAB SAMPLER: NIKKI SHULL, LAB TECHNICIAN
 MICOR PART NO QUANTITY LOT NO. DESCRIPTION
 18828 3950 I22048A 1/4-18 X 1/2 A325 HVY HK
 MANUFACTURE DATE 3/13/00 STRUC SCREW PLAIN



—CHEMISTRY

MATERIAL NUMBER	HEAT NUMBER	CHEMISTRY COMPOSITION (WT% HEAT ANALYSIS) BY MATERIAL SUPPLIER					SUPPLIER
		C	MN	P	S	SI	
RWB27667	RR 119496	.40	.92	.005	.007	.22	CO-STEEL USA DIST., INC. P. O. BOX 705 GREENUP, KY 41144 A2LA NO: EXP: FOR CHEMICAL TESTING
		MIN .30	.60			.15	
		MAX .62		.040	.050	.30	

—MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-97

SURFACE HARDNESS (RCDN)	CORE HARDNESS (RC)	PROOF LOAD 28400 LBS	TENSILE STRENGTH (LBS)	10 DEG-WEDGE STRESS (PSI)
N/A	27.9	PASS	48358	146784
N/A	28.7	PASS	48892	146881
N/A	27.8	PASS	49145	147141
AVERAGE VALUES FROM TESTS		PRODUCTION LOT SIZE	10000 PCS	
28.1		48798	146103	

—VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325 200 PCS. SAMPLED LOT PASSED
HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F)

—DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across	8	1.4020	1.4070
Grip Length	8	2.0010	2.0300
Head Height	8	0.4650	0.4680
Threads	8	PASS	PASS

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE SAE AND ASTM SPECIFICATIONS. THE SAMPLES TESTED CONFORM TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED FREE OF MERCURY CONTAMINATION. THE STEEL WAS MILLED AND MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. WE CERTIFY THAT THIS DATA IS A TRUE REPRESENTATION OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND OUR TESTING LABORATORY. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



MECHANICAL FASTENER CERTIFICATE NO. A2LA 139-01

MICOR FASTENER
A DIVISION OF NUCOR CORPORATION

JAMES B. GALANAS
TECHNICAL SERVICES MANAGER



A Division of Nucor Corporation

Post Office Box 8100 - Saint Joe, Indiana 46785 - Telephone 219/237-1600

CUSTOMER NO/NAME: 8614 AFGAN THREADED PRODUCTS
 TEST REPORT SERIALS: PR181175
 TEST REPORT ISSUE DATE: 5/21/00
 DATE SHIPPED: 5/23/00
 NAME OF LAB SAMPLER: FRANKLIN A. NEAL, LAB TECHNICIAN
 NUCOR ORDER #: 370107
 CUST PART #:
 CUSTOMER P.O. #: 3488
 NUCOR PART NO: 188618
 QUANTITY: 8625
 LOT NO.: 122046A
 DESCRIPTION: Y/4-10 X 3 1/4 A325 HVY HK
 MANUFACTURE DATE: 5/10/00
 STRUC SCREW PLAIN



—CHEMISTRY

MATERIAL NUMBER	HEAT NUMBER	CHEMISTRY COMPOSITION (WT% HEAT ANALYSIS) BY MATERIAL SUPPLIER					SUPPLIER
		C	MN	P	S	SI	
RH017951	RR 117209	.41	.91	.008	.008	.20	CO-STEEL USA DIST.. INC. P. O. BOX 706 GREENUP, KY 41144 AZLA NO: EXP: FOR CHEMICAL TESTING
		MIN .30	.60			.15	
		MAX .52		.040	.090	.30	

—MECHANICAL PROPERTIES IN ACCORDANCE WITH ASTM A325-97

SURFACE HARDNESS (R30H)	CORE HARDNESS (RC)	PROOF LOAD 28400 LBS	TENSILE STRENGTH 10 DEG-WEDGE (LBS)	STRESS (PSI)
N/A	27.1	PASS	47402	141922
N/A	27.3	PASS	47445	142051
N/A	27.0	PASS	47449	142063
AVERAGE VALUES FROM TESTS		PRODUCTION LOT SIZE	22000 PCS	
	27.1		47432	142012

—VISUAL INSPECTION IN ACCORDANCE WITH ASTM A325 315 PCS. SAMPLED LOT PASSED
 HEAT TREATMENT - AUSTENITIZED, OIL QUENCHED & TEMPERED (MIN 800 DEG F)

—DIMENSIONS PER ASME B18.2.6-1996

CHARACTERISTIC	#SAMPLES TESTED	MINIMUM	MAXIMUM
Width Across	8	1.4030	1.4110
Grip Length	8	1.7700	1.8200
Head Height	8	0.4610	0.4760
Threads	8	PASS	PASS

ALL TESTS ARE IN ACCORDANCE WITH THE LATEST REVISIONS OF THE METHODS PRESCRIBED IN THE APPLICABLE SAE AND ASTM SPECIFICATIONS. THE SAMPLES TESTED CONFORM TO THE SPECIFICATIONS AS DESCRIBED/LISTED ABOVE AND WERE MANUFACTURED FREE OF MERCURY CONTAMINATION. THE STEEL WAS MELTED AND MANUFACTURED IN THE U.S.A. AND THE PRODUCT WAS MANUFACTURED AND TESTED IN THE U.S.A. WE CERTIFY THAT THIS DATA IS A TRUE REPRESENTATION OF INFORMATION PROVIDED BY THE MATERIAL SUPPLIER AND OUR TESTING LABORATORY. THIS CERTIFIED MATERIAL TEST REPORT RELATES ONLY TO THE ITEMS LISTED ON THIS DOCUMENT AND MAY NOT BE REPRODUCED EXCEPT IN FULL.



NUCOR FASTENER
 A DIVISION OF NUCOR CORPORATION

James O. Neal
 JAMES O. NEAL
 TECHNICAL SERVICES MANAGER

MECHANICAL FASTENER
 CERTIFICATE NO. AZLA 139-01



CURTIS WALTER STEWART

A r c h i t e c t s

434 Cumberland Avenue
Portland ME 04101-2325

Benedict B. Walter, Vice President

Phone: 207.774.4441
Fax: 207.774.4016
E-mail: BWalter@CWSarch.com

November 19,2004

Mike Nugent
Inspection Services Manager
City of Portland
389 Congress Street
Portland, ME 04101

Re: FROZEN ROPES Addition to the Portland Sports Center/Joker's
510 Warren Avenue, Portland, Maine

Dear Mike,

Based on our conversation of 11/18/04, the above referenced addition is designed as an unlimited area Type III B, A-4 Assembly Use with a full automatic NFPA 13 sprinkler system. Attached is an updated Code Review based on IBC 2003 and a revised 2003 IBC Code Review sheet filled in with the architectural components updated by CWS Architects.

It is my understanding that, as a Type III building, interior building elements of any material permitted by the IBC Code are allowed in accordance with 2003 IBC 602.3 Type 111. Specifically, this will be the existing fully-sprinkled modular building serving as the entrance to the Portland Sports Center.

Please feel free to call if you have further questions.

very truly yours,

CURTIS WALTER STEWART ARCHITECTS

Benedict B. Walter, Architect
Vice President


cc: John DeStefano, DeStefano & Associates

attach: CWS Code Summary – Frozen Ropes November 19,2004
2003 IBC Code Review Sheet, updated for architectural components

NOV 19 2004

MECHANICAL PROJECT MANUAL

**FROZEN ROPES AT THE JOKERS
PORTLAND, MAINE**



871 A2

Prepared By:
Whitney Engineering, P.A.
10 Danforth Street
Portland, Maine 04101

Issued By:
Portland Air Conditioning, Inc.
P.O. Box 10300
Portland, Maine 04104

December 20,2004

SECTION 15100- MECHANICAL GENERAL REQUIREMENTS

PART 1 - GENERAL

1.1 DESCRIPTION OF WORK

A. Work Included

1. Furnish labor, materials, equipment, transportation and perform operations required to install heating and ventilating systems in the building, in accordance with these specifications and applicable drawings. Perform demolition and removal as required.
2. **Work** to be performed includes, but is not limited to the following:
 - a. Heating and ventilation (**H&V**) systems
 - b. Natural Gas fuel supply
 - c. Duct insulation
 - d. Fan and louver
 - e. Sheet Metal including registers and grilles
 - f. Temperature control, **air** testing and balance
3. Specifications and accompanying drawings do not indicate every detail of pipe, valves, **fittings**, hangers, duct work and equipment **necessary** for complete installation; but are provided to show general arrangement and extent of work to be performed.
4. Before submitting **proposal**, Contractor shall be familiar **with all** conditions. Failure to do so does not relieve Contractor of responsibility regarding satisfactory installation of the system.

B. Mechanical Electrical Work

1. All electric wiring for temperature control system shall be furnished and installed by Portland Air Conditioning Inc.
2. Fan EF-1

Fan **shall** be wired and provided with disconnect switch with overload protector and shall operate as described in Section 15772.
4. Remote Control Panel

Provide power and interlocking wiring for remote console provided by HV-I unit manufacturer.
5. HV-1

Wire unit through fused disconnect switch as recommended by unit manufacturer. Smoke detector is required for H&V unit.
6. Natural Gas Burner

Furnish circuit breaker for wiring to gas burner control panel by Gas Burner Installer.

1.2 PERMITS

Contractor shall apply for, obtain, and pay for all permits and inspections **required** by law and notify proper authorities in ample time for such inspections to be made.

1.3 MATERIALS

All materials and equipment **shall be** new and of the latest design **of** respective manufacturers. All materials and equipment **of** the same classification shall be same manufacturer, **unless** specified otherwise.

1.4 SHOP DRAWINGS

A. **As** soon as possible after award of Contract, before **any** material **or** equipment is purchased, Contractor shall provide **six (6)** copies **of** shop drawings to the engineer for review.

B. Review must be obtained on the **following** items:

1. H&V Equipment

- Registers
- Volume control dampers (manual and automatic)
- Duct sealant
- Sheet metal including louver and insulation
- Gas pipe and accessories
- Heating & ventilating unit and accessories
- Fan and accessories
- Temperature Controls

1.5 PRODUCT HANDLING

A. Protection

Use all means necessary **to** protect heating and ventilating materials before, during and after installation, and to protect the installed work and materials of all other trades.

1.6 MAINTENANCE MANUAL

A. Upon completion of H&V work provide two copies of a manual describing the system, emergency telephone number and where parts may **be** obtained.

1.7 GUARANTEE

Contractor shall guarantee all materials and workmanship **furnished** to be free from all defects for a **period** of one (1) year from date of final acceptance **of** completed system and shall make good, repair or replace any defective work which may develop within that time.

PART 2 - EXECUTION

2.1 SURFACE CONDITIONS

A. Inspection

1. **Prior to** all **work** of this Section, **carefully** inspect installed work of all ~~other~~ trades and verify that all work is complete ~~to the point where this~~ installation may properly commence.
2. **Verify** that **H&V** system may be installed in strict accordance with applicable codes and regulations.

B. Discrepancies

1. In ~~the~~ event of discrepancy, notify ~~Engineer~~ immediately.
2. Do not ~~proceed~~ with installation in areas of discrepancy until all such discrepancies have been fully resolved.

2.2 CLEANING

Prior to acceptance of **H&V** systems, clean casings of **H&V** equipment of foreign substance.

2.3 INSTRUCTIONS

On completion of project, provide ~~a~~ competent technician to instruct Owner's Representative in the care and operation of systems and equipment. Total ~~period~~ of instruction shall not exceed four **(4)** hours. The time of instruction shall be arranged with the Owner.

2.5 EQUIPMENT IDENTIFICATION

- A. Identify **gas** piping with Seton mark pipe ~~markers~~ by Seton Name Plate Corporation. Marker shall snap completely around pipe and be visible ~~from~~ all directions. Marker shall include both identification and direction of flow.

END OF SECTION 15100

..

SECTION 15250 MECHANICAL INSULATION AND CONDENSATE PROTECTION

PART 1 - GENERAL

1.1 DESCRIPTION OF WORK

General

Insulate ducts as specified in this Section or indicated on the drawings.

1.2 QUALITY OF COMPLIANCE

A. Fire and Smoke Ratings: For all insulation systems.

Provide composite mechanical insulation (insulation, jackets, coverings, sealers, mastics and adhesives) with flame spread index of 25 or less, smoke developed index of 50 or less, as tested by ASTM E 84 (NFPA 255) method.

Exception: Insulation installed on services located outdoors may have flame spread index of 75 and smoke developed index of 150.

PART 2 - PRODUCTS

2.1 DUCTWORK

Fiber glass duct wrap with factory supplied, non-combustible, vapor barrier facing Thermal conductivity shall not be greater than 0.28 BTU/hour - square feet - F/inch. Duct wrap shall have UL label. All laps to be sealed and held in place with adhesive and flare staples. All lap joints to be folded under before stapling so no raw insulation will be showing. On bottom of ducts 24" or wider, mechanical fasteners shall be provided approximately 12" on centers.

2.2 MISCELLANEOUS MATERIALS

- A. Staples, Bands, Wires and Cement: As recommended by insulation manufacturer for applications indicated.
- B. Adhesives, Sealers, and Protective Finishes: As recommended by insulation manufacturer for applications indicated.

PART 3 - EXECUTION

3.1 HVAC DUCT SYSTEMS INSULATION

- B. Insulate supply duct and duct stub at louver 1-1 with 1-1/2" thick duct wrap:

3.2 INSTALLATION

- B. Examine areas and conditions under which mechanical insulation will be installed. Do not proceed with work until unsatisfactory conditions have been corrected.

Frozen Ropes at the Jokers Portland, Maine

12/04

- C. Install insulation products in accordance with manufacturer's written instructions, and in accordance with **recognized** industry practices to **ensure** that insulation serves its intended purpose.
- D. Install insulation **on** mechanical **systems** subsequent to testing and acceptance of tests.
- E. Install insulation materials with smooth and even **surfaces**. Do not use pieces or scraps abutting each other.
- F. Clean and **dry** mechanical **surfaces** prior to insulating. Butt insulation joints firmly together to **ensure** complete and tight fit over surfaces **to be** covered.
- G. Maintain integrity of vapor-barrier jackets on mechanical insulation, and protect to prevent puncture or other damage.
- G. Extend **mechanical** insulation without interruption through walls, floors, **and** similar piping **penetrations**, except where otherwise indicated.

END OF SECTION 15250

SECTION 15488 - NATURAL GAS

PART 1 - GENERAL

1.1 Provide piping materials **and** factory **fabricated** piping products of **sues, types**, pressure **ratings**, and capacities needed **to** install a new gas **service to rooftop** unit HV-I. Provide materials and products complying **with** NFPA **54** where applicable. **Base** pressure rating on natural **gas system** maximum design pressures. Provide **sizes and types** matching piping and equipment **connections**; provide **fittings** of materials which match pipe materials used in **natural gas systems**. Where more **than** one **type** of materials or products are indicated selection is Installer's option.

1.2 QUALITY COMPLIANCE

ANSI Compliance: Comply with applicable provisions of ANSI **B31.2**.

NFPA Compliance: Comply with applicable provisions of NFPA 54, 1999 Edition

Utility Compliance: Comply with requirements of Northern Utilities, Inc.

State of Maine Compliance: Propane and Natural Gas Board Laws and Rules, 1998 Edition.

PART 2 - PRODUCTS

2.1 GAS SERVICE PIPING

- A. All Pipe Sizes: Black steel pipe; Schedule 40; wrought-steel butt welding fittings.
- B. Wrapping: Machine wrap pipe **using** 50% overlap wrap, **with** polyvinyl chloride tape. Hand wrap fittings using 100% overlap **wrap** extending **6"** beyond fitting onto wrapped pipe.

2.2 BUILDING DISTRIBUTION PIPING

- A. Pipe Size 2" **and** Smaller: Black steel pipe; Schedule 40; malleable-iron threaded fittings.
- B. Pipe Size 2-1/2" and Larger: Black steel pipe; Schedule 40; wrought-steel butt welding fittings.

2.01 PIPING SPECIALTIES

- A. Escutcheon Plates: Install on each pipe penetration exposed to view in occupied spaces.
- B. Sheet-Metal Pipe Sleeves: Install on each pipe penetration through interior partitions and ceilings.
- C. Cast-Iron Pipe Sleeves: Install on each pipe penetration through exterior walls or footings, both above and below grade.
- D. Steel Pipe Sleeves: Install on each pipe penetration except as otherwise indicated.
- E. Sleeve Seals: Install in sleeves in foundation walls below grade and in exterior walls; either caulked lead and oakum or modular mechanical rubber link seals.

2.4 SUPPORTS AND ANCHORS

- A. General: Provide factory fabricated supports and anchors complying with MSS SP-69. Install, complying with MSS SP-89.
- B. Gas Cocks:
 - 1. Gas service valves 2-1/2" and larger shall **be** lubricated plug type ~~with~~ iron bodies, lubricated iron plug, flanged ends and wrench operated and rated for 175# WOG. (Provide one (1) valve wrench **for** each size valve and turn over wrenches to Owner's Representative)
 - 2. Gas service valves 2" and smaller shall be **butterfly type** ~~with~~ bronze body, stainless steel stem and disc with Viton seal, **AGA** approved and UL Listed. Supply with "T" or lever handle as approved by local **gas** supplier.
- C. Install at connection to gas train for each gas-fired equipment item; on branches and **risers** as indicated.

PART 3 - EXECUTION

3.1 GENERAL

- A. No person other than an authorized employee of Northern Utilities, Inc., shall repair, alter, or make connections to a gas pipe upstream of the meter or restore gas service to the premises.
- B. Gas meters **should** be ~~installed~~ within five feet (5') of the service entrance to a building and at least **three** feet (3') distance ~~from~~ any electrical, switching gear, **transformers** or outlets.
- C. ~~The~~ Installer is responsible for his own work, including proper sizing, proper materials, supports and testing.
- D. Submit Certificate/Form to Northern Utilities, Inc. to activate gas **service**.

3.2 GAS SERVICE

- A. General: Arrange with Northern Utilities, Inc., to provide gas service to indicated location ~~with~~ shutoff at terminus. Consult with Utility as to extent of it's work, costs, fees and permits involved. Pay such costs and fees; obtain **permits**.
- B. Extend service pipe ~~from~~ Northern Utilities, Inc., **terminus to roof** building wall under Utilities' direction.
- C. Mechanical Contractor shall provide shutoff outside building downstream of gas meter. Gas service valve box ~~with~~ cover on upstream side of meter shall be by Northern Utilities.

3.3 EQUIPMENT CONNECTIONS

- A. General: Connect gas piping to rooftop unit HV-1 with drip leg and shutoff gas cock. Comply ~~with~~ equipment manufacturer's instructions.
- B. Provide shutoff in gas service **pipe** at entry to building. Extend pipe to gas meter location indicated. Provide parts and accessories required by Utility to **connect** meter.

3.4 PIPING TESTS

- A. Test natural **gas** piping in accordance with NFPA 54 and Northern Utilities, Inc.

3.5 PIPING INSTALLATION

1. Install natural gas piping in accordance ~~with~~ applicable codes and Northern Utilities, Inc., requirements.
2. Use sealants on metal gas piping threads which are chemically resistant to natural gas. Use sealants sparingly, and apply to only male threads of metal joints. **Pipe** joint compound shall be used on **all** threaded joints.
3. Remove cutting and threading burrs before assembling piping.
4. Do not install defective piping or fittings. Do not use pipe with threads which are chipped, stripped or damaged.
5. Plug each gas outlet, including valves with threaded plug or cap immediately after installation and retain until continuing piping or equipment connections are completed.
6. Ground gas piping electrically **and** continuously within project, and bond tightly to grounding connection.
7. Install drip-legs in gas piping at each riser at point where it is joined to horizontal run of pipe and where required by code or regulation.
8. Install "Tee" fitting with bottom outlet plugged or capped at bottom of pipe risers.
9. Use dielectric unions where dissimilar metals are joined together.
10. Install piping with 1/64" per foot (1/8%) downward slope in direction of flow.
11. Install piping parallel to other piping, but maintain **minimum** of 12" clearance between gas piping and steam or hot water piping above **180°F.** (93°C); between any gas piping and any other hot surface such **as** breaching.
12. No supply run to be smaller than 3/4" ID.
13. All material to be new and **unused** when piping is to be concealed.
14. Metallic pipe and fitting threads shall be taper threads and shall comply with the standard for pipe threads. General purpose (inch) ANSI/ASME B 1.20.1.
15. When installing gas piping which is to be concealed, the following shall not be used: Unions, tubing, fittings, threads, right and left couplings, bushings and swing joints made by combinations of fittings. Only elbows, tees and screw couplings are approved for use in concealed piping.
16. Piping passing through concrete, brick, concrete block, walls or floor is to be sleeved or protected from corrosion.
17. Piping in floors is to be protected from corrosion.
18. Piping underground, beneath buildings is prohibited.
19. Piping is not to be embedded in concrete floor.
20. Drop pieces are to **be** run full size to the appliance. **Any** reduction in the pipe size is to be done as close to the appliance as possible.
21. Prohibited **Locations:** Gas piping inside a building **shall** not be run in or through a circulating air duct, clothes chute, chimney or gas vent, ventilating duct, dumb waiter, elevator shafts or underneath buildings.
22. When any other fuel gas **is** to be interconnected with the natural gas system, Northern Utilities, Inc., should be contacted to advise the proper method.
23. Prohibited Concealed Piping:
 - a. Concealed gas piping shall not be located in solid partitions (concrete or cinder block). Tubing shall not be run in hollow walls **or** partitions unless protected against physical damage.
 - b. Concealed gas piping shall not be run horizontally through hollow walls or partitions.
 - c. Valves, cocks or any shutoff devices shall not be installed in concealed gas piping.

3.6 APPLIANCE INSTALLATION

- A. All appliances will **be installed in accordance** with manufacturer's recommendations. The recommendations will appear on name plate or on separate instructions which accompany the appliance. This information will list *minimum* clearance to combustible material and other information required for proper installation.
- B. A separate shutoff will be installed in an accessible location at each appliance.

3.7 TESTING

- A. Every new or enlarged **system** of gas piping must be tested **and** the proper completed form submitted to Northern Utilities, **Inc.** before gas will be turned on.
- B. Testing for Tightness: (**NFPA 54**, Page 33 - 4.1.2 (A.) OXYGEN SHALL NOT BE USED AS A TESTING **MEDIUM**. Note: **A** proper test cannot be made with appliances connected. This could also result in expensive damage **to** the controls on the appliance. Gas meter must also be isolated **from** section being tested, **as** pressure back against meter will cause extensive internal damage.
- C. Test Pressure: **Minimum** test pressure for low pressure delivery in concealed gas piping systems (below 1/4 psi) shall be no less than 25 psig for a time **period** of one hour. Minimum test pressure for high pressure delivery systems (above 1/4 psi) shall be no less than 65 psig for one hour for piping under 2". 100 psi for piping above 2" or where pipe is welded. During pressure test, all joints shall be tested with a soap and water solution. **Any** leaks found will be **repaired** and system again tested.
- D. After successful pressure test, piping shall be connected to meter and the appliance connected to piping **system**.
- E. All outlets including **those** with shutoff valve, shall be closed gas-tight **with** plug or cap if threaded. **Any** pipe left temporarily shall be plugged or capped gas-tight. If flanged, a blind flange and proper gasket shall be installed.

3.8 NOTICE

Northern Utilities, Inc., responsibility for gas piping in any installation is limited to pipe and fittings which comprise service entering installation up to and including outlet **connections** of the meter or meter bar. All meters shall be installed **within** five feet of service entrance. Where special requirements prohibit installation of meters **within** five feet (5') of service entrance, Northern Utilities, Inc., shall be contacted to obtain authorization to proceed with **an** alternate meter piping configuration **under** requirements specified by the Company.

END OF SECTION 15488

SECTION 15772- HEATING AND VENTILATING EQUIPMENT

PART 1 - GENERAL

1.1 SCOPE

Provide rooftop heating and ventilating unit, exhaust fan, louver and temperature controls.

PART 2 - PRODUCTS

2.1 HV- 1 ROOFTOP UNIT

Power vented, natural gas **fired** forced **air** furnace designed for outdoor installation. Unit shall spark ignited intermittent pilot, two stage 24 volt **gas** valve, limit **and** safety controls, venter pressure switch to verify power vent flow before allowing operation of **the** gas valve. Unit shall have weatherized galvalume steel cabinet with interlocking joint construction. Provide **plenum** for downturn of **air** flow. Unit shall have aluminized steel heat exchanger, **24** volt control transformer, motor contactor, terminal block, filter rack with 2" throwaway **filters**, full curb cap base and adjustable belt drive. Provide 30% outside air inlet with hood and manual outside air dampers. Provide thermostat with two stage control (100% and 50%) and remote console with lights indicating blower **is** operating. Unit shall be Reznor Model RPB 250.

2.2 EXHAUST FANS

American Coolair Type CBHX AMCA Certified propeller exhaust fans as manufactured by American Coolair **Corporation**. Provide welded steel panel and structural angle supports, die formed steel blades firmly attached to **aluminum** hub, **oversized** sealed ball bearings, belt drive **motor**, automatic (gravity) shutter and metal housing with mounting flanges and motor side guard.

2.3 LOUVER L-1

NCA Manufacturing, Inc. Model WDR-6 Wind Driven Rain Resistant sightproof extruded Stationary Louver. Louver shall be **AMCA** Licensed for Wind Driven Rain at 29.1 MPH. Frames shall be 0.081 inches **thick** and blades 0.090 inches thick extruded **aluminum** alloy. Provide **screen** removable **for cleaning**. Provide motor operated damper **with** Siemens **OpenAir** CGD Electronic Damper Operator.

2.4 AUTOMATIC TEMPERATURE CONTROL

A. Overview:

During cold weather, space heating and occupant ventilation shall be provided by heating & ventilating unit HV- 1 with exhaust fan **EF-1** OFF and outside **air** louver L- 1 damper closed. **EF-1** and intake damper ventilation system does not have any heating capability and should not be used during cold weather.

During warmer weather, HV- 1 shall be OFF and EF- 1 shall be ON with outside **air** louver L- 1 damper OPEN. Operation of **EF- 1** and interlocked damper operator shall be at the option of the Owner.

B. Heating and Ventilating Unit HV-1:

OCCUPIED:

Two stage thermostat shall monitor space temperature against set point (70F adjustable) and cycle HV 1 rooftop gas burner staged at 100%, 50% or OFF to meet thermostat setpoint. During Occupied periods, 30% outside air damper shall open and fan shall run continuously.

UNOCCUPIED:

Thermostat set point shall be reset to 55F (adjustable) and HV-1 shall cycle fan intermittently on call for heat and turn gas burner ON to maintain room temperature. In addition, 30% outside air damper shall be closed.

A remote console shall indicate when gas burner is operating or OFF

C. Exhaust Fan EF-1

1. EF-1: Batting area exhaust fan shall be controlled from a wall mounted manual switch. When manual switch is toggled ON, motor operated damper at intake and gravity shutter at exhaust fan shall move to open position and fan shall start upon proof intake motor operated damper is open. Toggling, manual switch OFF, fan motor shall stop and both dampers shall close.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. *General:* Install split system indoor and outdoor units in accordance with manufacturer's installation instructions. Install unit plumb and level, firmly anchored in location indicated, and maintain manufacturer's recommended clearances.
- B. *Support:* Install outdoor unit on reinforced concrete pads and suspend indoor unit from steel angles, rods and isolators.
- C. *Electrical Wiring:* Install electrical devices furnished by manufacturer, but not specified to be factory-mounted. Furnish copy of manufacturer's wiring diagram submittal to Electrical Installer. Do not proceed with equipment start-up until wiring installation is acceptable to Equipment Installer.
- D. *Ductwork:* Refer to Section 15841, "Low Pressure Ductwork and Accessories". Connect supply and return ducts to unit with flexible duct connections. Provide transitions to exactly match unit duct connection sizes.
- E. *Start-up HVAC equipment* in accordance with manufacturer's start-up instructions. Test controls and demonstrate compliance with requirements. Replace damaged or malfunctioning controls and equipment.

END OF SECTION 15772

SECTION 15841 LOW PRESSURE DUCTWORK AND ACCESSORIES

PART 1 - GENERAL

1.1 DESCRIPTION OF WORK

A. Extent of **low** pressure ductwork is **indicated** on drawing and in schedules. **Low** pressure ductwork is defined as ductwork subjected to **velocities** of 2500 fpm or less, and **operating** pressure of **2"** WG. **or** less, positive **or** negative.

B. Types of low pressure ductwork required for **project** include the following:

- Heating supply and return air systems
- Exhaust systems
- Test and **Air** balancing

i.2 QUALITY COMPLIANCE

A. SMACNA Standards: Comply ~~with~~ SMACNA "HVAC DUCT Construction Standards Metal and Flexible"; 1st Edition **1993**.

B. ASHRAE Standards: Comply ~~with~~ ASHRAE Handbook and Product Directory, 2001 Equipment Volume, Chapter 1 "Duct Construction", for fabrication and installation of low pressure ductwork.

C. NFPA Compliance: Comply with the following **as** applicable:

1. Standard HVAC supply, return, relief, ~~transfer~~ and exhaust ducts not itemized below: **NFPA 90A "Standard for the Installation of Air Conditioning and Ventilating System"**, 2002 Edition.
2. Dust, Stock and Vapor Exhaust: NFPA 91-2004 "Standard for the Installation of Blower and Exhaust Systems for Dust, Stock and Vapor Removal or Conveying".

D. Dimensions

The size of ducts marked on the drawings will be adhered to **as** closely **as** possible. The right is reserved to vary duct sizes to accommodate structural conditions during progress of work with-out additional cost to Owners. Duct layout is schematic to indicate size and general arrangement only. All ducts shall be arranged to adjust to "field conditions". Sheet Metal Contractor shall coordinate work with Electrical Contractor and other trades.

PART 2 - PRODUCTS

2.1 DUCTS AND AIR TERMINAL DEVICES:

A. Ducts shall be constructed of galvanized steel in accordance with the following table of duct sizes and latest ASHRAE Guide and Data Book unless otherwise shown on drawings.

Dimensions of Longest Side (inches)

<u>Standard Ducts</u>	<u>Sheet Metal Gauge</u>
UP thru 12	26
13-39	24
31 -54	22

B. Dampers and Splitters

All dampers and deflectors shall be a **minimum** of #22 gauge and stiffened **as** required. Splitter dampers shall not be used.

C. Flexible Connectors

Furnish and install flexible connections on HV-1 unit. Connections shall be made from Ventglas neoprene coated glass fabric **as** manufactured by Ventfabrics, Inc.

D. Diffusers, Registers and Grilles

s

1. Registers shall be **installed at air** supply and **return openings** as shown. Units shall be provided with white finish and **countersunk screw** holes. Devices shall be Titus.
2. Supply Air Registers: Steel, double deflection AeroBlade Model 272RL with front blades parallel to longest dimension, 3/4" blade spacing, individually adjustable blades, steel border with **extruded** aluminum blades, opposed blade damper and for surface mounting
3. Return Air Registers: Steel Model 350RL, 3/4" blade spacing, 0 degrees deflection, opposed blade dampers and for surface mounting.

E. Duct Sleeve

Provide aluminum duct sleeve through outside wall at intake louver and exhaust fan

F. Sealant

Seal ducts with water based, non-combustible sealant equal to multipurpose sealant by Transcontinental Limited.

G. Duct Lining

No duct liner **is** required

PART 3 - EXECUTION

3.1 GENERAL

Assemble and install ductwork in accordance with recognized industry practices to achieve air tight (5% leakage) and noiseless (no objectionable noise) systems, and capable of performing each indicated service. Install each run with **minimum** of joints. Align ductwork accurately at connections, within 1/8" misalignment tolerance and with **internal** surfaces smooth. Support ducts **rigidly** with suitable ties, braces, hangers and anchors of type **which** will hold ducts true-to-shape and to prevent buckling.

3.2 SEALING DUCT

- A. After installation to **seal** class recommended in SMACNA "HVAC Duct Standards - 1st Edition 1985". Use sealant described in Paragraph 2.1 (F) of **this** section. All joints in sheet metal ducts shall be made airtight, and all branches and turns shall be made with long radius elbows and fittings. If long radius elbows are not used, elbows shall be provided with fixed double wall turning vanes designed to reduce resistance of the elbow to equivalent of a long radius elbow with throat radius not **less** than duct width.