



. . . Fire Protection by Computer Design

Sprinkler Systems Inc.
2-4 Avon Street
P O Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : JOKER'S ADDITION
Building : 2012 ADDITION
Location : 510-512 WARREN AVENUE, PORTLAND, MAINE 04103
System : 3 OF 3
Contract : 12066
Data File : 12066JOKERSADDNPTLD1.WXF

Hydraulic Design Information Sheet

Name - JOKER'S ADDITION Date - 9-19-2012
 Location - 510-512 WARREN AVENUE, PORTLAND, MAINE 04103
 Building - 2012 ADDITION System No. - 3 OF 3
 Contractor - OWNER Contract No. - 12066
 Calculated By - SCOTT E. GARLAND Drawing No. - 1 OF 1
 Construction: () Combustible (X) Non-Combustible Ceiling Height - VARIES
 Occupancy - INDOOR SPORTS CENTER - LIGHT HAZARD

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - 1950 SF System Type Sprinkler/Nozzle
 Density - .10 () Wet Make RELIABLE
 D Area Per Sprinkler - 166.7 (X) Dry Model F1FR56
 E Elevation at Highest Outlet - 138.5 () Deluge Size 1/2 X 1/2
 S Hose Allowance - Inside - () Preaction K-Factor 5.6
 I Rack Sprinkler Allowance - () Other Temp.Rat.155 DEG
 G Hose Allowance - Outside - 100

N Note DESIGN AREA #1 - ROOF

Calculation Flow Required - 226.022 Press Required - 67.742 AT BASE OF RISER
 Summary C-Factor Used: 100 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 5-13-2009 Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 82 @ Press -
 R Residual Press - 81 Elev. - Well
 Flow - 1352 Proof Flow
 S Elevation - 100.0

U
 P Location - ON WARREN AVENUE IN FRONT OF BUILDING

P
 L Source of Information - PORTLAND WATER DISTRICT

Y

C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf
 O C

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:

Fittings Used Summary

Sprinkler Systems Inc.
JOKER'S ADDITION

Page 3
Date 9-19-2012

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|----------------------------|--|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|-----|
| E | NFPA 13 90' Standard Elbow | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| F | NFPA 13 45' Elbow | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 3 | 3 | 4 | 5 | 7 | 9 | 11 | 13 | 17 | 19 | 21 | 24 | 28 |
| G | NFPA 13 Gate Valve | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| T | NFPA 13 90' Flow thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zac | Ames 2000SS | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Sprinkler Systems Inc.
 JOKER'S ADDITION

Page 4
 Date 9-19-2012

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|-------|------------|
| 1 | 138.5 | 5.6 | 8.86 | na | 16.67 | 0.1 | 166.7 | 8.862 |
| 2 | 137.375 | 5.6 | 9.72 | na | 17.46 | 0.1 | 166.7 | 8.862 |
| 3 | 136.25 | 5.6 | 11.59 | na | 19.07 | 0.1 | 166.7 | 8.862 |
| 4 | 135.125 | 5.6 | 15.23 | na | 21.86 | 0.1 | 166.7 | 8.862 |
| AT | 133.917 | | 23.39 | na | | | | |
| 5 | 138.5 | 5.6 | 8.9 | na | 16.71 | 0.1 | 166.7 | 8.862 |
| 6 | 137.375 | 5.6 | 9.76 | na | 17.49 | 0.1 | 166.7 | 8.862 |
| 7 | 136.25 | 5.6 | 11.64 | na | 19.11 | 0.1 | 166.7 | 8.862 |
| 8 | 135.125 | 5.6 | 15.29 | na | 21.9 | 0.1 | 166.7 | 8.862 |
| BT | 133.917 | | 23.48 | na | | | | |
| 9 | 138.5 | 5.6 | 9.05 | na | 16.84 | 0.1 | 166.7 | 8.862 |
| 10 | 137.375 | 5.6 | 9.91 | na | 17.63 | 0.1 | 166.7 | 8.862 |
| 11 | 136.25 | 5.6 | 11.81 | na | 19.24 | 0.1 | 166.7 | 8.862 |
| 12 | 135.125 | 5.6 | 15.51 | na | 22.05 | 0.1 | 166.7 | 8.862 |
| CT | 133.917 | | 23.8 | na | | | | |
| A | 129.417 | | 29.68 | na | | | | |
| B | 129.375 | | 29.81 | na | | | | |
| C | 129.333 | | 30.2 | na | | | | |
| D | 129.292 | | 31.03 | na | | | | |
| E | 129.125 | | 38.38 | na | | | | |
| F | 128.875 | | 46.36 | na | | | | |
| TDV | 112.917 | | 58.83 | na | | | | |
| G | 107.5 | | 61.97 | na | | | | |
| BASE | 101.0 | | 67.74 | na | | | | |
| 1000 | 100.0 | | 68.86 | na | 100.0 | | | |
| TEST | 100.0 | | 69.2 | na | | | | |

The maximum velocity is 14.89 and it occurs in the pipe between nodes 12 and CT

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
 JOKER'S ADDITION

Page 5
 Date 9-19-2012

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftg's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|----------|-------------------|-----------------|-------|------------------|-------------|-------------|-------|-----------------|------------------|
| 1 | 16.67 | 1.442 | | 0.0 | 13.333 | 8.862 | | | | |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | K Factor = 5.60 | |
| 2 | 16.67 | 0.0277 | | 0.0 | 13.333 | 0.369 | | | | Vel = 3.27 |
| 2 | 17.46 | 1.442 | | 0.0 | 13.333 | 9.718 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 3 | 34.13 | 0.1040 | | 0.0 | 13.333 | 1.387 | | | | Vel = 6.70 |
| 3 | 19.06 | 1.442 | | 0.0 | 13.333 | 11.592 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 4 | 53.19 | 0.2366 | | 0.0 | 13.333 | 3.154 | | | | Vel = 10.45 |
| 4 | 21.86 | 1.442 | 1E | 2.652 | 14.417 | 15.233 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 2.652 | 0.523 | | | | |
| AT | 75.05 | 0.4471 | | 0.0 | 17.069 | 7.631 | | | | Vel = 14.74 |
| AT | 0.0 | 1.442 | 1T | 5.304 | 4.417 | 23.387 | | | | |
| to | | 100.0 | | 0.0 | 5.304 | 1.949 | | | | |
| A | 75.05 | 0.4471 | | 0.0 | 9.721 | 4.346 | | | | Vel = 14.74 |
| | 0.0 | | | | | | | | | |
| | 75.05 | | | | | 29.682 | | | | K Factor = 13.78 |
| 5 | 16.71 | 1.442 | | 0.0 | 13.333 | 8.902 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 6 | 16.71 | 0.0278 | | 0.0 | 13.333 | 0.370 | | | | Vel = 3.28 |
| 6 | 17.49 | 1.442 | | 0.0 | 13.333 | 9.759 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 7 | 34.2 | 0.1045 | | 0.0 | 13.333 | 1.393 | | | | Vel = 6.72 |
| 7 | 19.11 | 1.442 | | 0.0 | 13.333 | 11.639 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 8 | 53.31 | 0.2375 | | 0.0 | 13.333 | 3.166 | | | | Vel = 10.47 |
| 8 | 21.90 | 1.442 | 1E | 2.652 | 14.417 | 15.292 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 2.652 | 0.523 | | | | |
| BT | 75.21 | 0.4488 | | 0.0 | 17.069 | 7.661 | | | | Vel = 14.78 |
| BT | 0.0 | 1.442 | 1T | 5.304 | 4.417 | 23.476 | | | | |
| to | | 100.0 | | 0.0 | 5.304 | 1.967 | | | | |
| B | 75.21 | 0.4488 | | 0.0 | 9.721 | 4.363 | | | | Vel = 14.78 |
| | 0.0 | | | | | | | | | |
| | 75.21 | | | | | 29.806 | | | | K Factor = 13.78 |
| 9 | 16.84 | 1.442 | | 0.0 | 13.333 | 9.045 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 10 | 16.84 | 0.0282 | | 0.0 | 13.333 | 0.376 | | | | Vel = 3.31 |
| 10 | 17.63 | 1.442 | | 0.0 | 13.333 | 9.908 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 11 | 34.47 | 0.1061 | | 0.0 | 13.333 | 1.414 | | | | Vel = 6.77 |
| 11 | 19.24 | 1.442 | | 0.0 | 13.333 | 11.809 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 0.0 | 0.487 | | | | |
| 12 | 53.71 | 0.2408 | | 0.0 | 13.333 | 3.210 | | | | Vel = 10.55 |
| 12 | 22.06 | 1.442 | 1E | 2.652 | 14.417 | 15.506 | | | | K Factor = 5.60 |
| to | | 100.0 | | 0.0 | 2.652 | 0.523 | | | | |
| CT | 75.77 | 0.4550 | | 0.0 | 17.069 | 7.767 | | | | Vel = 14.89 |
| CT | 0.0 | 1.442 | 1T | 5.304 | 4.417 | 23.796 | | | | |
| to | | 100.0 | | 0.0 | 5.304 | 1.985 | | | | |
| C | 75.77 | 0.4550 | | 0.0 | 9.721 | 4.423 | | | | Vel = 14.89 |

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
 JOKER'S ADDITION

Page 6
 Date 9-19-2012

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftn'g's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|---------------|-------------------|---------------------|--------------------|-------------|-------------|-------|------------------------------------|-------|
| | 0.0 75.77 | | | | | 30.204 | | K Factor = 13.79 | |
| A to B | 75.05 | 3.26 100.0 | 0.0 | 12.500 | 29.682 | 0.018 | | | |
| B to C | 75.05 | 0.0085 | 0.0 | 12.500 | 0.106 | | | Vel = 2.88 | |
| B to C | 75.21 | 3.26 100.0 | 0.0 | 12.500 | 29.806 | 0.018 | | | |
| C to D | 150.26 | 0.0304 | 0.0 | 12.500 | 0.380 | | | Vel = 5.78 | |
| C to D | 75.76 | 3.26 100.0 | 0.0 | 12.500 | 30.204 | 0.018 | | | |
| D to E | 226.02 | 0.0646 | 0.0 | 12.500 | 0.808 | | | Vel = 8.69 | |
| D to E | 0.0 | 3.26 100.0 | 1E | 6.714 | 105.750 | 31.030 | | | |
| E to F | 226.02 | 0.0647 | 0.0 | 112.464 | 0.072 | 7.278 | | Vel = 8.69 | |
| E to F | 0.0 | 3.26 100.0 | 1T | 14.388 | 107.333 | 38.380 | | | |
| F to TDV | 226.02 | 0.0647 | 0.0 | 121.720 | 0.108 | 7.876 | | Vel = 8.69 | |
| F to TDV | 0.0 | 4.26 100.0 | 7E | 65.781 | 250.333 | 46.364 | | | |
| TDV to G | 226.02 | 0.0176 | 0.0 | 316.114 | 6.911 | 5.559 | | Vel = 5.09 | |
| TDV to G | 0.0 | 4.26 100.0 | 3E | 28.192 | 16.583 | 58.834 | | | |
| G to BASE | 226.02 | 0.0176 | 0.0 | 44.775 | 2.346 | 0.787 | | Vel = 5.09 | |
| G to BASE | 0.0 | 6.357 120.0 | 1Zac | 0.0 | 6.500 | 61.967 | | | |
| BASE to 1000 | 226.02 | 0.0018 | 0.0 | 6.500 | 5.763 | 0.012 | | * Fixed loss = 2.948 Vel = 2.28 | |
| BASE to 1000 | 0.0 | 6.16 140.0 | 1E | 20.084 | 360.000 | 67.742 | | | |
| 1000 to TEST | 226.02 | 0.0016 | 1F | 10.042 | 77.467 | 0.433 | | Vel = 2.43 | |
| 1000 to TEST | 100.00 | 8.27 140.0 | 1E | 28.468 | 380.000 | 68.860 | | Qa = 100 | |
| TEST | 326.02 | 0.0007 | 1T | 55.354 | 83.822 | 0.0 | | Vel = 1.95 | |
| | 0.0 326.02 | | | | | 69.201 | | K Factor = 39.19 | |

Water Supply Curve (C)

Sprinkler Systems Inc.
JOKER'S ADDITION

Page 7
Date 9-19-2012

City Water Supply:
C1 - Static Pressure : 82
C2 - Residual Pressure: 81
C2 - Residual Flow : 1352

Demand:
D1 - Elevation : 16.674
D2 - System Flow : 226.022
D2 - System Pressure : 69.201
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 326.022
Safety Margin : 12.727

