


| Exit Capacities                                      | Required | Provided |
|--|----------|----------|
| Total Exit Capacity                                  | 1664     | 2490     |
| "Main Entrance" Exit Capacity (Turf & The Gold Room) | 428      | 490      |
| "Main Entrance" Exit Capacity (Gym Area)             | 381      | 680      |

| Travel Distances      | Permitted (Max)                                     | Actual (Max) |
|-----------------------|---|--------------|
| Exit Travel           | 250 ft  | 133 ft       |
| Common Path of Travel | 20 ft (Unlimited Occupants) / 75 ft x 50 Occupants* | 0            |
| Dead End Distances    | 20 ft   | 0            |



LS1 FIRST AND SECOND FLOOR LIFE SAFETY  
SCALE: 3/32"=1'-0"

FIRST FLOOR PLAN

SECOND FLOOR PLAN

**FIRE RISK MANAGEMENT, INC.**  
Professional Engineers & Fire Consultants  
100 N. W. 20th St. Suite 200  
Portland, ME 04107

REVISIONS

| No. | Description | Date |
|-----|-------------|------|
| 3   |             |      |
| 2   |             |      |
| 1   |             |      |

PROJECT NAME: FITNESS FACTORY MAINE  
PORTLAND SPORTS COMPLEX

LIFE SAFETY PLAN

512 WARREN AVENUE  
PORTLAND, ME

LS-1