



Reviewed for Code Compliance  
Inspectors Division  
Approved with Conditions  
Date: 02/27/17

[Click here to enable](#) desktop notifications for City of Portland Mail. [Learn mo](#)

More

# Mail

COMPOSE

173 Holm Ave. Permit Application 2016-02895 - Plan Review Questions/Comments Inbox x


## Inbox

Starred

Sent Mail

Drafts

More

 Brian +



**Brian Stephens**

To: Rush Construction, I have reviewed the submitted drawings and have the fo...



**Dominic Rush** <RushConstruction@hotmail.com>

7:12 AM (56 minutes ago)

to me

Good morning Brian  
 Sorry for slow response  
 When do you think I will see permit  
 Thanks Diminic Rush

**From:** Brian Stephens [mailto:[bstephens@portlandmaine.gov](mailto:bstephens@portlandmaine.gov)]

**Sent:** Tuesday, February 7, 2017 4:03 PM

**To:** [rushconstruction@roadrunner.com](mailto:rushconstruction@roadrunner.com)

**Subject:** 173 Holm Ave. Permit Application 2016-02895 - Plan Review Questions/Comments

To: Rush Construction,

I have reviewed the submitted drawings and have the following questions:

1. Do you intend to reuse (or replace) the existing guards? No we plan to keep guard rails
2. Please describe mechanical fasteners to be used at the base and top of each new 4x4 post. Going to use simpson HL 55 g
3. Please describe the size/spacing of collar ties. 16" oc

Thank you for your response,  
Brian

No recent chats  
[Start a new one](#)

