

4/28/03

Deal Above Kitchen - Existing 2x10 cut joint cut across 1/2 the height.
By previous plumber - Contractor is going to Sister
new 2x12 & new Paper w/ Jt

4/29 - Above 2x10 Problem resolved as outlined above
Framing OK - Still needs Plumbing & elec B-4
OK to Close R w/ Jt

7/3/03 OK to close. AR

7/10/03 Completed.

AR