P Who windows Anderson
Doors no sizes
Low E

Please revise and provide new details for both collar ties and ceiling/rafter ties per R 802.3.1.

2 CROSS SECTION
3/8" = 1'-0"

OMIT (NO GARAGE ADDITION)

Provide framing detail of how the dog house will be tied in to roof rafters.

4 SLAB & FROST WALL @ GARAGE
3/4" = 1'-0"

OMIT

1 CROSS SECTION
3/8" = 1'-0"

no Hang?

? what plywood

5 SOFFIT DETAIL
3/4" = 1'-0"

3 CROSS SECTION
3/8" = 1'-0"

6 SOFFIT DETAIL
3/4" = 1'-0"

To meet the allowance of R-38 insulation must go over the wall top plate. Please revise and provide details.

Per IECC table 402.1.1, R-20 is required for wood framed walls.

7 SOFFIT DETAIL
3/4" = 1'-0"

CLIENT
CLIENT

NOTE: ... FOR INFORMATIONAL PURPOSES ONLY. IF USED FOR CONSTRUCTION, THE CONTRACTOR SHALL ASSUME ALL RESPONSIBILITY FOR LOCAL CODE COMPLIANCE. ALL DRAWINGS, PLANS, SKETCHES, ETC. ARE ... AND DESIGN INC. ARE NOT REGISTERED ARCHITECTS OR ENGINEERS. ALL DIMENSIONS AND SPECIFICATIONS TO BE ... BY THE OWNER AND CONTRACTOR

CURRAN DRAFTING & DESIGN
P.O. BOX 4512
PORTLAND, MAINE 04112
(207) 831-1844 Tel
WWW.CDRAFTINGDESIGN.COM

PROJECT NAME

SANBORN ADDITION

PROJECT LOCATION

54 DORSET ST.
PORTLAND, ME 04102

BUILT BY

SHEET NAME

CROSS SECTIONS & DETAILS

© ALL RIGHTS RESERVED
ALL IDEAS, DESIGNS AND PLANS INDICATED OR REPRESENTED BY THESE DRAWINGS ARE OWNED AND ARE THE PROPERTY OF CURRAN DRAFTING & DESIGN INC. AND WERE CREATED AND DEVELOPED FOR USE ON, OR IN CONNECTION WITH THE SPECIFIED PROJECT. NONE OF SUCH IDEAS, DESIGNS AND PLANS SHALL BE USED BY ANYONE FOR ANY PURPOSE WHATSOEVER WITHOUT THE WRITTEN PERMISSION OF CURRAN DRAFTING AND DESIGN INC.

DRAWN BY: M.P.C.
CHECKED BY: M.P.C.

SCALE: AS-NOTED
DATE: 02/21/2006
FILE NUMBER 06-0004
REVISIONS:

A-3