

 COORDINATE HEIGHT WITH SPRINKLER MAIN AND RISERS ON WALL ABOVE. REFER TO SHEET FX101 CONTRACTOR TO PROVIDE SPOOL SECTION FOR REMOTE READOUT WATER METER INSTALLATION BY UTILITY COMPANY FINISHED FLOOR PROVIDE SLEEVE AND SLEEVE SEAL AT FLOOR PENETRATION 4" TO WATER MAIN. REFER TO SHEET CU101 FOR CONTINUATION
THERMAL SHIELD INSERT BACK UP MATERIAL UL THERMAFIBER OR FOAM FIRESTOP CAULK CHEDULE 40 BLACK STEEL PIPE SLEEVE (SIZE FOR PIPE AND INSULATION) INSULATION PIPE
COPPER PIPING WITH INSULATION FROM THERMOSTATIC MIXING VALVE DIELECTRIC UNION 1-1/4" GALVANIZED OR STAINLESS STEEL TO MATCH SAFETY SHOWER EQUIPMENT
PLUGGED INLET STAINLESS STEEL ACTUATING ARM AND PULL-ROD HANDLE AT 69" AFF MAX WATER SPRAY PATTERN MIN 20" DIA @ 60" AFF EMERGENCY EYE/FACEWASH PLUGGED DRAIN OUTLET
AND EYEWASH DETAIL