



1 MASONRY WALL 1 ELEVATION

SF203 / SCALE: 1/4" = 1'-0"
SF101, SF503




2 MASONRY WALL 2 ELEVATION

SF203 / SCALE: 1/4" = 1'-0"
SF101




3 MASONRY WALL 3 ELEVATION

SF203 / SCALE: 1/4" = 1'-0"
SF101




4 MASONRY WALL 4 ELEVATION

SF203 / SCALE: 1/4" = 1'-0"
SF101




5 MASONRY WALL 5 ELEVATION

SF203 / SCALE: 1/4" = 1'-0"
SF101



6 8" REINF MASONRY WALL TO SLAB CONN DETAIL

SF203, SF204 / SCALE: 1 1/2" = 1'-0"



7 CONC SLAB TO 8" MASONRY WALL CONN DETAIL

SF101, SF203, SF204 / SCALE: 1 1/2" = 1'-0"


DRAWING NOTES:

- COORDINATE EXACT SIZE AND LOCATION OF MASONRY OPENINGS WITH ARCHITECTURAL PLANS.
- LAP SPLICE #5'S = 1'-8".

KEYNOTES: (THIS SHEET ONLY)

- CONTINUOUS HORIZONTAL JOINT REINFORCEMENT AT 1'-4" ON-CENTER.
- 8" REINFORCED CMU LINTEL WITH (1) #5. EXTEND REINFORCING 2'-0" PAST OPENING, UNLESS NOTED OTHERWISE.
- CONTINUOUS 8" CMU BOND BEAM WITH (1) #5.
- (1) #5 IN JAMB. EXTEND REINFORCING 2'-0" PAST OPENING IN EACH DIRECTION.
- #5 VERTICAL AT 8" ON-CENTER. GROUT CELLS SOLID.
- #5 VERTICAL AT 1'-4" ON-CENTER. GROUT CELLS SOLID.
- #5 VERTICAL AT 2'-0" ON-CENTER. GROUT CELLS SOLID.
- #5 VERTICAL AT 2'-8" ON-CENTER. GROUT CELLS SOLID.
- #5 DOWELS, 3'-0" LONG, WITH SPACING TO MATCH VERTICAL WALL REINFORCING.
- TOP OF CMU WITH 3/8" x 6" STEEL PLATE. GROUT COURSE BELOW SOLID. SEE DETAIL 11/SF501.
- 8" REINFORCED CMU SILL WITH (1) #5. EXTEND REINFORCING 2'-0" PAST OPENING, UNLESS NOTED OTHERWISE.
- 16" REINFORCED CMU LINTEL WITH (1) #5. EXTEND REINFORCING 2'-0" PAST OPENING, UNLESS NOTED OTHERWISE.
- STEEL POUR STOP AT CMU WALL/DOOR OPENING. SEE DETAIL 11/SF502 (SIMILAR).

GRAPHIC SCALES



CHECK GRAPHIC SCALES BEFORE USING

STATE OF MAINE PUBLIC SCHOOL PROJECT	
TITLE: PORTLAND PUBLIC SCHOOLS NEW FRED P. HALL ELEMENTARY SCHOOL	
LOCATION: 23 ORONO ROAD, PORTLAND, ME	
TITLE THIS DWG: MASONRY WALL ELEVATIONS 1	
DRAWN BY: MJC	CHECKED BY: DNM
NO. DATE	DESCRIPTION
	REVISIONS
	DATE 03/17/17
DRAWING NO. SF203 SHEET NO. 103 OF 312	