



Laurie Leader <lr@portlandmaine.gov>

---

**RE: Won-Door**

1 message

---

**Laura Clebak** <lclebak@oakpoint.com>

Thu, Jun 8, 2017 at 3:29 PM

To: Laurie Leader <lr@portlandmaine.gov>

Cc: Jason Grant <jgrant@portlandmaine.gov>, Tyler Barter <tbarter@oakpoint.com>

Laurie,

The specification is attached.

The 2009 NFPA 101 also permits these types of doors in Section 7.2.1.4.1(4)(b) because they meet Section 7.2.1.14. If you look at the 2009 NFPA 101 Handbook, Exhibit 7.25, on page 170 shows a Won-Door as part of the discussion on Section 7.2.1.14.

Thank you,

Laura

**From:** Laurie Leader [mailto:[lr@portlandmaine.gov](mailto:lr@portlandmaine.gov)]

**Sent:** Thursday, June 08, 2017 3:18 PM

**To:** Tyler Barter; Laura Clebak

**Cc:** Jason Grant

**Subject:** Won-Door

Laura,

Thanks for chatting with me regarding fire walls and Won-Doors. I do not see any specifications in the spec book for these doors. Can you either point out where we can find this or send us a copy of the specification.

I have copied Jason Grant, NFPA plan reviewer, on this email as well. I think he may have some questions regarding the Won-Door meeting NFPA standards.

Thanks,

Laurie

--

Laurie Leader  
Plan Review/Code Enforcement  
City of Portland, Maine  
Inspections Division  
389 Congress Street  
Portland, ME 04101

P: [207-874-8714](tel:207-874-8714)

F: [207-874-8716](tel:207-874-8716)

E: [lrl@portlandmaine.gov](mailto:lrl@portlandmaine.gov)

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

---

 **102233 fl - accordion folding partitions.pdf**  
49K