


275 0048001



# Portland Fire Department Monthly School Inspection

Name: Hall School	Address: Orano Rd.	
Principal: Cynthia Remick	Emergency contact #:	
Date inspected: 10/21/14	Inspector: Shift 4	
	Time in: 11:00	Time out:

Fire Drills Conducted Yes  No  Date of last drill: \_\_\_\_\_

**EXITS:**

	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	✓		
Exit signs & Emer lights properly lit	✓		

**Fire Alarm System**

Panel clear, accessible, operational	✓		
--------------------------------------	---	--	--

**Fire Extinguishers**

Extinguishers full & tagged annually	✓		
Extinguishers accessible	✓		

**Heating System**

Boiler room clear of all combustibles	✓		
Boiler room properly rated/protected	✓		

**Electrical system**

Extension cord use vs. permanent	✓		
Electrical panels clear & accessible	✓		
Electrical circuits clearly identified	✓		

**Sprinkler System**

Sprinkler heads >18" of clearance	✓		
Sprinkler Rm & FDC labeled & clear	✓		
Spare heads & wrench supplied	✓		
Sprinkler system tagged insp. date	✓		

**House Keeping**

Furnishings & decorations flame rest	✓		
Art work displayed < 20% wall area	✓		
Housekeeping organized for safety	✓		

Additional Safety Concerns: