

Portland Fire Department Monthly School Inspection

Name:	Address: <u>23 Olono</u>
Principal: <u>K. Harrison</u>	Emergency contact #:

Date inspected: <u>5-9-12</u>	Inspector: <u>Capt. Cruz</u>
Time in: <u>1000</u>	Time out: <u>1045</u>

Fire Drills Conducted Yes No Date of last drill: April

EXITS: Pass Fail Notes:

Exit / Escapes clear of obstructions	✓		
Exit signs & Emer lights properly lit	✓		

Fire Alarm System

Panel clear, accessible, operational	✓		
--------------------------------------	---	--	--

Fire Extinguishers

Extinguishers full & tagged annually	✓		
Extinguishers accessible	✓		

Heating System

Boiler room clear of all combustibles	✓		
Boiler room properly rated/protected	✓		

Electrical system

Extension cord use vs. permanent	✓		
Electrical panels clear & accessible	✓		
Electrical circuits clearly identified	✓		

Sprinkler System


Sprinkler heads >18" of clearance	✓		
Sprinkler Rm & FDC labeled & clear	✓		
Spare heads & wrench supplied	✓		
Sprinkler system tagged insp. date	✓		

Quarterly Insp. - ?

House Keeping

Furnishings & decorations flame rest	✓		
Art work displayed < 20% wall area	✓		
Housekeeping organized for safety	✓		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <u>Hall Elem</u>	Address: <u>28 Crown Rd</u>
Principal: <u>Holly Hassen</u>	Emergency contact #:

Date inspected: <u>6-12-12</u>	Inspector: <u>Capt. Clark</u>
Time in:	Time out:

Fire Drills Conducted Yes No Date of last drill: 5-31-12

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exit signs & Emer lights properly lit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Fire Alarm System	Pass	Fail	Notes:
Panel clear, accessible, operational	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Fire Extinguishers	Pass	Fail	Notes:
Extinguishers full & tagged annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Extinguishers accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	


Heating System	Pass	Fail	Notes:
Boiler room clear of all combustibles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Boiler room properly rated/protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Electrical system	Pass	Fail	Notes:
Extension cord use vs. permanent	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical panels clear & accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical circuits clearly identified	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Sprinkler System	Pass	Fail	Notes:
Sprinkler heads >18" of clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler Rm & FDC labeled & clear	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Spare heads & wrench supplied	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler system tagged insp. date	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

House Keeping	Pass	Fail	Notes:
Furnishings & decorations flame rest	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Art work displayed < 20% wall area	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housekeeping organized for safety	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name:	Address: 23 00th Ave		
Principal: Cynthia Renick	Emergency contact #:		
Date inspected: 9-27	Inspector: Capt. Carr	Time in:	Time out:

Fire Drills Conducted Yes No Date of last drill: _____

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass Fail

Notes:

<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>	
-------------------------------------	--------------------------	--

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date


<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <u>Hall School</u>	Address: <u>ORONO RD</u>
Principal: <u>Rennick</u>	Emergency contact #:

Date inspected: <u>12-5-12</u>	Inspector: <u>Capt. Case</u>
Time in:	Time out:

Fire Drills Conducted Yes No Date of last drill: November

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Notes:

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Additional Safety Concerns: