CBL: 276 B008001

Generated by RES*check* Package Generator

Compliance Certificate

Project Title: Single Family Residence

Report Date: 12/30/10

Energy Code:	**2003 IECC**
Location:	**Portland, Maine**
Construction Type:	**Single Family**
Glazing Area Percentage:	**15%**
Heating Degree Days:	**7378**

Construction Site:
79 Candlewick Rd.
Portland, ME 04102
Permit # 10-1345
Permit Date: 10/26/2010

Owner/Agent:
Paul Grant
21 Greenwood Rd.
Brunswick, ME 04011

Designer/Contractor:

Compliance: **Passes**

Assembly	Cavity R-Value	Cont. R-Value	Glazing or Door U-Factor
Ceiling:	41.0		
Wall:	19.0	19.0	
Window:			0.350
Door:			0.350
Floor:	19.0		
Furnace: 80 AFUE			

Compliance Statement: The proposed building design described here is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2003 IECC requirements in the RES*check* Package Generator and to comply with the mandatory requirements listed in the RES*check* Inspection Checklist.

Name - Title _____ Signature _____ Date _____