


Downeast is only setting tank
and tying into gas line installed
by others

Jill Worsham
16 Glen Haven Rd West
303-881-7069



* No windows or doors within
Five (5) feet.

* No sources of ignition within
Ten (10) feet

* LP tank sets on precast cement
pad.

* Tank is at least 75 feet from road

Steve McCusker
Downeast Energy
South Portland ME
04106
CELL - 651-6677