

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

CHAREST DEBRA & BRUCE LITTLE JTS

**Located at**

55 GLEN HAVEN W

**PERMIT ID:** 2017-01683

**ISSUE DATE:** 11/07/2017

**CBL:** 277 I009001

has permission to **Amendment #1 to BP2017-01226. Replace existing stairs on front of house.**  
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Brian Stephens

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

single-family

***Building Inspections***

**Use Group:** R      **Type:**  
Single Family Dwelling Unit  
First Floor  
MUBEC/IRC-2009

***Fire Department***

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status of Permit or Schedule an Inspection at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Footings

Framing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2017-01683	<b>Date Applied For:</b> 10/25/2017	<b>CBL:</b> 277 I009001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> single family	<b>Proposed Project Description:</b> Amendment #1 to BP2017-01226. Replace existing stairs on front of house.			
<b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Christina Stacey <b>Approval Date:</b> 10/30/2017				
<b>Note:</b>				<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
<ol style="list-style-type: none"> <li>1) .All conditions from previous permits for this project are still in effect with the issuance of this permit.</li> <li>2) This approves the repair or rebuild of entry steps within the existing non-conforming footprint.</li> <li>3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li> </ol>				
<b>Dept:</b> Building Inspecti <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Brian Stephens <b>Approval Date:</b> 11/07/2017				
<b>Note:</b>				<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
<ol style="list-style-type: none"> <li>1) The stair construction shall comply with IRC Sec. R311 which includes, but is not limited to, a maximum riser height of 7-3/4" and a minimum net tread of 10", and nosings not less than 3/4" but not more than 1-1/4" where solid risers are required.</li> <li>2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.</li> <li>3) If there are 4 or more risers, a graspable handrail is required on one side of stairs with ends returned. The top rail of a guardrail can be used as the handrail if it meets graspability dimensions. A 2x4 is not considered graspable. One handrail is required on ramps exceeding a pitch of 12:1.</li> <li>4) When a landing or deck is over 30" above a floor or grade, a guard is required at a minimum height of 36". Guardrail openings shall be less than 4". The stair rail can be 34" to 38" in height with openings less than 4-3/8", and at the open side of a stair, less than 6" is allowed at the triangle of the tread/riser at the bottom rail.</li> <li>5) Beams &amp; girders shall be solid or built up and bearing, notched or supported by approved anchors per IBC Sec. 2308.7 and IRC R502.6</li> <li>6) .All conditions from previous permits for this project are still in effect with the issuance of this amendment.</li> <li>7) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.</li> </ol>				