

ELECTRICAL PERMIT

City of Portland, Me.

277-A-A-015



277-A-A-015

To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date May 8, 1997

Permit # 15768


LOCATION: 75 Woodyville

OWNER Mark Deane ADDRESS _____

							TOTAL EACH FEE				
OUTLETS		Telephone		Data		CATV			.20		
		Receptacles		Switches		Smoke Detector			.20		
FIBER OPTICS									15.00		
FIXTURES		incandescent		fluorescent					.20		
		fluorescent strip							.20		
SERVICES	1	Overhead			100	TTL AMPS TO	800	1	15.00	15.00	
		Underground					800		15.00		
Temporary Service		Overhead				AMPS OVER	800		25.00		
		Underground					800		25.00		
METERS	1	(number of)						1	1.00	1.00	
MOTORS		(number of)							2.00		
RESID/COM		Electric units							1.00		
HEATING		oil/gas units		Interior		Exterior			5.00		
APPLIANCES		Ranges		Cook Tops		Wall Ovens			2.00		
Insta-Hot		Water heaters		Fans		Dryers			2.00		
Disposals		Dishwasher		Compactors		Others (denote)			2.00		
MISC. (number of)		Air Cond/win							3.00		
		Air Cond/cent				Pools			10.00		
		HVAC		EMS		Thermostat			5.00		
		Signs							10.00		
		Alarms/res							5.00		
		Alarms/com							15.00		
		Heavy Duty(CRKT)							2.00		
		Circus/Carnv							25.00		
		Alterations							5.00		
		Fire Repairs							15.00		
		E Lights							1.00		
		E Generators							20.00		
PANELS	1	Service		Remote		Main		1	4.00	4.00	
TRANSFORMER		0-25 Kva							5.00		
		25-200 Kva							8.00		
		Over 200 Kva							10.00		
							TOTAL AMOUNT DUE				
MINIMUM FEE/COMMERCIAL 35.00							MINIMUM FEE		25.00		25.00

INSPECTION: Will be ready 5/13/97 11:30 AM or will call _____

CONTRACTORS NAME Roger Hebert MASTER LIC. # 15768
 ADDRESS 73 Bell Street, Portland 04102 LIMITED LIC. # _____
 TELEPHONE 878-5688

SIGNATURE OF CONTRACTOR 

ELECTRICAL INSTALLATIONS

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection _____

By Inspector _____

INSPECTION: Service 5/13/97 by [Signature]

Service called in 5/13/97 (Linda)

Closing-in _____ by Camp

PROGRESS INSPECTIONS:	
<u>5/13/97</u>	<u>(SERVICE)</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

5/13/97
[Signature]

DATE:	REMARKS:
<u>5/13/97</u>	<u>Violations:</u>
	<u>- sheetrock screws in meter socket</u>
	<u>- Bad ground meter</u>

SIGNATURE OF CONTRACTOR

TELEPHONE

ADDRESS

CONTRACTOR'S NAME

INSPECTION: Will be ready _____ or will call _____

MINIMUM RECOMMENDATIONAL \$5.00

TOTAL AMOUNT DUE

Over 200 Kva

25-500 Kva

0-25 Kva

Service

Transformers

E Generators

E Motors

Panelboards

Control Panels

Automatic

Armatures

HVAC

EMS

Thermostat

Fans

Class (battery)

Control Panels

Emergency

Electric Units

Number of

Services

Features

First Office

Receipts

Insulated Strip

Insulators

Form 1-1-73

Form 1-1-73

TOTAL EACH YEAR