

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716


Permit No: 08-0273	Issue Date: 03/26/2006	CBL: 283 E008001
-----------------------	---------------------------	---------------------

Location of Construction: 106 Longwood Dr	Owner Name: Goldfarb Matthew S &	Owner Address: 106 Longwood Dr	Phone:
Business Name:	Contractor Name: Aero Heating and Ventilating	Contractor Address: 378 Presumpscot Portland	Phone 2077612092
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone:

Past Use: Single Family	Proposed Use: Single Family / Install 275 gallon oil tank in the basement.	Permit Fee: \$270.00	Cost of Work: \$24,255.00	CEO District: 3
Proposed Project Description: Install Heating System		FIRE DEPT: <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: R-3 Type: SB IMC 2003 UFPA 211 Signature: CLM 3/24/06	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Signature: Date:		

Permit Taken By: gg	Date Applied For: 03/26/2008	Zoning Approval
------------------------	---------------------------------	------------------------

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p>Special Zone or Reviews</p> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <i>OK</i> Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>	<p>Zoning Appeal</p> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	<p>Historic Preservation</p> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied <i>OK</i>
	Date: <i>[Signature]</i>	Date:	Date: <i>[Signature]</i>




I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



283 2008

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 106 LONGWOOD DR. Use of Building SINGLE FAMILY Date 3/26/08
 Name and address of owner of appliance MRT & MRS. MATT GOLD FARB, ESQ.
106 LONGWOOD DR. PORTLAND ME 04102
 Installer's name and address AERO HEATING & VENTILATING INC. (AUGUST FUEL)
378 PRESUMPTUOIST ST., PORTLAND ME 04103 Telephone 761-2892 FAX 761-4471

Location of appliance:

- Basement
- Floor
- Attic
- Roof

Type of Fuel:

ELECTRIC A/C


- Gas
- Oil
- Solid

Appliance Name: UNICO SYSTEM - IN SERIES

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____



The Type of License of Installer

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # _____
- Other REF. HANDLING CERT.

#029203976

Type of Chimney: N/A

Masonry Lined
Factory built _____

Metal
Factory Built U.L. Listing # _____

Direct Vent
Type _____ UL# _____

Type of Fuel Tank N/A

- Oil
- Gas

Size of Tank 275 GAL.

Number of Tanks 1

Distance from Tank to Center of Flame 15 feet.

Cost of Work: \$ 24,255.

Permit Fee: \$ 270.00

Approved Sub. Jim Sabombe
for Aero Heating

Approved with Conditions

Fire: _____ See attached letter or requirement

Ele.: _____

Bldg.: _____

Cheryl M
Inspector's Signature

3/26/08
Date Approved

Signature of Installer [Signature]

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 08-0273	Date Applied For: 03/26/2008	CBL: 283 E008001
------------------------------	--	----------------------------

Location of Construction: 106 Longwood Dr	Owner Name: Goldfarb Matthew S &	Owner Address: 106 Longwood Dr	Phone:
Business Name:	Contractor Name: Aero Heating and Ventilating	Contractor Address: 378 Presumpscot Portland	Phone (207) 761-2092
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	


Proposed Use: Single Family / Install 275 gallon oil tank in the basement.	Proposed Project Description: Install Heating System
--	--

Dept: Zoning	Status: Approved	Reviewer: Chris Hanson	Approval Date: 03/26/2008
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Dept: Building	Status: Approved with Conditions	Reviewer: Chris Hanson	Approval Date: 03/26/2008
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) Tanks shall be installed per NFPA 58			
2) The appliance shall be installed in accordance with the IMC 2003 and NFPA 211			
3) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules			

M2 & Mrs Matt (Golf) FAIRB E59
106 Longwood Dr
Portland, ME 04104

3/26/08

2 cars



Longwood Drive

Mat 6 Mud mat 1977 Cold Falls
106 Rockwood Park
Portland ME 04104

3/24/08

L. C. COST

