Reviewed for Code Compliance
Inspections Division
Date: 08/30/16

*ELECTRICAL PACKAGES – Job#2658653*

| NO. | TAG | PACKAGE # | LOCATION | SWITCHES | | OPTION | FANS CONTROLLED | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | LOCATION | QUANTITY | | TYPE | ø | H.P. | VOLT | FLA |
| 1 | | SC-211110FP | Wall Mount In SS Box | Utility Cabinet Right | 1 Light<br>1 Fan | Smart Controls Thermostatic Control | Exhaust | 1 | 1.500 | 230 | 6.8 |
| | | | | | | | Supply | 1 | 1.000 | 230 | 6.1 |

*TYPICAL SC-TYPE CONTROL SYSTEM*
*WITH REMOTE MOUNTED PANEL*

## MEETS AUTOMATIC ACTIVATION REQUIREMENTS

IMC 507.2.1.1 TYPE I HOOD SYSTEMS SHALL BE DESIGNED AND INSTALLED TO AUTOMATICALLY ACTIVATE THE EXHAUST AN WHENEVER COOKING OPERATIONS OCCUR. THE ACTIVATION OF THE EXHAUST FAN SHALL OCCUR THROUGH AN INTERLOCK WITH THE COOKING APPLIANCES, BY MEANS OF HEAT SENSORS, OR BY MEANS OF OTHER APPROVED METHODS.

NFPA96 8.2.3.3 THE EXHAUST FAN SHALL BE PROVIDED WITH A MEANS SO THAT THE FAN IS ACTIVATED WHEN ANY APPLIANCE UNDER THE HOOD IS TURNED ON.

**REVISIONS**

| DESCRIPTION | DATE: |
|---|---|
| | |
| | |
| | |
| | |

CAPTIVEAIRE
www.captiveaire.com
MAINE OFFICE
PO Box 86, 179 South Rd., Topsfield, ME, 04490 PHONE: (207) 796-2590 FAX: (919) 227-5946 EMAIL: reg21@captiveaire.com

Tin Pan Bakery
897 Brighton Ave,
PORTLAND, ME, 04102

**DATE:** 5/16/2016

**DWG.#:** 2658653

**DRAWN BY:** BFC-21

**SCALE:** 3/4" = 1'-0"

**MASTER DRAWING**

**SHEET NO.**
7