

EXHAUST FAN INFORMATION - Job#2745465

FAN UNIT NO.	TAG	FAN UNIT MODEL #	CFM	ESP.	RPM	HP.	B.H.P.	Ø	VOLT	FLA	WEIGHT (LBS.)	SDNES
1		SIF11BD	1000	0.750	1890	1.000	0.6790	1	115	9.0	202	16.5

MUA FAN INFORMATION - Job#2745465

FAN UNIT NO.	TAG	FAN UNIT MODEL #	BLOWER	HOUSING	CFM	ESP.	RPM	HP.	B.H.P.	Ø	VOLT	FLA	WEIGHT (LBS.)	SDNES
2		INLINE1-G10	G10D	INLINE1	750	0.750	969	1.000	0.7820	1	115	10.2	219	10.6

FAN OPTIONS

FAN UNIT NO.	TAG	OPTION (Qty. - Descr.)
1		1 - SIF11 - Straight discharge. Square Duct Connection.
		1 - SIF11 - Inlet - Square Duct Connection
		1 - SIF - Horizontal Overhead Mount - Pre-Installed Mounts (G1-36).
		1 - I 1S-BDD Damper
		1 - Extra Set of Belts
		1 - Hanging Spring Vibration Isolators (Set of 4), For Indoor or Outdoor use with Square Inline Fans. (HSA125)
		1 - Full Grating For Untempered Fans
2		1 - ECH Wiring Package-Supply Fans Untempered- Manual Speed Control.
		1 - INLINE1 Indoor Hanging Option - Includes 2 HSA125 Hanging Spring Isolators per Uni-Strut
		1 - 3 Year Extended Motor Warranty

FAN ACCESSORIES

FAN UNIT NO.	TAG	EXHAUST	SUPPLY
1		GREASE CUP	GRAVITY DAMPER
		WALL MOUNT	MOTORIZED DAMPER
		DISCHARGE	WALL MOUNT
2		YES	YES


FAN SOUND INFORMATION

FAN UNIT NO.	MOTOR	RPM	LVA	SDNES	DBA	DISTANCE FT	DCTAVE 1	DCTAVE 2	DCTAVE 3	DCTAVE 4	DCTAVE 5	DCTAVE 6	DCTAVE 7	DCTAVE 8
1	Exhaust	1890	78.7	16.5	67.2	5	89.7	82.2	77.1	77.3	71.6	69.3	66.4	60.6
2	Supply	969	71.9	10.6	60.4	5	73.9	71.6	70.6	67.4	65.9	65.6	60.7	58.1

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted
 Approved with NO Exception Taken
 Rejected and Resubmit

Signature _____ Date _____



CAPTIVEAIR

JOB Tinpan Bakery
 LOCATION Biddeford, ME,
 DATE 8/18/2016 JOB # 2745465
 DWG # 2 DRAWN BY BFC-21